

**DECLARATION OF PERFORMANCE****According to Construction Products Regulation EU N° 305/2011  
N° 020 - CPR - 2013**1. *Unique Product identification code:*

**S4-34800 (EN54-11 & 17)**  
**S4-34842 (EN54-11 & 17)**  
**S4-34805 (EN54-11 & 17)**  
**S4-34845 (EN54-11 & 17)**

2. *Type, batch or serial number or any other element allowing identification of the construction product as required pursuant to Article 11(4):*

<b>Analogue Addressable Type A indoor manual Callpoint with Glass non re-settable element</b>	<b>S4-34800</b>
<b>Analogue Addressable Type A indoor manual Callpoint with Glass non re-settable element and with protective cover</b>	<b>S4-34842</b>
<b>Analogue Addressable Type A indoor manual Callpoint with Plastic re-settable element</b>	<b>S4-34805</b>
<b>Analogue Addressable Type A indoor manual Callpoint with plastic re-settable element and with protective cover</b>	<b>S4-34845</b>

3. *Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:*

**Fire detection and fire alarm systems installed in and around buildings**

4. *Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11(5):*

**Gent By Honeywell (Novar Systems Limited)**

**Manufactured by:**  
**Honeywell Life Safety Systems**  
**140 Waterside Road**  
**Hamilton Industrial Park**  
**Leicester**  
**LE5 1TN**  
**United Kingdom**

5. *Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12(2):*

**Not applicable**

6. *System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:*

**System 1**

7. In case of the declaration of performance concerning a construction product covered by the harmonized standard:

**Loss Prevention Certification Board (BRE Global Limited)**

Performed type testing and the initial inspection of the manufacturing plant and of the factory production control with continuous surveillance assessment and approval of the factory production control under system 1 and issue the EC certificate of conformity.

**0832-CPR-F0200 (S4-34800, S4-34842, S4-34805 and S4-34845)**

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:

**Not applicable, see item 7**

9. Declared Performance:

All requirements including all Essential Characteristics and the corresponding performances for the intended use or uses indicated in point 3 above have been determined as described in the hEN mentioned in the table below

Essential characteristics	Performance	Harmonised technical specification	
		EN54-11:2005	EN54-17:2005/ AC2007
Performance under fire conditions	Pass		5.2
Operational reliability	Pass		4
Durability of operational reliability: temperature resistance	Pass		5.4, 5.5
Durability of operational reliability; vibration resistance	Pass		5.9 to 5.12
Durability of operational reliability; humidity resistance	Pass		5.6, 5.7
Durability of operational reliability; corrosion resistance	Pass		5.8
Durability of operational reliability; electrical stability	Pass		5.3, 5.13
Nominal activation conditions/Sensitivity and performance under fire conditions	Pass	4.3.2, 4.4, 4.7.1, 4.7.4, 5.2, 5.3	
Operational reliability	Pass	4.2, 4.3.1, 4.5, 4.6, 4.7.2, 4.7.3, 4.7.5, 4.8, 5.4, 5.5	
Durability of operational reliability: temperature resistance	Pass	5.7, 5.9	
Durability of operational reliability: temperature resistance	NPD	5.8 (Outdoor devices only)	
Durability of operational reliability; vibration resistance	Pass	5.14 to 5.17	
Durability of operational reliability; humidity resistance	Pass	5.10, 5.12	
Durability of operational reliability; humidity resistance	NPD	5.11, 5.19 (Outdoor devices only)	
Durability of operational reliability; corrosion resistance	Pass	5.11, 5.13	
Durability of operational reliability; electrical stability	Pass	5.6, 5.18	

10 The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4

Signed for and on behalf of the manufacturer by:

Name and Function: Kishore Chauhan Sr Advanced Quality Engineer

Signature:  .....

Date: 16<sup>th</sup> January 2020.