

Electrical Energy Meter with integrated Serial Modbus interface EEM230-D-MO

Electrical energy meter with an integrated serial RS-485 Modbus interface allow direct reading of all relevant data, such as energy (total and partial), current, voltage, active and reactive power.

Main features

- Single-phase energy meter, 230 VAC 50 Hz
- Direct measurement up to 32 A
- Display of active power, voltage and current
- Modbus RTU interface to query the data
- Reactive power and cosφ available through interface
- Up to 247 meters can be connected to the Modbus interface
- 7-digits display
- Lead seal possible with cap as accessory
- Accuracy class B according to EN50470-3, accuracy class 1 according to IEC62053-21

Order Number

Standard Version: EEM230-D-MO MID Version: EEM230-D-MO-MID

Sealing caps: EEM230-SEALCAP (Bulk with 20 units)

Technical data

Precision class	B according to E		
	1 according to I	EC62053-21	
Operating voltage	230 VAC, 50 Hz		
	Tolerance –20 %	o / +15 %	
Reference/maximum	$I_{ref} = 5 A, I_{max} = 32$	2 A	
current			
Starting/minimum current	$I_{st} = 20 \text{ mA}, I_{min} = 0.25 \text{ A}$		
Power consumption	Active 0.4W		
ounting range 00'000.0099'999.99		9'999.99	
	100'000.099	9'999.9	
Pulses per kWh	LC-Display	2000 lmp./kWh	




Mounting


Mounting		
Mounting	On 35 mm rail, according to EN60715TH35	
Terminal connections main circuit	Conductor cross-section max. 6 mm², screwdriver pozidrive no. 1, Slot no. 1, torque: 1.2 Nm	
Terminal connections control circuit	Conductor cross-section max. 2.5 mm², screwdriver pozidrive no.0, Slot no.1, torque: 0.5 Nm	
Insulation characteristics	4 kV / 50 Hz test according to VDE0435 for energy meter part	
	6 kV 1.2/50 μs surge voltage according to IEC255-4	
	2 kV / 50 Hz test according to VDE0435 for Interface Device protection class II	
Ambient temperature		
Storage temperature	−30°+85°C	
Environment	Mechanical M2 Electromagnetic E2	
Relative humidity	95% at 25°+40°C, without condensation	
EMC/interference immunity	Surge voltage according to IEC61000-4-5 at main circuit 4 kV, at Modbus interface, 1 kV	
	Burst voltage according to IEC61000-4-4 at main circuit 4 kV, at Modbus interface 1 kV	
	ESD according to IEC61000-4-2, contact 8 kV, air 15 kV	

Dimension diagram

85 62.3 45 45 35.6 89.2



Display elements, direct measurement



T total (kWh)

■ T part (kWh)

2000 pulses/kWh

P (kW)

U (V)

■ I(A)

Indicates the total consumption Indicates the partial consumption.

This value can be reset


Indicates the instantaneous power

Indicates the voltage


Indicates the current

Pulsates according to the amount of used power. Error indication (Line 1L/2L inverted) pulsating with 600/600 ms

Wiring Diagram



Menu to display the value on LC



Technical data Modbus

Protocol	Modbus RTU according to IDA specification	
Bus system	RS-485 Serial line	
Transmission rate (bps)	4800-9600-19'200-38'400-57'600-115'200. The transmission Baud rate is automatically detected	
Transmission mode	Even parity: 8 data bits, 1 stop bit Odd parity: 8 data bits, 1 stop bit No parity: 8 data bits, 2 stop bits The transmission Mode is automatically detected	
Bus cable	Twisted, shielded, $2 \times 0.5 \text{ mm}^2$, 1200 m max.	
Response time (to system response)	Write: up to 60ms Read: up to 60ms	

- The communication is ready 30 s after the 'Power On'.
- Refresh time for the data is 5 s. Therefore the delay between reads of the same data should be at least 5 s.
- The use of energy meters in bus with intensive communication can increase the data refresh time.
- 247 devices can be connected to the Modbus. Over 128 devices, a repeater should be used.
- The interface don't have a terminal resistor, this should be provided external.
- For a description of the used registers please look at the 'Register Page'.

Data transmission

- Only «Read Holding Registers [03]/ Write Multiple Registers [16]» instructions are recognized.
- Up to 20 registers can be read at a time.
- The device supports broadcast messages.
- In accordance with the Modbus protocol, a register R is numbered as R 1 when transmitted.
- The device has a voltage monitoring system. In case of voltage loss, registers are stored in EEPROM (transmission rate, etc.)

Exception Responses

- ILLEGAL FUNCTION [01]: The function code is not implemented.
- ILLEGAL DATA ADDRESS [02]: The address of some requested registers is out of range or more than 20 registers have been requested.
- ILLEGAL DATA VALUE [03]: The value in the data field is invalid for the referenced register.

Change the Modbus address direct on device

- In the menu, go for «U»
- Push long (≥3 sec) → «Adr»
- Push short → address +1, push long → address +10
- Once the desired address is selected wait, to validate, till the root menu to come back

Registers

For double registers (4-5, 16-17, 28-29, 30-31) the high register is sent first (big-Endian). Partial counter (30-31) can be reset by writing 0 in both registers in the same message.

R	Read	Write	Description	Unit
1	X	VVIICE	Firmware-Version	Ex: 11 = FW 1.1
	X		Number of supported registers	Will give 40
3 4–5	X		Number of supported flags Baudrate	Will give 0
4-5	Χ		Baudrate	Ex: Baudrate High = 1 Baudrate Low = 49'664 1 × 65'536 + 49'664 = 115'200 bps
6	Х		Not Used	Will give 0
7	X		Type / ASN function	Will give «EE»
8	Х		Type / ASN function	Will give «M2»
9	Х		Type / ASN function	Will give «30»
10	Х		Type / ASN function	Will give «»
11	X		Type / ASN function	Will give «D-»
12	Х		Type / ASN function	Will give «MO»
13	Х		Type / ASN function	Will give « » for non MID or «–M» for MID Version
14	X		Type / ASN function	Will give « » for Non MID or «ID» for MID Version
15	X		HW vers. Modif.	Ex: 11 = HW 1.1
16–17	Χ		Serial number Low	Unique ASCII serial number
18	Х		Serial number High	Unique ASCII serial number
19	Х		Not Used	Will give 0
20	Χ		Not Used	Will give 0
21	Х		Not Used	Will give 0
22	Х		Status/Protect	0 = no problem 1 = problem with last communication request
23	Х		Modbus Timeout	ms
24	Х	X ¹⁾	Modbus Address	Range 1–247
25	Х		Error register	0 : No error 1 : Error
26	Х		Not Used	Will give 0
27	Х		Not Used	Will give 0
28–29	Х		WT1 total Counter Energy Total Tariff 1	10 ⁻² kWh (multiplier 0,01) Ex: WT1 total High = 13 WT1 total Low = 60'383 13 × 65'536 + 60'383 = 91'2351 = 9123.51 kWh
30–31	Х	Х	WT1 partial Counter Energy Partial Tariff 1	10 ⁻² kWh (multiplier 0,01) Ex: WT1 partial High = 13 WT1 partial Low = 60'383 13 × 65'536 + 60'383 = 91'2351 = 9123.51 kWh
32	Х		Not Used	Will give 0
33	X		Not Used	Will give 0
34	X		Not Used	Will give 0
35	Х		Not Used	Will give 0
36	X		URMS Effective Voltage	V Ex: 230 = 230 V
37	X		IRMS Effective Current	10 ⁻¹ A (multiplier 0,1) Ex: 314 = 31.4 A
38	Х		PRMS Effective active Power	10 ⁻² kW (multiplier 0,01) Ex: 1545 = 15,45 kW
39	X		QRMS Effective reactive Power	10 ⁻² kvar (multiplier 0,01) Ex: 1545 = 15,45 kvar
40	Х		cos phi	10 ⁻² (multiplier 0,01) Ex: 67 = 0,67

¹⁾ The Modbus Address register is not writable with a broadcast message.



Manufactured for and on behalf of the Environmental and Combustion Controls Division of Honeywell Technologies Sàrl, Rolle, Z.A. La Pièce 16, Switzerland by its Authorized Representative:

Saia-Burgess Controls AG Bahnhofstrasse 18 3280 Murten / Switzerland

+41 26 580 30 00 Phone +41 26 580 34 99 Fax

Subject to change without notice. Printed in Switzerland PP26-593 ENG03 07.2015