<u>Field Failure Rate [FFR]</u> is practically equivalent to the MTBF(Mean Time Between Failure), in million of Hours and year at 24 hours a day, 7 days a week. These FFR are gross. There are defined as the ration between the Cumulative producted Modules multiplied by Time and the number of modules returned to Murten for Repair, regardless whether the module is defective or not, if the user has made a mistake or not.

		Exan	nple for a T	ypical Conf	figuration	<u>A</u>	vailability:	Real	<u>configura</u>	<u>tion</u> to be fil	led by the User		<u>Availability</u>	
Type / Field Failure			1/FFR	Summ	FFR Total				1/FFR	Summ	FFR Total -			
	[mio h]	[Years												
PCD1, PCD2	(@ 24h/D]			6.5E-02	15.5 [years]	135 664 [ł] 100.00%	•		7.4E-02	13.5 [years]	118 192 [h] 100.00%
C100, C150	8.8	1000	1	1.0E-03					1	1.0E-03				
C2000	8.8	1000	0						0					
M110, 120, M150	0.6	70	0						1	1.4E-02	Availibi	l ity =FFR / (FFR	+ Rtime)	
M17x, M48x	0.5	60	1	1.7E-02					0				,	
M5xxx ¹⁾	0.2	20	0						0		Availabil	<u>ity</u> is based on		
E11x, E16x, E61x	4.4	500	3	6.0E-03					0		- the cor	dition where the	e customer i	s supposed
A200,220,250 ³⁾	3.5	400	1	2.5E-03					0		to have	spare modules		
A300, A400, A46x	6.1	700	6	8.6E-03					0		- so an e	estimated Repa	Ir time of 4 I	nours to
W1xx	1.8	200	0						3	1.5E-02	be applie	anu replaceu in	e delective i	nouule can
W2, W3, W4, W6	3.5	400	1	2.5E-03					0			5 u .		
W5	2.6	300	1	3.3E-03					0					
H1	3.5	400	0						1	2.5E-03				
R6000	2.6	300	0						0					
F2xxx	2.6	300	0						0					
F5xx	2.6	300	0						0					
T8 ¹⁾	1.8	200	0						0					
PCD7														
F1xx, F2xx	8.8	1000	2	2.0E-03					2	2.0E-03				
F6xx, F7xx, F8xx	0.9	100	1	1.0E-02					1	1.0E-02				
F74xx	1.8	200	1	5.0E-03					1	5.0E-03				
F75xx	1.8	200	1	5.0E-03					0					
R4xx	8.8	1000	1	1.0E-03					0					
R5xx	8.8	1000	1	1.0E-03					0		_			
H104S ¹⁾	1.8	200	0						0					
D23x	0.8	90	0						0					
D4xx ^{1) 2) 5)}	0.4	41	0						1	2.4E-02				
PCS1.Cxx ¹⁾	0.4	40	0						0					

¹⁾ Previsional estimation

²⁾ Backlight: 50% luminosity after 50'000h ⁵⁾ PCD7.D457VTSF: 2775. FIT, 360'326 h, 15014 T, 41.1 Jahre @65°C

³⁾ Subject to limited Life Time; for Relais typical 0.7 x 10⁶ cycles

Field Failure Rate [FFR] is practically equivalent to the MTBF(Mean Time Between Failure),

in million of Hours and year at 24 hours a day, 7 days a week.

These FFR are gross. There are defined as the ration between the Cumulative producted Modules multiplied by Time and the number of modules returned to Murten for Repair, regardless whether the module is defective or not, if the user has made a mistake or not.

			Exam	ple for a ⁻	Typical Conf	figuration	Av	Real configuration to be filled by the User Availability								
Type / Field Failure Rate [FFR]				1/FFR	Summ	FFR Total -				1/FFR	Summ	FFR Total -				
	[mio h]	[Years	1 I	ļ		-						-				
PCD3	(24h/D]			3.2E-02	31.4 [years]	275 422 [h] 100.00%			3.3E-02	29.9 [years	261 708	[h] 100.00%		
C100, C110	8.8	1000	1	1.0E-03	How to int	terpret the valu	ie of MTBF?		0							
C200	3.5	400	0						0							
M3xxx, M5xxx ⁴⁾	0.9	97	0		After a Tim	ne of one MTBF	all sample of a	a j	0		Availibil	ity=FFR / (FFI	R + Rtime)			
M6xxx @35°C					population	has to be repai	red and put ag	ain into								
M3xxx, M5xxx ⁴⁾	0.5	57	1	1.8E-02	service.	vo 100 or 1000		aanilaa	1	1.8E-02	Availabili	ity is based on				
M6xxx @50°C					= 11 you na	ve 100 01 1000	1000 failed on				- the con	idition where the	e customer	is supposed		
M3xxx. M5xxx ⁴⁾	0.3	33	0		=during a t	time slice of 10 v	vears the perc	entage of	0			spare modules	air time' of 1	hours to		
M6xxx @65°C					once failed	devices is:	,	sine ge er			localize a	and replaced th	ne defective	module can		
T66x ¹⁾	0.2	20	0		100% *	Time duration /	MTBF		0		be applie	ed.				
T76x ¹⁾	1.8	200	0		100%* 1	10 years/ 31.4=	31.8%		0							
					In the prac	tice.										
E11x, E16x, E61x	4.4	500	3	6.0E-03	- higher fai	ilures rate happe	ened durina th	e first vear	1	2.0E-03	-					
A200.220.250 ³⁾	3.5	400	1	2.5E-03	due to add	litional stress pro	ovoked by all r	nanual	2	5.0E-03						
A300, A400, A46x	6.1	700	1	1.4E-03	interventio	ns, and also in a	a smaller part o	due to the	1	1.4E-03						
W1xx	1.8	200	0		early morta	ality of compone	ents.		0		-					
W2, W3, W4, W6	3.5	400	0		- good env	ironment lowers	s the defective	rate	3	7.5E-03						
W5	2.6	300	1	3.3E-03	through lov	wer and constar	nt temperature	and	0							
H1	3.5	400	0		interventio	n etc	re, infrequent r	luman	0							
R5xx, R6xx ¹⁾	2.6	300	0		interventio	1, 610			0							
F1xx	2.6	300	0						0		-					
F2xx	1.8	200	0						0							
PCD7																
F1xx	8.8	1000	0						0							
R-SD xxx	1.0	110	0						0							
D4xx ^{1) 2) 5)}	0.4	41	1	2.4E-02					0							

¹⁾ Previsional estimation

²⁾ Backlight: 50% luminosity after 50'000h ⁵⁾ PCD7.D457VTSF: 115.1Years @35°C, 70.9Years @50°C, 21.6Years @65°C

³⁾ Subject to limited Life Time; for Relais typical 0.7 x 10⁶ cycles

⁴⁾ MTBF calculated: 38.1Years @35°C, 29.9Years @50°C, 21.6Years @65°C,

Field Failure Rate [FFR] is practically equivalent to the MTBF(Mean Time Between Failure),

in million of Hours and year at 24 hours a day, 7 days a week.

These FFR are gross. There are defined as the ration between the Cumulative producted Modules multiplied by Time and the number of modules returned to Murten for Repair, regardless whether the module is defective or not, if the user has made a mistake or not.

			Example for a Typical Configuration Availability: Real configuration to be filled by the User										Availability	
Type / Field Failure R			1/FFR	Summ	FFR Total -	J			1 / FFR	Summ	FFR Total -			
	[mio h]	[Years					/							
PCD3	(@ 24h/D]	•		3.2E-02	31.4 [years]	275 422 [h]	100.00%	•		3.3E-02	29.9 [years]	261 708 [h] 100.00%
C100, C110	8.8	1000	1	1.0E-03					0					
C200	3.5	400	0						0		_			
M3xxx, M5xxx ⁴⁾	0.9	97	0		Chose	in function of op	erating temperation	ature 35°C	0		Availibil	ity=FFR / (FFF	R + Rtime)	
M6xxx @35°C			_								A	• • • • • • • • • • • •		
M3xxx, M5xxx ⁴⁾	0.5	57	1	1.8E-02				50°C	1	1.8E-02	Availabili	ty is based on	o customor i	c cuppocod
M6xxx @50°C								65.0			to have s	and the modules		s supposed
M3xxx, M5xxx ⁴⁾	0.3	33	0					65 C	0		- so an e	stimated 'Repa	air time' of 4 l	nours to
M6xxx @65°C											localize a	and replaced th	ne defective r	nodule can
T66x ¹⁾	0.2	20	0						0		be applie	ed.		
T76x ¹⁾	1.8	200	0						0					
E11x, E16x, E61x	4.4	500	3	6.0E-03		Fa	uivalent I/O for		1	2.0E-03				
A200,220,250 ³⁾	3.5	400	1	2.5E-03		- 9		020.000	2	5.0E-03				
A300, A400, A46x	6.1	700	1	1.4E-03					1	1.4E-03				
W1xx	1.8	200	0						0					
W2, W3, W4, W6	3.5	400	0						3	7.5E-03				
W5	2.6	300	1	3.3E-03					0					
H1	3.5	400	0						0					
R5xx, R6xx ¹⁾	2.6	300	0						0					
F1xx	2.6	300	0						0					
F2xx	1.8	200	0						0					
PCD7														
F1xx	8.8	1000	0						0					
R-SD xxx	1.0	110	0						0		4			
D4xx ¹⁾²⁾⁵⁾	0.4	41	1	2.4E-02					0					

¹⁾ Previsional estimation

²⁾ Backlight: 50% luminosity after 50'000h ⁵⁾ PCD7.D457VTSF: 115.1Years @35°C, 70.9Years @50°C, 21.6Years @65°C

³⁾ Subject to limited Life Time; for Relais typical 0.7 x 10⁶ cycles

⁴⁾ MTBF calculated: 38.1Years @35°C, 29.9Years @50°C, 21.6Years @65°C,

Field Failure Rate [FFR] is practically equivalent to the MTBF(Mean Time Between Failure),



in million of Hours and year at 24 hours a day, 7 days a week. These FFR are gross. There are defined as the ration between the Cumulative producted Modules multiplied by Time and the number of modules returned to Murten for Repair, regardless whether the module is defective or not, if the user has made a mistake or not.

					Example for a Typical Configuration Availability:								Real configuration to be filled by the User Availability						
Type / Field Failure Rate [FFR]				1/FFR	Summ	FFR T	otal —)			1 / FFR	Summ	FFR Total						
		[mio h]	[Years						· · · · · · · ·				1	-					
PCD7.Dxxx, P	<u>PCS1</u>	(224h/D]	•		8.7E-0	3 115.1	[years] 1	008 276 [r	1 00.00%	1 T		8.7E-03	115.1 [year	s] 1 008 27	76 [h] <mark>100.00%</mark>			
													Availibi	l ity= FFR / (FF	R + Rtime)				
				-							_		Availabil	ity is based on					
				-							_		- the cor	ndition where the	ne customer	is supposed to			
													have spa	are modules					
				_									- so an e	estimated 'Rep	air time' of 4	hours to			
													applied.	and replaced t		module can be			
				_									_						
					1								1						
D23x		0.8	90	0							0								
D4xx ^{1) 2) 5)}	@35°C	1.0	115	1	8.7E-03						1	8.7E-03							
D4xx ¹⁾²⁾⁵⁾	@50°C	0.6	71	0							0								
D4xx ^{1) 2) 5)}	@65°C	0.4	41	0							0								
PCS1.Cxx ¹⁾		0.4	40	0							0								

¹⁾ Previsional estimation

²⁾ Backlight: 50% luminosity after 50'000h ⁵⁾ PCD7.D457VTSF: 2775. FIT, 360'326 h, 15014 T, 41.1 Jahre @65°C

³⁾ Subject to limited Life Time; for Relais typical 0.7 x 10⁶ cycles