



Architects and Engineering Specification

System Sensor L-Series Color Lens Attachments

The System Sensor L-Series colored lens attachments shall be Model _____ approved for fire protective service as listed in UL 1638. The lens attachments shall only be used with plain (no "FIRE" print) System Sensor L- Series strobe devices or in conjunction with a non-fire printed bezel. The lens shall mount to any wall- or ceiling-mount strobes and shall be rated from -35°F to 151°F.