



## Architects and Engineering Specification

### System Sensor L-Series Horn

The horn appliance shall be a System Sensor L-Series Model \_\_\_\_\_ listed to UL 464 and shall be approved for fire protective service. The horn shall have two audibility options and an option to switch between a temporal three pattern and a non-temporal (continuous) pattern. These options are set by a multiple position switch. The horn shall operate on a coded or non-coded power supply. Indoor L-Series products shall operate between 32 and 120 degrees Fahrenheit from a regulated DC or full-wave rectified unfiltered power supply.

The horn strobe shall mount to a standard  $4 \times 4 \times 1\frac{1}{2}$ -inch back box, 4-inch octagon back box, or double gang back box, and single-gang  $2 \times 4 \times 1\frac{7}{8}$ -inch back box. A universal mounting plate shall be used for mounting ceiling and standard wall products. A separate mounting plate shall be used for mounting compact wall products. The notification appliance circuit wiring shall terminate at the mounting plate.

The L-Series horn and the Sync•Circuit™ Module MDL3 accessory, if used, shall be powered from a non-coded notification appliance circuit output and shall operate on a nominal 12 or 24 volts. When used with the Sync•Circuit Module MDL3, 12-volt-rated notification appliance circuit outputs shall operate between 8.5 and 17.5 volts; 24-volt-rated notification appliance circuit outputs shall operate between 16.5 and 33 volts. If the notification appliances are not UL 9th edition listed with the corresponding panel or power supply being used, then refer to the compatibility listing of the panel to determine maximum devices on a circuit.

The horn shall be plug-in and shall have the ability to check wiring continuity via a shorting spring on the universal mounting plate. The shorting spring shall also provide tamper resistance via an open circuit if the device is removed. All notification appliances shall be backward compatible.