



Product

Intelligent Control Module

Architect and Engineering Specifications

Intelligent control module shall be a System Sensor model number M500S. Addressable control modules shall provide supervised monitoring of wiring to load devices that require an external power supply to operate, such as horns, strobes, or bells. It shall be capable of Class B (Style Y) and Class A (Style Z) supervision. Upon command from the control panel, the control module shall be able to disconnect the supervision and connect the external power supply across the load device. The disconnection of the supervision shall provide verification to the panel that the control relay state changed. The external power supply shall always be relay isolated from the communication loop. The control module shall transmit full analog measurement of the supervised wiring back to the panel and can be used to detect impedance changes or other special test functions.

The modules shall provide address-setting means on the module using rotary switches. Because of the possibility of installation error, systems that use binary jumpers or DIP switches to set the module address are not acceptable. The modules shall also store an internal identifying code that the control panel shall use to identify the type of detector. Systems that require a special programmer to set the module address (including temporary connection at the panel) are labor intensive and not acceptable. Each module occupies any one of at least 99 possible addresses on the signaling line circuit (SLC) loop. It responds to regular polls from the system and reports its type and status.

The module shall have an LED that is controlled by the panel to indicate module status. Coded signals, transmitted from the panel, can cause the LED to blink, latch on, or latch off. Refer to the control panel technical documentation for module LED status operation.

The module shall mount in a standard 4-inch square, 2-1/8" deep electrical box, surface mounted backbox listed, or compatible duct smoke detector housing. The notification appliance circuit (NAC) shall wire in a Class B (Style Y) or Class A (Style Z) fashion. Each control module shall support up to 1 amp of inductive or 2 amps of resistive audible/visual signals. Audio/visual power shall be provided by a separate supervised power loop from the main fire alarm control panel or from a supervised, UL listed remote power supply. The module shall use SEMS screws for easy wiring. Wiring terminals shall be easily accessible for troubleshooting while installed.

Meets Agency Standards

- ANSI/ UL 864- Control Units and Accessories for Fire Alarm Systems
- ULC S527- Control Units for Fire Alarm Systems
- FM- ANSI/NFPA 72- National Fire Alarm Code