



Architects and Engineering Specification

SpectrAlert Advance Mini Horn

The mini horn shall be System Sensor model number _____ and shall be listed UL 464 for fire protective signaling systems. Mini horn shall be capable of operating at nominal 12 or 24VDC (includes fire alarm panels with built in sync) and shall mount to a single gang back box. Mini horn shall operate between 32°F and 120°F. When used with the Sync•Circuit™ Module MDL3, 12-volt rated notification appliance circuit outputs shall operate between 8.5 and 17.5 volts; 24-volt rated notification appliance circuit outputs shall operate between 16.5 and 33 volts. If the notification appliances are not UL 9th edition listed with the corresponding panel or power supply being used, then refer to the compatibility listing of the panel to determine maximum devices on a circuit.

All notification appliances shall be backward compatible.