



## Architects and Engineering Specification L-Series Universal Dual Strobe Expansion Plate

### UPPER APPLIANCE (Configurable)

The upper position of the Universal Strobe Expansion plate is configurable with another L-Series appliance. See the applicable Engineering Spec for the specific appliance that shall be mounted to the expansion plate as the upper appliance.

### LOWER APPLIANCE, Strobe

The strobe shall be a System Sensor L-Series Model \_\_\_\_\_ listed to UL 1638 and shall be approved for fire protective service. The strobe shall be wired as a primary signaling notification appliance and comply with the Americans with Disabilities Act requirements for visible signaling appliances, flashing at 1 Hz over the strobe's entire operating voltage range. The strobe shall have field-selectable candela settings including 15, 30, 75, 95, 110, 135, 185 for wall mounted units. The strobe light shall consist of a xenon flash tube and associated lens/reflector system. Indoor L-Series products shall operate between 32 and 120 degrees Fahrenheit from a regulated DC or full-wave rectified unfiltered power supply.

For MNS or ECS applications, the lower appliance can be used for general notification and not be held to fire protection service requirements.

The strobe shall mount to a standard 4 × 4 × 1½ -inch back box, 4-inch octagon back box, double gang back box, and single-gang 2 × 4 × 1<sup>7</sup>/<sub>8</sub>-inch back box. A universal mounting plate shall be used for mounting ceiling and standard wall products. A separate mounting plate shall be used for mounting compact wall products. The notification appliance circuit wiring shall terminate at the mounting plate.

The L-Series strobe and the Sync•Circuit™ Module MDL3 accessory, if used, shall be powered from a non-coded notification appliance circuit output and shall operate on a nominal 12 or 24 volts. When used with the Sync•Circuit Module MDL3, 12-volt-rated notification appliance circuit outputs shall operate between 8.5 and 17.5 volts; 24-volt-rated notification appliance circuit outputs shall operate between 16.5 and 33 volts. If the notification appliances are not UL 9th edition listed with the corresponding panel or power supply being used, then refer to the compatibility listing of the panel to determine maximum devices on a circuit.

The strobe shall be plug-in and shall have the ability to check wiring continuity via a shorting spring on the universal mounting plate. The shorting spring shall also provide tamper resistance via an open circuit if the device is removed. All notification appliances shall be backward compatible.

### System Sensor L-Series Color Lens Attachments

The System Sensor L-Series colored lens attachments shall be Model \_\_\_\_\_ approved for fire protective service as listed in UL 1638. The lens attachments shall only be used with plain (no "FIRE" print) System Sensor L-Series strobe devices or in conjunction with a non-fire printed bezel. The lens shall mount to any wall-mount strobes and shall be rated from -35°F to 151°F.

**System Sensor**  
3825 Ohio Avenue  
St. Charles, Illinois 60174  
Telephone: 630-377-6580  
Fax: 630-377-6495  
[www.systemsensor.com](http://www.systemsensor.com)