

# Operating Instructions

## HP300ULX

POWER SUPPLY AND BATTERY CHARGER  
PERFORM INSTALLATION ACCORDING TO NFPA72

**INPUT:**

120 VAC AT 1.40A MAXIMUM

**OUTPUT:**

12/24 VDC SELECTABLE AT 2.50A MAXIMUM

**BATTERY CHARGING CURRENT:**

300mA MAXIMUM

**MAXIMUM BATTERY CAPACITY:**

FOR 12 VOLT SYSTEM 1 - 55AH AT 12 VOLT

FOR 24 VOLT SYSTEM 2 - 55AH AT 12 VOLT

**FOR SERVICE INFORMATION CONTACT:**

HONEYWELL POWER PRODUCTS  
12 CLINTONVILLE ROAD  
NORTHFORD, CT 06472  
USA

PHONE: 1-877-HPP-POWR  
FAX: 203-484-1079  
WEB: HONEYWELL.POWER.COM

THIS PRODUCT IS  
LISTED TO:  
UL1481, UL603, UL294

TO BE FRAMED AND MOUNTED ADJACENT TO THE PRODUCT