# **M500R Relay Control Module**

3825 Ohio Avenue, St. Charles, Illinois 60174 1-800-SENSOR2, FAX: 630-377-6495 www.systemsensor.com

### **Specifications**

Normal Operating Voltage: 15 to 32 VDC Maximum Current Draw: 6.5mA (LED on)

Average Operating Current: 300 µA, 1 communication every 5 seconds

EOL Resistance: Not used

Temperature Range: 32°F to 120°F (0°C to 49°C) Humidity: 10% to 93% Non-condensing

Dimensions:  $4^{1}/2^{\circ}$  H x  $4^{\circ}$  W x  $1^{1}/4^{\circ}$  D (Mounts to a  $4^{\circ}$  square by  $2^{1}/8^{\circ}$  deep box.)

Accessories: SMB500 Electrical Box; CB500 Barrier

## **Before Installing**

This information is included as a quick reference installation guide. Refer to the control panel installation manual for detailed system information. If the modules will be installed in an existing operational system, inform the operator and local authority that the system will be temporarily out of service. Disconnect power to the control panel before installing the modules.

**NOTICE:** This manual should be left with the owner/user of this equipment.

# **General Description**

The M500R Relay Control Module is intended for use in intelligent, two-wire systems, where the individual address of each module is selected using the built-in rotary decade switches. It allows a compatible control panel to switch discrete contacts by code command. The relay contains two isolated sets of Form-C contacts, which operate as a DPDT switch and are rated in accordance with the table in the manual. Circuit connections to the relay contacts are not supervised by the module. The module also has a panel controlled LED indicator. This module can be used to replace an M500C module that has been configured for Form-C operation.

## **Compatibility Requirements**

To ensure proper operation, these modules shall be connected to listed compatible system control panels only.

#### Mounting

The M500R mounts directly to 4" square electrical boxes (see Figure 2A). The box must have a minimum depth of  $2^1/s$ ". Surface mounted electrical boxes (SMB500) are available from System Sensor.


## Wiring

**NOTE:** All wiring must conform to applicable local codes, ordinances, and regulations. When using control modules in nonpower limited applications, the System Sensor CB500 Module Barrier must be used to meet UL requirements for the separation of power-limited and nonpower-limited terminals and wiring. The barrier must be inserted into a 4"x4"x2\(^1/8\)" junction box, and the control module must be placed into the barrier and attached to the junction box

(Figure 2A). The power-limited wiring must be placed into the isolated quadrant of the module barrier (Figure 2B).


- 1. Install module wiring in accordance with the job draw ings and appropriate wiring diagrams.
- 2. Set the address on the module per job drawings.
- 3. Secure module to electrical box (supplied by installer), as shown in Figure 2A.

Figure 1. Controls and indicators:



C0925-01

Figure 2A. Module mounting with barrier:



SS-460-002 1 I56-3852-000


## **Relay Contact Ratings:**

CURRENT RATING	MAXIMUM VOLTAGE	LOAD DESCRIPTION	APPLICATION
3 A	30 VDC	Resistive	Non-coded
2 A	30 VDC	Resistive	Coded
.9 A	110 VDC	Resistive	Non-coded
.9 A	125 VDC	Resistive	Non-coded
.5 A	30 VDC	Inductive $(L/R = 5ms)$	Coded
1 A	30 VDC	Inductive $(L/R = 2ms)$	Coded
.3 A	125 VAC	Inductive (PF = .35)	Non-coded
1.5 A	25 VAC	Inductive (PF = .35)	Non-coded
.7 A	70.7 VAC	Inductive (PF = .35)	Non-coded
2 A	25 VAC	Inductive (PF = .35)	Non-coded

# **▲**WARNING

All relay switch contacts are shipped in the standby (open) state, but may have transferred to the activated (closed) state during shipping. To ensure that the switch contacts are in their correct state, modules must be made to communicate with the panel before connecting circuits controlled by the module.

Figure 3. Relay module wiring diagram:



\*NOTE: ANY FAULT IN THE POWER SUPPLY IS LIMITED TO THAT ZONE AND DOES NOT RESULT IN A FAULT IN A SEPARATE ZONE.

## **Three-Year Limited Warranty**

System Sensor warrants its enclosed product to be free from defects in materials and workmanship under normal use and service for a period of three years from date of manufacture. System Sensor makes no other express warranty for the enclosed product. No agent, representative, dealer, or employee of the Company has the authority to increase or alter the obligations or limitations of this Warranty. The Company's obligation of this Warranty shall be limited to the replacement of any part of the product which is found to be defective in materials or workmanship under normal use and service during the three year period commencing with the date of manufacture. After phoning System Sensor's toll free number 800-SENSOR2 (736-7672) for a Return Authorization number, send defective units postage prepaid to: System Sensor, Returns

Department, RA #\_\_\_\_\_\_, 3825 Ohio Avenue, St. Charles, IL 60174. Please include a note describing the malfunction and suspected cause of failure. The Company shall not be obligated to replace units which are found to be defective because of damage, unreasonable use, modifications, or alterations occurring after the date of manufacture. In no case shall the Company be liable for any consequential or incidental damages for breach of this or any other Warranty, expressed or implied whatsoever, even if the loss or damage is caused by the Company's negligence or fault. Some states do not allow the exclusion or limitation of exclusion may not apply to you. This Warranty gives you specific legal rights, and you may also have other rights which vary from state to state.