
Installation


Gasket Set - for S3 devices

(S3-GASKET-IP55)

The Gasket Set (S3-GASKET-IP55) is supplied in pack of 10. There are two gaskets used from the 'Gasket set', which are fitted to a Deep Backbox moulding of an S3 device to provide IP55 protection.



1. Peel off the outer 'Rim gasket' from the backing of a 'Gasket set', as shown.




Deep Backbox - front view

2. Position the sticky side of the 'Rim gasket' into the Deep Backbox as shown and then press it down to ensure it adheres to the moulding.



Gasket set

3. Peel off the 'Round gasket' from the backing of a 'Gasket set' and remove the central cutout.



Backbox - rear view

4. Centrally position the sticky side of the 'Round gasket' onto the rear side of a Deep Backbox as shown. Press the gasket down to ensure it adheres to the moulding.



Backbox - with gasket fitted

5. The Deep Backbox with the gasket fitted can now be used to install an S-Cubed (S3) device in an area requiring IP55 protection.

At the end of their useful life, the packaging, product and batteries should be disposed of via a suitable recycling centre and in accordance with national or local legislation.

WEEE Directive:
At the end of their useful life, the packaging, product and batteries should be disposed of via a suitable recycling centre.
Do not dispose of with your normal household waste.
Do not burn.

Gent by Honeywell reserves the right to revise this publication from time to time and make changes to the content hereof without obligation to notify any person of such revisions of changes.

Honeywell

Hamilton Industrial Park, Waterside Road, Leicester LE5 1TN, UK.

Website: www.gent.co.uk
www.smsfire.co.uk

Telephone: Gent +44 (0) 116 246 2000
SMS +44 (0) 116 246 2100

Tech. Support www.gentexpert.co.uk
www.smstoolbox.co.uk

Fax (UK) Gent +44 (0) 116 246 2300
SMS+44 (0) 116 246 2016

4188-1095 issue 1_1/16