NOTIFIER® by Honeywell

12 Clintonville Road
Northford, CT 06472-1653
Phone: 203.484.7161

FZM-1 Interface Module

SPECIFICATIONS

Normal Operating Voltage:	15 to 32 VDC
Maximum Current Draw:	5.1 mA (LED on)
Average Operating Current:	270 µA (LED flashing)
EOL Resistance:	3.9K Ohms
Maximum IDC Wiring Resistance:	25 Ohms
IDC Supply Voltage (between Terminals T10 and T11)	
Regulated DC Voltage:	24 VDC power limited
Ripple Voltage:	0.1 Volts RMS maximum
Alarm Current:	90 mA per module
Standby Current:	13 mA Maximum @24 VDC
Temperature Range:	32˚F to 120˚F (0˚C to 49˚C)
Humidity:	10% to 93% Non-condensing
Dimensions:	4.5″ H × 4″ W × 1.25″ D (Mounts to a 4″ square by 2.125″ deep box.)
Accessories:	SMB500 Electrical Box

BEFORE INSTALLING

This information is included as a quick reference installation guide. Refer to the control panel installation manual for detailed system information. If the modules will be installed in an existing operational system, inform the operator and local authority that the system will be temporarily out of service. Disconnect power to the control panel before installing the modules.

NOTICE: This manual should be left with the owner/user of this equipment.

GENERAL DESCRIPTION

The FZM-1 Interface Module is intended for use in intelligent, two-wire systems, where the individual address of each module is selected using the built-in rotary switches. This module allows intelligent panels to interface and monitor two-wire conventional smoke detectors. It transmits the status (normal, open, or alarm) of one full zone of conventional detectors back to the control panel. All two-wire detectors being monitored must be UL compatible with this module. The FZM-1 has a panel controlled LED indicator and can be used to replace an MMX-2 module in existing systems. FZM-1 is capable of handling more than one detector in alarm condition.


COMPATIBILITY REQUIREMENTS

To ensure proper operation, this module shall be connected to a compatible Notifier system control panel only (list available from Notifier). In addition, please refer to Notifier Device Compatibility document number 15378 for the compatible list of detectors.

MOUNTING

The FZM-1 mounts directly to 4-inch square electrical boxes (see Figure 2). The box must have a minimum depth of 2.125 inches. Surface mounted electrical boxes (SMB500) are available from Notifier.

FIGURE 1. CONTROLS AND INDICATORS




C1059-00

WIRING

NOTE: All wiring must conform to applicable local codes, ordinances, and regulations. This module is intended for power-limited wiring only.


1. Install module wiring in accordance with the job drawings and appropriate wiring diagrams.
2. Set the address on the module per job drawings.
3. Secure module to electrical box (supplied by installer), as shown in Figure 2.

FIGURE 2. MODULE MOUNTING




C1066-00

FIGURE 3. INTERFACE TWO-WIRE CONVENTIONAL DETECTORS, NFPA CLASS B




C1061-00

FIGURE 4. INTERFACE TWO-WIRE CONVENTIONAL DETECTORS, NFPA CLASS A



C1062-00

FIGURE 5. RELAY CONTROL MODULE USED TO DISCONNECT A POWER SUPPLY



C0945-00

NOTIFIER® is a registered trademark of Honeywell International, Inc.

©2022 Fire-Lite. 3/11/2022