

Unitary Controller

INSTALLATION AND OPERATIONS GUIDE

General	2	Unitary Controllers Configuration	36
Trademark Information	2	Compass Device Configuration	36
Product Description	2	Recovering from a Misconfiguration	36
Controller Part Numbers	3	Initial Screen	36
Dimension	3	Ethernet and IP	37
Network Security	5	BACnet Configuration	38
General Safety Information and Installation Precaution	5	BACnet Point Objects	40
Read all the instructions below	5	BACnet Network Configuration	41
High Voltage safety test	5	BACnet Compatibility	45
Lightning and high-voltage danger	5	Time Synchronization Configuration	46
Wiring and equipment separations	5	UTC Offset, Daylight saving, Latitude, Longitude	47
Specifications	6	Modbus	48
Hardware	6	Syslog	54
Electrical	6	BLE Settings	56
Supported Devices	6	Configuring all Inputs and Outputs (Templates)	59
Operational Environment	7	Inputs	63
SPDT Relays	7	Outputs	70
Solid State Relay	7	Network topologies	74
Wire Gauge	7	Daisy Chain topology	74
Universal IO	8	Ring network topology	75
Communication	8	RSTP	76
IP T1L Communication	8	Introduction	76
IP T1L Cable Specifications	9	RSTP Scenario	77
Hardware Overview	10	Port Roles	78
Unitary Controllers Model	10	RSTP Configuration	79
System Overview	11	RSTP Diagnostics	80
Service Button	12	Troubleshooting RSTP	81
Mounting	12	Tested Network Switches	81
DIN Rail Mounting	12	Objects and Property References	82
Wall Mounting	13	Objects in the VLC8u8 Unitary Controllers	82
Power Supply	14	Objects in the VLC16u8 Unitary Controllers	84
General Information	14	Properties of VLC AI Objects	86
Power Wiring	14	Properties of VLC AO Objects	86
Power Wiring Examples	15	Properties of VLC AV Objects	88
Selecting a power supply wire	17	Properties of Microset VLC AV Objects	89
Input / Output Wiring	18	Properties of VLC BI Objects	90
Wiring Requirements	18	Properties of VLC BO Objects	91
Internal Wiring Examples	19	Properties of VLC BV Objects	92
Internal Wiring Small Controller	20	Properties of Microset VLC BV Objects	93
Identifying terminals and terminal wire	21	Properties of the VLC Device Objects	93
Terminal Connections	23	Properties of VLC Event - Enrollment Objects	95
UIO Wiring Examples	26	Properties of VLC File Objects	95
SSR (DO) Wiring Examples	27	Properties of VLC Notification-Class Objects	96
Auxiliary Wiring Examples	28	Properties of VLC Program Objects	97
SPDT Relay Wiring Examples	28	Properties of VLC Scheduled Objects	97
Microset Bus	29	Properties of VLC Trendlog Objects	98
Microtouch	29	Properties of VLC Zone Objects	99
Microset II	29	Diagnostic AVs and BVs	102
Microset 4	29	Regulatory Information	107
Wire shields and shield grounding	30	FCC Regulation	107
Microset II/ Microset 4 / Microtouch Wiring Examples	30	Canadian Regulatory Statement	107
LED Operations	34	CE Statement	107
Controller Status LED	34	Wireless Connectivity	107
Modbus LED Status	35	Standards and Compliance	108
IP T1L LED Status	35	Approvals and Certifications	108
Service Pin LED Status	35	WEEE Directive 2012/19/EC Waste Electrical and Electronic Equipment directive	108
		Abbreviations	110
		Related Technical Literature	110

GENERAL

Trademark Information

BACnet® is a registered trademark of ASHRAE Inc.

All information in this document is provided without warranty of any kind. Honeywell reserves the right to change any information herein without prior notice. No guarantees are given as to the accuracy of information. Trademarks and trade names may be used in the document to refer to the entities claiming their products' marks and names. Alerton, BACtalk, and their logos are registered as trademarks of Honeywell. Honeywell disclaims any proprietary interest in trademarks and trade names other than its own.

Product Description

Alerton VisualLogic® Unitary controllers provide flexible, freely programmable, demand-led control that delivers tangible benefits to reduce energy spending while driving new levels of functionality and efficiency in today's buildings.

These new controllers offer BACnet® IP through IP CAT5/6 or IP T1L network connectivity along with Microset Bus and Modbus RTU as embedded integration protocols, flexible Universal Input/Output (UIOs), Power Relays (SPDT), and solid-state relays (SSRs).

They offer performance-based engineering via Alerton's VisualLogic® programming tool. The optional integrated Bluetooth® Low Energy (BLE) capability enables an easy pairing with the Connect Mobile app for efficient wiring validation.

Table 1 Part Numbers

Part Number	Housing	Universal IO	Solid State Relay (SSR)	SPDT Relay	Communication	MSET Bus	Bluetooth
VLC8u8-IP	Small	8	4	4	BACnet® IP (CAT5/6)	Yes	No
VLC8u8-IP-BLE	Small	8	4	4	BACnet® IP (CAT5/6)	Yes	Yes
VLC8u8-T1L	Small	8	4	4	BACnet® IP (T1L)	Yes	No
VLC8u8-T1L-BLE	Small	8	4	4	BACnet® IP (T1L)	Yes	Yes
VLC16u8-IP	Large	16	4	4	BACnet® IP (CAT5/6)	Yes	No
VLC16u8-IP-BLE	Large	16	4	4	BACnet® IP (CAT5/6)	Yes	Yes
VLC16u8-T1L	Large	16	4	4	BACnet® IP (T1L)	Yes	No
VLC16u8-T1L-BLE	Large	16	4	4	BACnet® IP (T1L)	Yes	Yes



NOTE:

CAT5 cables are used primarily because they offer a connection speed of 100 Mbps while CAT6 cables support up to 10 Gbps. The network infrastructure is designed for 100 Mbps, therefore CAT6's higher capacity would not be fully utilized in the current setup.

Table 2 Accessories / Replacement Part

Part Number	Description
CW-COV-L-UNITARY	Terminal cover for the Large Unitary Controllers (sold in pack of 10)
CW-COV-S-UNITARY	Terminal cover for the Small Unitary Controllers (sold in pack of 10)
SCRW-TB-UNI-L	Set of removable terminal blocks covering all models of Unitary Controllers
IO-JUMPER-4-10	4-pin relay output Jumper Bar to connect 4 relays IN terminals (sold in pack of 10)
10BASE-T1L-ADAPT-0	BACnet® IP (T1L) single pair media adapter that allows converting 10BASE-T traffic to 10BASE-T1L without including power supply.

Controller Part Numbers




Fig. 1 Controller Part Numbers

Dimension




Fig. 2 Alerton Unitary Controller (Large Housing) Dimensions




Fig. 3 Alerton Unitary Controller (Small Housing) Dimensions

All dimensions are in inches (mm).

Table 3 Dimension

Parameter	Specifications
Dimension (L x W x H)	Large - 8.5 x 4.8 x 2.4 inches (216.0 x 121.6 x 60.9 mm)
	Small - 7.1 x 4.8 x 2.4 inches (180.0 x 121.6 x 60.9 mm)
Weight	Large - 1.278 lbs. (580 g)
	Small - 1.102 lbs. (500 g)
Mounting	Mounting in fuse boxes (DIN43880), on DIN rails or surface mounted with optional protection covers.

NETWORK SECURITY

WARNING

Alerton hereby states that the Unitary Controllers are not inherently protected against all cyber security risks from the Internet and are thus intended solely for use in private or protected networks.

Unprotected Internet connections can expose the Alerton Unitary Controllers to cyber security risks.

To ensure a safe and reliable operation, take necessary protective measures, such as locating BMS controls behind a firewall and using a VPN connection for remote maintenance. Numerous third-party manufacturers offer suitable VPN routers. For more details, refer Alerton Unitary Controller - Security Guide 31-00529.

General Safety Information and Installation Precaution

Follow the safety instructions provided by Alerton in this manual while doing any operation such as installation, mounting, or starting.

- The controllers must be installed and mounted by authorized and trained personnel.
- Except for Alerton, the operation and safety warranties become void in case of any modification.
- Observe all applicable local standards and regulations.
- Use only Alerton supplied or approved accessories.
- Before installing or dismantling the system, disconnect the power supply by removing the power terminal block from the controller or through local isolation.

CAUTION

You must disconnect the power before installing, removing, or replacing the Alerton Unitary Controller. Switch off the power before you install any jumpers.

Read all the instructions below

Follow all instructions to avoid equipment damage or hazardous condition. Read all instructions carefully before installing equipment.

High Voltage safety test

Experienced electricians, at first contact, always assume that hazardous voltages may exist in any wiring system. A safety check using a known, reliable voltage measurement or detection device should be made immediately before starting work and when work resumes.

Lightning and high-voltage danger

Most electrical injuries involving low-voltage wiring result from sudden, unexpected high voltages on normally low-voltage wiring. Low voltage wiring can carry hazardous high voltages under unsafe conditions. Never install or connect wiring or equipment during electrical storms. Improperly protected wiring can carry a fatal lightning surge for many miles. All outdoor wiring must be equipped with properly grounded and listed signal circuit protectors, which must be installed in compliance with local, applicable codes. Never install wiring or equipment while standing in water.

Wiring and equipment separations

All wiring and controllers must be installed to minimize the possibility of accidental contact with other potentially hazardous and disruptive power and lighting wiring. Never place 24 VAC or communications wiring near other bare power wires, lightning rods, antennas, transformers, or steam or hot water pipes. Never place the wire in any conduit, box, channel, duct, or other enclosure containing power or lighting circuits of any type. Always provide adequate separation of communications and another electrical wiring according to code. Keep wiring and controllers at least six feet from large inductive loads (power distribution panels, lighting ballasts, motors, etc.)

SPECIFICATIONS

Hardware

Table 4 Hardware Specification

Parameter	Specification
CPU	Crossover processor NXP I.MRT, Cortex M7
Memory Capacity	64 MB QSPI Flash, 16 MB SDRAM
IP CAT5/6 ¹⁾	2 x RJ-45 ports, 10/100 Mbps with a protection that allows loop topology to continue the communication with other controllers even if one node fails, when used with an RSTP supporting device.
IP T1L ²⁾	2 x T1L ports with fail-safe, up to 10 Mbps with a protection that allows loop (when used with an RSTP supporting device) and daisy-chain topology to continue the communication with other controllers even if one node fails.
Real Time Clock	24 hours backup after power failure. After 24 hours, the time will reset to factory default time until the user performs time sync via BACnet® or Network Time Protocol (NTP)
Small LED	Transmission or reception of IP T1L/Modbus/Bluetooth signal (green) and service pin status.
Large LED	Controller status (green, yellow, and red).
NOTE: ¹⁾ applicable for IP CAT5/6 variant only. ²⁾ applicable for IP T1L variant only.	

Electrical

Table 5 Electrical Specifications

Parameter	Specification
Rated Input Voltage	20 - 30 VAC / 24 - 30 VDC
Nominal Power Consumption	<ul style="list-style-type: none"> BACnet® IP CAT5/6 (VLC8u8-IP-BLE): 12 VA BACnet® IP CAT5/6 (VLC16u8-IP-BLE): 15 VA BACnet® IP T1L (VLC8u8-T1L-BLE): 10 VA BACnet® IP T1L (VLC16u8-T1L-BLE): 12 VA

Table 5 Electrical Specifications

Full Load Power Consumption (Communication, Bluetooth, Universal IO, and 24 VDC, excluding the load on the SSRs and Relays). NOTE: For the current consumption of SSR, refer SSR section table below.	<ul style="list-style-type: none"> BACnet® IP CAT5/6 (VLC8u8-IP-BLE): 40 VA BACnet® IP CAT5/6 (VLC16u8-IP-BLE): 62 VA BACnet® IP T1L (VLC8u8-T1L-BLE): 40 VA BACnet® IP T1L (VLC16u8-T1L-BLE): 58 VA
Frequency Range	50 - 60 Hz
Auxiliary Power Output for 24 VDC (3 for large and 1 for small controller)	3 x 24 VDC at 75 mA each 1 x 24 VDC at 75 mA
Auxiliary Power Output for 24 VAC/VDC (Pin 48,49)	1 x 24 VAC/VDC at 300 mA
Impulse Voltage	330 VAC
Type Of Loads	Resistive or inductive loads
Material Group	IIIb
Classes Of Control Function	Class A control
Type of Output Waveform	Sine wave or DC voltage

Supported Devices

Table 6 Supported devices

Parameter	Specification
Microset Wall Modules	Microset 4: MS4-TH, MS4-TH-NL, MS4-THC Microset II: MS-2000-BT, MS-2000-BT-NL, MS-2000H-BT
Microtouch Wall Modules	TS-1050-BT, TS-1050-BT-NL
Modbus Devices	Modbus RTU devices from any manufacturer including Honeywell Modbus devices, for example DALI64MODPSUF/S, TR100, TR50, and TC300 can be used.

Operational Environment

Table 7 Operational Environment

Parameter	Specification
Storage Temperature	-40 °F to 150 °F (-40 °C to 66 °C)
Operating Temperature	-40 °F to 122 °F (-40 °C to 50 °C)
Humidity	5 % to 95 % non-condensing
Protection	IP20, NEMA 1
Pollution Level	2

SPDT Relays

Table 8 SPDT Relays

Parameter	Specification	
Contact Rating	Up to 277 VAC / 230 VAC (+20 %)	
	3 contacts per relay (normally open (NO), normally closed (NC), common (IN)).	
	10 A constant current on normally open (NO) contact and 100 A inrush for 100 ms	
	Total current across all relays is limited to 10 A if all commons are connected via a relay jumper.	
	<table> <tr> <td>Motor Load Rating: 120 VAC, 1 HP (10 FLA), 240 VAC, 2 HP (10 FLA), 277 VAC, 3/4 HP (6.9 FLA).</td><td>General Purpose Rating: 120 VAC @10 A, 240/277 VAC @10 A.</td></tr> </table>	Motor Load Rating: 120 VAC, 1 HP (10 FLA), 240 VAC, 2 HP (10 FLA), 277 VAC, 3/4 HP (6.9 FLA).
Motor Load Rating: 120 VAC, 1 HP (10 FLA), 240 VAC, 2 HP (10 FLA), 277 VAC, 3/4 HP (6.9 FLA).	General Purpose Rating: 120 VAC @10 A, 240/277 VAC @10 A.	
Output	40000 cycles for contact A (NO) 6000 cycles for contact C (CO)	
Number of Automatic Cycles	40000 cycles for contact A (NO) 6000 cycles for contact C (CO)	
Type of disconnection or interruption provided by each circuit.		
Relay outputs can be used as dry contact output.		
Type 1.C, also known as Form C or SPDT (Single Pole Double Throw).		

Solid State Relay

Table 9 Solid State Relay Specification

Specification
SSR works with maximum 24 VAC / VDC.
1.5 A constant current across all 4 outputs; 3.5 A inrush for 0.1 seconds per SSR output.
Factory installed jumper (pin 7 to 14) between 24 VAC or 24 VDC supply and SSR input shared by all SSRs.
The fuse should be 5 A, for example, 0AGC005.V, OAGW005.VP or BK/AGW-5, and the fuse folder, for example, 150603 or BK/HRK-R.

Wire Gauge

Table 10 Wire Gauge

Parameter	Specification
Power Input	12 - 14 AWG
SSR Output and SRIN	22 - 18 AWG
Relay	18 - 14 AWG
IP T1L	18 - 23 AWG, Twisted Pair, Shielded Al-Foil and Cubraid tinned
Note: 1. For more details about wiring, refer Selecting a power supply wire on page 17 2. For more details about IP T1L Cable Specifications refer IP T1L Cable Specifications on page 9	

Universal IO

Table 11 Universal IO Specification

Parameter	Specification
AI	<ul style="list-style-type: none"> 16-bit universal inputs accept 10 k thermistor (type II and III), 3k thermistor, dry contact, 1k platinum RTD, 0-20 mA, 0-10 V, or dry-contact pulse. Pulse input maximum frequency of 100 Hz. Pulse input minimum duty cycle 5 ms ON / 5 ms OFF. Sensors: 10K Ohm NTC Type II, 10K Ohm NTC Type III, PT1000, 100 Ohm to 100K Ohm resistive (custom characteristic).
BI	<ul style="list-style-type: none"> Dry contact binary input. Pulse input with maximum frequency 100 Hz, minimum pulse width 5 ms.
AO	<ul style="list-style-type: none"> Voltage output with 0-10 VDC Current output with 0-20 mA. 16-bit analog output.
DO	0...11 VDC at 20 mA binary output with direct/reverse.
NOTE: Some 4-20 mA input sensors may need an external resistor to function properly. Please refer to the sensor's documentation.	

IP T1L Communication

Table 13 IP T1L Communication Specification

Parameter	Specification
10 BASE-T1L Standard	802.3cg-2019
Connection	Screw terminal, auto MDI-X
Cable Types	18 - 23 AWG, Twisted Pair, Shielded AI-Foil and Cubraid tinned
Distance	Maximum distance between controllers support upto 3281 ft. (1000 m) based on cables characteristics. For more details about cable type and characteristics refer to the IP T1L Network Specification Guide.
Transmission Rate	10 Mbps

Communication

Table 12 Communication Specification

Parameter	Specification
Protocol Supported	<ul style="list-style-type: none"> BACnet[®]/Ethernet, BACnet[®]/IPv4, BACnet[®]/IPv6 Modbus RTU (Master) Rapid Spanning Tree Protocol (RSTP) Network Time Protocol (NTPv4) Bluetooth (Optional)
IP Addressing Modes	<ul style="list-style-type: none"> Dynamic: Full duplex (IPv4 and IPv6) addressing, DHCP, SLAAC, Link-Local addressing. Static: Assigned

IP T1L Cable Specifications

Table 14 IP T1L Cable Specifications

Cable	Typical Uses	Cable Characteristics	Maximum distance (between working nodes)
74040NH – Belden ²⁾	IP T1L- Long distance harsh environments	2 cores solid 18 AWG, SF/UTP Shielded and foil, unshielded twisted pair.	1000 m
8471 – Belden ²⁾	LON	2 cores stranded/tinned 16 AWG, unshielded cable.	560 m
9841 – Belden ²⁾ IP TP/1/1/24/200/HF- 600V	MS/TP (Serial)	2 cores stranded/tinned 24 AWG, Foil shield & drain wire, twisted pair.	400 m
8723NH – Belden ²⁾ ³⁾ IP TP/2/2/22/200/HF- 600V	Trend 4 wire LAN	4 cores, 2 pairs, stranded/tinned, 22 AWG, Foil shield & drain wire, twisted pairs.	200 m
8761NH – Belden ²⁾ IP TP/1/1/22/200/HF- 600V	Trend 2 wire LAN	2 cores stranded/tinned, 22 AWG, Foil shield & drain wire, twisted pairs.	320 m
5501UE 0081000 – Belden/BAV	Security, speaker, PA, & telephone systems	3 cores stranded bare copper, 22 AWG, no shield or twist.	600 m
82836 – Helukabel ¹⁾	Profibus - Industrial Ethernet	2 cores solid, 18 AWG Foil + braided screen twisted pair.	800 m
3076F – Belden ¹⁾	Harsh environment digital and serial two-way communication	2 cores solid 18 AWG, Shielded and foil, unshielded twisted pairs.	428 m
Helukabel J-Y(ST)YLG ¹⁾	Telecommunications & Fire Alarm Cable (Fire Warning Cable)	Multicore solid bare copper, 20 AWG (0.8 mm), foil wrapped.	320 m
Cat5/Cat6	Standard wired IT network cable	8 core, 4 pairs, solid bare copper, 23 AWG, twisted pairs.	720 m
<p>Depending on the cable type and assuming the distance between functional nodes does not exceed the maximum stated above, the maximum number of offline IP T1L devices on the bus varies between 2 and 10 for daisy-chaining to remain functional.</p> <p>¹⁾ Testing source - Analog Devices standard IP T1L cable testing.</p> <p>²⁾ Testing source - Analog Devices & Honeywell device testing.</p> <p>³⁾ Do not combine pairs as this impacts performance.</p>			

HARDWARE OVERVIEW

Unitary Controllers Model




Fig. 4 Unitary Controllers (Large) Overview

System Overview




Fig. 5. Alerton Unitary Controllers System Overview

*Devices subject to local availability, Contact your local sales representative for information on available device on your region.

Service Button

Fig. 4 shows the hardware overview with the location of the service button. The service button is used to trigger dedicated events. It is important to distinguish different controller behaviors elicited depending on whether the service button is pressed when the controller is powering up or in normal operation.

See the following dedicated events:

To factory reset the controller, user must follow the below steps:

- Power-cycle the controller and simultaneously press the service button for 5 seconds until yellow status LED flashes twice.
- The device will erase each file stored in the controller. The time it takes to erase depends upon the amount of data stored in the controller, it can go from 15 to 90 seconds. During this period the status LED stays off.
 - The application is cleared from the controller.
 - The device instance will revert to its default 4194303
 - The device name will revert to default.
e.g: (1) For Unitary Controller IP CAT5/6 small variant with BLE, device name will revert to VLC8u8-IP-BLE.
(2) For Unitary Controller IP T1L large variant without BLE, device name will revert to VLC16u8-T1L.
 - The Ethernet, BACnet IPv4, and BACnet IPv6 settings will revert to their factory settings. The IP address will be reset to default 192.168.1.200 BACnet over Ethernet communication enabled.
- Status LED will flash yellow twice indicating that the factory reset has finished.
- Device will reboot.



NOTE:

Before performing a factory reset, user must remove the Device entry from The Compass Device Manager. If user fails to do, the device may reset, but it will change the default device instance from 4194303 to the actual instance in the Device Manager.



NOTE:

Pressing Service Button during normal operation will not result in any action. This feature is reserved for future use.

Mounting

Before Installation



IMPORTANT:

It is recommended that the unit be kept at room temperature for at least 24 hours before applying power. This is to allow the evaporation of any condensation resulting from low shipping / storage temperatures.



NOTE:

Avoid mounting in areas where acid fumes or other corrosive vapors can harm the metal parts of the controller or in areas where escaping gas or other explosive vapors are present.



IMPORTANT:

US requirement, only: This device must be installed in a UL-listed enclosure offering adequate space to maintain the segregation of the line voltage field wiring and Class 2 field wiring.




CAUTION


To avoid electrical shock or equipment damage, you must switch OFF the power supply before attaching or removing connections to or from any terminals.

DIN Rail Mounting


1. Mount the DIN rail on the wall/surface by using screws.



2. Extend all red mounting clips to the unlock position as shown in figure 7.



3. Remove the controller from the wall and drill four holes at the marked locations.



4. Insert anchors into the four mounting screw holes.
5. Place the controller on the wall/panel so that the holes are aligned. Insert the screws into the topside holes first and fasten them with a screwdriver.
6. Insert the screws into the bottom hole and fasten them with a screwdriver.




NOTE:


It is recommended to use the 6/18 1-inch pan head Phillips tapping screws.

Wall Mounting


1. Extend all red clips to the screw mounting position by inserting the flat blade screwdriver at a marked location and move up the nod from the lower slot to the upper slot as shown in figure 9.



2. Hold the controller along the wall and mark drilling locations through the screw red clip slots, as shown in figure 10.



3. Remove the controller from the wall and drill four holes at the marked locations.



4. Insert anchors into the four mounting screw holes.
5. Place the controller on the wall/panel so that the holes are aligned. Insert the screws into the topside holes first and fasten them with a screwdriver.
6. Insert the screws into the bottom hole and fasten them with a screwdriver.



NOTE:

It is recommended to use the 6/18 1-inch pan head Phillips tapping screws.

POWER SUPPLY

General Information

To prevent a risk of injury due to electrical shock and/or damage to the device due to short-circuiting, low voltage and high-voltage lines must be kept physically separate. To prevent a risk of short-circuiting and damage to your Unitary Controllers, do not reverse the polarity of the power connection cables and avoid ground loops (connecting one field device to several controllers).

Before wiring the controller, determine the input and output device requirements for each controller used in the system. Select input and output devices compatible with the controller and the application. Consider the operating range, wiring requirements, and environmental conditions while selecting input and output devices.

Determine the location of controllers, sensors, actuators, other input, and output devices, and create wiring diagrams for illustrations of typical controller wiring for various configurations.

The application engineer must review the control job requirements. This includes the sequence of operation for the controller and the system as a whole. Usually, some variables must be passed between the controllers that are required for optimum system-wide operation. Typical examples are the TOD, occupied, unoccupied, outdoor air temperature, and demand limit control signal. Understanding these interrelationships early in the job engineering process is vital for proper implementation while configuring the controllers.



NOTE:

All wiring must comply with applicable electrical codes and ordinances. Refer to the job or manufacturers' drawings for details. Local wiring guidelines (for example, IEC 364-6-61 or VDE 0100) may take precedence over recommendations provide in these installation instructions.

To comply with CE requirements, devices having a voltage of 50-1000 VAC or 75-1500 VDC, but lacking a supply cord, plug, or other means for disconnecting from the power supply must have the means of disconnect incorporated in the fixed wiring. This type of disconnect must have a contact separation of at least 1/8 in. (3 mm) at all poles.

Power Wiring

All wiring must comply with applicable electrical codes and ordinances as specified on installation wiring diagrams. Controller wiring is terminated to the screw terminal blocks located on the device.



NOTE:

A single transformer can power more than one controller. The same side of the transformer secondary must be connected to the same power input terminal on each controller. Fig. 6 shows the power wiring details for multiple controllers. Controller and configuration are not necessarily limited to three devices, but the total power draw, including accessories, cannot exceed 100 VA when powered by the same transformer (U.S. only).



NOTE:

Power must be off prior to connecting or removing connections from the 24 VAC power (24 V~ / 24 V) and 20 VDC power terminals.

Use the heaviest gauge wire available, up to 18 AWG (1 mm²), with a minimum of 22 AWG (0.3 mm²), for all power wiring.



CAUTION



To prevent a risk of short-circuiting and damage to your controller and external devices, do not reverse the polarity of the power supply connection cables.



IMPORTANT:

Power multiple controllers from a single transformer and connect the same transformer secondary side to each device's power input terminal. When connecting power, ensure that one leg of the 24 VAC/VDC secondary circuit and the grounded terminal on the device connect to a known earth ground at the panel or enclosure. Be cautious not to exceed the power consumption limit of the transformer. Limit the distance of the power wire running between the device and the transformer to 400 feet (122 meters) for 18 AWG wire. For installation purposes, the installer is responsible for appropriately selecting the AWG gauge to ensure safe and efficient operation. If there are any doubts, they can be resolved through our engineering technical support to avoid any misunderstandings. Restrict installations to the same room. The transformer must be UL Listed for smoke control and needs to be mounted and installed in an enclosure. Use a 15407287 series power supply.

Power Wiring Examples



⚠ WHEN CONNECTING POWER TO THE UNITARY CONTROLLERS, CONNECT THE COM OF THE VAC SECONDARY CIRCUIT TO A KNOWN EARTH GROUND.

Fig. 6 Power Wiring Example

Total Power of Controller's Transformer	Nominal Power Consumption	Total Power of Controller's Transformer	Maximum Power Consumption																																																																																																																				
<table><tr><td>Model</td><td>VLC8u8-IP-BLE</td></tr><tr><td>Number of Ethernet Ports in use</td><td>1</td></tr><tr><td>Number of T1L Ports in use</td><td>0</td></tr><tr><td>Number of UIOs configured as AOx</td><td>0</td></tr><tr><td>Microset Device</td><td>None</td></tr><tr><td>Current Drawn from 24VDC output 1 (Small)</td><td>0</td></tr><tr><td>Current Drawn from 24VDC output 2 (Large)</td><td>0</td></tr><tr><td>Current Drawn from 24VDC output 3 (Large)</td><td>0</td></tr><tr><td>Current Drawn from POW24 (Large)</td><td>0</td></tr><tr><td>Current Drawn from SSR 1 @24VAC</td><td>0</td></tr><tr><td>Current Drawn from SSR 2 @24VAC</td><td>0</td></tr><tr><td>Current Drawn from SSR 3 @24VAC</td><td>0</td></tr><tr><td>Current Drawn from SSR 4 @24VAC</td><td>0</td></tr><tr><td>How many relay outputs are being used?</td><td>0</td></tr><tr><td>External device</td><td>None</td></tr><tr><td>External power supply is being used for SSR outputs?</td><td>No</td></tr><tr><td>Base Power Consumption **</td><td>1.1</td></tr><tr><td>Ethernet Power Consumption</td><td>0.0</td></tr><tr><td>T1L Power Consumption</td><td>0.0</td></tr><tr><td>UIO Power Consumption</td><td>0.0</td></tr><tr><td>Microset Power Consumption</td><td>0.0</td></tr><tr><td>Total Power Consumption from Aux Outputs</td><td>0.0</td></tr><tr><td>SSR 1 Power Consumption</td><td>0.0</td></tr><tr><td>SSR 2 Power Consumption</td><td>0.0</td></tr><tr><td>SSR 3 Power Consumption</td><td>0.0</td></tr><tr><td>SSR 4 Power Consumption</td><td>0.0</td></tr><tr><td>SSR Total Power Consumption</td><td>0.0</td></tr><tr><td>Relay's Coil consumption</td><td>0.0</td></tr><tr><td>TOTAL POWER OF CONTROLLER'S TRANSFORMER</td><td>1.1</td></tr></table>	Model	VLC8u8-IP-BLE	Number of Ethernet Ports in use	1	Number of T1L Ports in use	0	Number of UIOs configured as AOx	0	Microset Device	None	Current Drawn from 24VDC output 1 (Small)	0	Current Drawn from 24VDC output 2 (Large)	0	Current Drawn from 24VDC output 3 (Large)	0	Current Drawn from POW24 (Large)	0	Current Drawn from SSR 1 @24VAC	0	Current Drawn from SSR 2 @24VAC	0	Current Drawn from SSR 3 @24VAC	0	Current Drawn from SSR 4 @24VAC	0	How many relay outputs are being used?	0	External device	None	External power supply is being used for SSR outputs?	No	Base Power Consumption **	1.1	Ethernet Power Consumption	0.0	T1L Power Consumption	0.0	UIO Power Consumption	0.0	Microset Power Consumption	0.0	Total Power Consumption from Aux Outputs	0.0	SSR 1 Power Consumption	0.0	SSR 2 Power Consumption	0.0	SSR 3 Power Consumption	0.0	SSR 4 Power Consumption	0.0	SSR Total Power Consumption	0.0	Relay's Coil consumption	0.0	TOTAL POWER OF CONTROLLER'S TRANSFORMER	1.1	<p>SKU: VLC8u8-IP-BLE</p> <p>Power: 12 VA</p> <p>Loads Exercised:</p> <p>Ethernet Ports x 1</p>	<table><tr><td>Model</td><td>VLC8u8-IP-BLE</td></tr><tr><td>Number of Ethernet Ports in use</td><td>2</td></tr><tr><td>Number of T1L Ports in use</td><td>0</td></tr><tr><td>Number of UIOs configured as AOx</td><td>0</td></tr><tr><td>Microset Device</td><td>Microset 4</td></tr><tr><td>Current Drawn from 24VDC output 1 (Small)</td><td>75</td></tr><tr><td>Current Drawn from 24VDC output 2 (Large)</td><td>0</td></tr><tr><td>Current Drawn from 24VDC output 3 (Large)</td><td>0</td></tr><tr><td>Current Drawn from POW24 (Large)</td><td>0</td></tr><tr><td>Current Drawn from SSR 1 @24VAC</td><td>0</td></tr><tr><td>Current Drawn from SSR 2 @24VAC</td><td>0</td></tr><tr><td>Current Drawn from SSR 3 @24VAC</td><td>0</td></tr><tr><td>Current Drawn from SSR 4 @24VAC</td><td>0</td></tr><tr><td>How many relay outputs are being used?</td><td>0</td></tr><tr><td>External device</td><td>None</td></tr><tr><td>External power supply is being used for SSR outputs?</td><td>No</td></tr><tr><td>Base Power Consumption **</td><td>1.1</td></tr><tr><td>Ethernet Power Consumption</td><td>2.2</td></tr><tr><td>T1L Power Consumption</td><td>0.0</td></tr><tr><td>UIO Power Consumption</td><td>0.0</td></tr><tr><td>Microset Power Consumption</td><td>0.0</td></tr><tr><td>Total Power Consumption from Aux Outputs</td><td>12.2</td></tr><tr><td>SSR 1 Power Consumption</td><td>0.0</td></tr><tr><td>SSR 2 Power Consumption</td><td>0.0</td></tr><tr><td>SSR 3 Power Consumption</td><td>0.0</td></tr><tr><td>SSR 4 Power Consumption</td><td>0.0</td></tr><tr><td>SSR Total Power Consumption</td><td>0.0</td></tr><tr><td>Relay's Coil consumption</td><td>0.0</td></tr><tr><td>TOTAL POWER OF CONTROLLER'S TRANSFORMER</td><td>40.0</td></tr></table>	Model	VLC8u8-IP-BLE	Number of Ethernet Ports in use	2	Number of T1L Ports in use	0	Number of UIOs configured as AOx	0	Microset Device	Microset 4	Current Drawn from 24VDC output 1 (Small)	75	Current Drawn from 24VDC output 2 (Large)	0	Current Drawn from 24VDC output 3 (Large)	0	Current Drawn from POW24 (Large)	0	Current Drawn from SSR 1 @24VAC	0	Current Drawn from SSR 2 @24VAC	0	Current Drawn from SSR 3 @24VAC	0	Current Drawn from SSR 4 @24VAC	0	How many relay outputs are being used?	0	External device	None	External power supply is being used for SSR outputs?	No	Base Power Consumption **	1.1	Ethernet Power Consumption	2.2	T1L Power Consumption	0.0	UIO Power Consumption	0.0	Microset Power Consumption	0.0	Total Power Consumption from Aux Outputs	12.2	SSR 1 Power Consumption	0.0	SSR 2 Power Consumption	0.0	SSR 3 Power Consumption	0.0	SSR 4 Power Consumption	0.0	SSR Total Power Consumption	0.0	Relay's Coil consumption	0.0	TOTAL POWER OF CONTROLLER'S TRANSFORMER	40.0	<p>SKU: VLC8u8-IP-BLE</p> <p>Power: 40 VA</p> <p>Loads Exercised:</p> <p>Ethernet Ports x 2</p> <p>Microset x 1</p> <p>UIOs x 8</p> <p>AUX OUT x 1</p> <p>POW 24</p> <p>Relays enabled</p>
Model	VLC8u8-IP-BLE																																																																																																																						
Number of Ethernet Ports in use	1																																																																																																																						
Number of T1L Ports in use	0																																																																																																																						
Number of UIOs configured as AOx	0																																																																																																																						
Microset Device	None																																																																																																																						
Current Drawn from 24VDC output 1 (Small)	0																																																																																																																						
Current Drawn from 24VDC output 2 (Large)	0																																																																																																																						
Current Drawn from 24VDC output 3 (Large)	0																																																																																																																						
Current Drawn from POW24 (Large)	0																																																																																																																						
Current Drawn from SSR 1 @24VAC	0																																																																																																																						
Current Drawn from SSR 2 @24VAC	0																																																																																																																						
Current Drawn from SSR 3 @24VAC	0																																																																																																																						
Current Drawn from SSR 4 @24VAC	0																																																																																																																						
How many relay outputs are being used?	0																																																																																																																						
External device	None																																																																																																																						
External power supply is being used for SSR outputs?	No																																																																																																																						
Base Power Consumption **	1.1																																																																																																																						
Ethernet Power Consumption	0.0																																																																																																																						
T1L Power Consumption	0.0																																																																																																																						
UIO Power Consumption	0.0																																																																																																																						
Microset Power Consumption	0.0																																																																																																																						
Total Power Consumption from Aux Outputs	0.0																																																																																																																						
SSR 1 Power Consumption	0.0																																																																																																																						
SSR 2 Power Consumption	0.0																																																																																																																						
SSR 3 Power Consumption	0.0																																																																																																																						
SSR 4 Power Consumption	0.0																																																																																																																						
SSR Total Power Consumption	0.0																																																																																																																						
Relay's Coil consumption	0.0																																																																																																																						
TOTAL POWER OF CONTROLLER'S TRANSFORMER	1.1																																																																																																																						
Model	VLC8u8-IP-BLE																																																																																																																						
Number of Ethernet Ports in use	2																																																																																																																						
Number of T1L Ports in use	0																																																																																																																						
Number of UIOs configured as AOx	0																																																																																																																						
Microset Device	Microset 4																																																																																																																						
Current Drawn from 24VDC output 1 (Small)	75																																																																																																																						
Current Drawn from 24VDC output 2 (Large)	0																																																																																																																						
Current Drawn from 24VDC output 3 (Large)	0																																																																																																																						
Current Drawn from POW24 (Large)	0																																																																																																																						
Current Drawn from SSR 1 @24VAC	0																																																																																																																						
Current Drawn from SSR 2 @24VAC	0																																																																																																																						
Current Drawn from SSR 3 @24VAC	0																																																																																																																						
Current Drawn from SSR 4 @24VAC	0																																																																																																																						
How many relay outputs are being used?	0																																																																																																																						
External device	None																																																																																																																						
External power supply is being used for SSR outputs?	No																																																																																																																						
Base Power Consumption **	1.1																																																																																																																						
Ethernet Power Consumption	2.2																																																																																																																						
T1L Power Consumption	0.0																																																																																																																						
UIO Power Consumption	0.0																																																																																																																						
Microset Power Consumption	0.0																																																																																																																						
Total Power Consumption from Aux Outputs	12.2																																																																																																																						
SSR 1 Power Consumption	0.0																																																																																																																						
SSR 2 Power Consumption	0.0																																																																																																																						
SSR 3 Power Consumption	0.0																																																																																																																						
SSR 4 Power Consumption	0.0																																																																																																																						
SSR Total Power Consumption	0.0																																																																																																																						
Relay's Coil consumption	0.0																																																																																																																						
TOTAL POWER OF CONTROLLER'S TRANSFORMER	40.0																																																																																																																						
<table><tr><td>Model</td><td>VLC16u8-IP-BLE</td></tr><tr><td>Number of Ethernet Ports in use</td><td>1</td></tr><tr><td>Number of T1L Ports in use</td><td>0</td></tr><tr><td>Number of UIOs configured as AOx</td><td>0</td></tr><tr><td>Microset Device</td><td>None</td></tr><tr><td>Current Drawn from 24VDC output 1 (Small)</td><td>0</td></tr><tr><td>Current Drawn from 24VDC output 2 (Large)</td><td>0</td></tr><tr><td>Current Drawn from 24VDC output 3 (Large)</td><td>0</td></tr><tr><td>Current Drawn from POW24 (Large)</td><td>0</td></tr><tr><td>Current Drawn from SSR 1 @24VAC</td><td>0</td></tr><tr><td>Current Drawn from SSR 2 @24VAC</td><td>0</td></tr><tr><td>Current Drawn from SSR 3 @24VAC</td><td>0</td></tr><tr><td>Current Drawn from SSR 4 @24VAC</td><td>0</td></tr><tr><td>How many relay outputs are being used?</td><td>0</td></tr><tr><td>External device</td><td>None</td></tr><tr><td>External power supply is being used for SSR outputs?</td><td>No</td></tr><tr><td>Base Power Consumption **</td><td>1.4</td></tr><tr><td>Ethernet Power Consumption</td><td>1.1</td></tr><tr><td>T1L Power Consumption</td><td>0.0</td></tr><tr><td>UIO Power Consumption</td><td>0.0</td></tr><tr><td>Microset Power Consumption</td><td>0.0</td></tr><tr><td>Total Power Consumption from Aux Outputs</td><td>0.0</td></tr><tr><td>SSR 1 Power Consumption</td><td>0.0</td></tr><tr><td>SSR 2 Power Consumption</td><td>0.0</td></tr><tr><td>SSR 3 Power Consumption</td><td>0.0</td></tr><tr><td>SSR 4 Power Consumption</td><td>0.0</td></tr><tr><td>SSR Total Power Consumption</td><td>0.0</td></tr><tr><td>Relay's Coil consumption</td><td>0.0</td></tr><tr><td>TOTAL POWER OF CONTROLLER'S TRANSFORMER</td><td>2.5</td></tr></table>	Model	VLC16u8-IP-BLE	Number of Ethernet Ports in use	1	Number of T1L Ports in use	0	Number of UIOs configured as AOx	0	Microset Device	None	Current Drawn from 24VDC output 1 (Small)	0	Current Drawn from 24VDC output 2 (Large)	0	Current Drawn from 24VDC output 3 (Large)	0	Current Drawn from POW24 (Large)	0	Current Drawn from SSR 1 @24VAC	0	Current Drawn from SSR 2 @24VAC	0	Current Drawn from SSR 3 @24VAC	0	Current Drawn from SSR 4 @24VAC	0	How many relay outputs are being used?	0	External device	None	External power supply is being used for SSR outputs?	No	Base Power Consumption **	1.4	Ethernet Power Consumption	1.1	T1L Power Consumption	0.0	UIO Power Consumption	0.0	Microset Power Consumption	0.0	Total Power Consumption from Aux Outputs	0.0	SSR 1 Power Consumption	0.0	SSR 2 Power Consumption	0.0	SSR 3 Power Consumption	0.0	SSR 4 Power Consumption	0.0	SSR Total Power Consumption	0.0	Relay's Coil consumption	0.0	TOTAL POWER OF CONTROLLER'S TRANSFORMER	2.5	<p>SKU: VLC16u8-IP-BLE</p> <p>Power: 15 VA</p> <p>Loads Exercised:</p> <p>Ethernet Ports x 1</p>	<table><tr><td>Model</td><td>VLC16u8-IP-BLE</td></tr><tr><td>Number of Ethernet Ports in use</td><td>2</td></tr><tr><td>Number of T1L Ports in use</td><td>0</td></tr><tr><td>Number of UIOs configured as AOx</td><td>16</td></tr><tr><td>Microset Device</td><td>Microset 4</td></tr><tr><td>Current Drawn from 24VDC output 1 (Small)</td><td>75</td></tr><tr><td>Current Drawn from 24VDC output 2 (Large)</td><td>75</td></tr><tr><td>Current Drawn from 24VDC output 3 (Large)</td><td>75</td></tr><tr><td>Current Drawn from POW24 (Large)</td><td>200</td></tr><tr><td>Current Drawn from SSR 1 @24VAC</td><td>0</td></tr><tr><td>Current Drawn from SSR 2 @24VAC</td><td>0</td></tr><tr><td>Current Drawn from SSR 3 @24VAC</td><td>0</td></tr><tr><td>Current Drawn from SSR 4 @24VAC</td><td>0</td></tr><tr><td>How many relay outputs are being used?</td><td>0</td></tr><tr><td>External device</td><td>None</td></tr><tr><td>External power supply is being used for SSR outputs?</td><td>No</td></tr><tr><td>Base Power Consumption **</td><td>1.4</td></tr><tr><td>Ethernet Power Consumption</td><td>2.2</td></tr><tr><td>T1L Power Consumption</td><td>0.0</td></tr><tr><td>UIO Power Consumption</td><td>17.6</td></tr><tr><td>Microset Power Consumption</td><td>0.0</td></tr><tr><td>Total Power Consumption from Aux Outputs</td><td>23.2</td></tr><tr><td>SSR 1 Power Consumption</td><td>0.0</td></tr><tr><td>SSR 2 Power Consumption</td><td>0.0</td></tr><tr><td>SSR 3 Power Consumption</td><td>0.0</td></tr><tr><td>SSR 4 Power Consumption</td><td>0.0</td></tr><tr><td>SSR Total Power Consumption</td><td>0.0</td></tr><tr><td>Relay's Coil consumption</td><td>2.8</td></tr><tr><td>TOTAL POWER OF CONTROLLER'S TRANSFORMER</td><td>62.0</td></tr></table>	Model	VLC16u8-IP-BLE	Number of Ethernet Ports in use	2	Number of T1L Ports in use	0	Number of UIOs configured as AOx	16	Microset Device	Microset 4	Current Drawn from 24VDC output 1 (Small)	75	Current Drawn from 24VDC output 2 (Large)	75	Current Drawn from 24VDC output 3 (Large)	75	Current Drawn from POW24 (Large)	200	Current Drawn from SSR 1 @24VAC	0	Current Drawn from SSR 2 @24VAC	0	Current Drawn from SSR 3 @24VAC	0	Current Drawn from SSR 4 @24VAC	0	How many relay outputs are being used?	0	External device	None	External power supply is being used for SSR outputs?	No	Base Power Consumption **	1.4	Ethernet Power Consumption	2.2	T1L Power Consumption	0.0	UIO Power Consumption	17.6	Microset Power Consumption	0.0	Total Power Consumption from Aux Outputs	23.2	SSR 1 Power Consumption	0.0	SSR 2 Power Consumption	0.0	SSR 3 Power Consumption	0.0	SSR 4 Power Consumption	0.0	SSR Total Power Consumption	0.0	Relay's Coil consumption	2.8	TOTAL POWER OF CONTROLLER'S TRANSFORMER	62.0	<p>SKU: VLC16u8-IP-BLE</p> <p>Power: 62 VA</p> <p>Loads Exercised:</p> <p>Ethernet Ports x 2</p> <p>Microset x 1</p> <p>UIOs x 16</p> <p>AUX OUT x 3</p> <p>POW 24</p> <p>Relays enabled</p>
Model	VLC16u8-IP-BLE																																																																																																																						
Number of Ethernet Ports in use	1																																																																																																																						
Number of T1L Ports in use	0																																																																																																																						
Number of UIOs configured as AOx	0																																																																																																																						
Microset Device	None																																																																																																																						
Current Drawn from 24VDC output 1 (Small)	0																																																																																																																						
Current Drawn from 24VDC output 2 (Large)	0																																																																																																																						
Current Drawn from 24VDC output 3 (Large)	0																																																																																																																						
Current Drawn from POW24 (Large)	0																																																																																																																						
Current Drawn from SSR 1 @24VAC	0																																																																																																																						
Current Drawn from SSR 2 @24VAC	0																																																																																																																						
Current Drawn from SSR 3 @24VAC	0																																																																																																																						
Current Drawn from SSR 4 @24VAC	0																																																																																																																						
How many relay outputs are being used?	0																																																																																																																						
External device	None																																																																																																																						
External power supply is being used for SSR outputs?	No																																																																																																																						
Base Power Consumption **	1.4																																																																																																																						
Ethernet Power Consumption	1.1																																																																																																																						
T1L Power Consumption	0.0																																																																																																																						
UIO Power Consumption	0.0																																																																																																																						
Microset Power Consumption	0.0																																																																																																																						
Total Power Consumption from Aux Outputs	0.0																																																																																																																						
SSR 1 Power Consumption	0.0																																																																																																																						
SSR 2 Power Consumption	0.0																																																																																																																						
SSR 3 Power Consumption	0.0																																																																																																																						
SSR 4 Power Consumption	0.0																																																																																																																						
SSR Total Power Consumption	0.0																																																																																																																						
Relay's Coil consumption	0.0																																																																																																																						
TOTAL POWER OF CONTROLLER'S TRANSFORMER	2.5																																																																																																																						
Model	VLC16u8-IP-BLE																																																																																																																						
Number of Ethernet Ports in use	2																																																																																																																						
Number of T1L Ports in use	0																																																																																																																						
Number of UIOs configured as AOx	16																																																																																																																						
Microset Device	Microset 4																																																																																																																						
Current Drawn from 24VDC output 1 (Small)	75																																																																																																																						
Current Drawn from 24VDC output 2 (Large)	75																																																																																																																						
Current Drawn from 24VDC output 3 (Large)	75																																																																																																																						
Current Drawn from POW24 (Large)	200																																																																																																																						
Current Drawn from SSR 1 @24VAC	0																																																																																																																						
Current Drawn from SSR 2 @24VAC	0																																																																																																																						
Current Drawn from SSR 3 @24VAC	0																																																																																																																						
Current Drawn from SSR 4 @24VAC	0																																																																																																																						
How many relay outputs are being used?	0																																																																																																																						
External device	None																																																																																																																						
External power supply is being used for SSR outputs?	No																																																																																																																						
Base Power Consumption **	1.4																																																																																																																						
Ethernet Power Consumption	2.2																																																																																																																						
T1L Power Consumption	0.0																																																																																																																						
UIO Power Consumption	17.6																																																																																																																						
Microset Power Consumption	0.0																																																																																																																						
Total Power Consumption from Aux Outputs	23.2																																																																																																																						
SSR 1 Power Consumption	0.0																																																																																																																						
SSR 2 Power Consumption	0.0																																																																																																																						
SSR 3 Power Consumption	0.0																																																																																																																						
SSR 4 Power Consumption	0.0																																																																																																																						
SSR Total Power Consumption	0.0																																																																																																																						
Relay's Coil consumption	2.8																																																																																																																						
TOTAL POWER OF CONTROLLER'S TRANSFORMER	62.0																																																																																																																						
<table><tr><td>Model</td><td>VLC8u8-T1L-BLE</td></tr><tr><td>Number of Ethernet Ports in use</td><td>1</td></tr><tr><td>Number of T1L Ports in use</td><td>0</td></tr><tr><td>Number of UIOs configured as AOx</td><td>0</td></tr><tr><td>Microset Device</td><td>None</td></tr><tr><td>Current Drawn from 24VDC output 1 (Small)</td><td>0</td></tr><tr><td>Current Drawn from 24VDC output 2 (Large)</td><td>0</td></tr><tr><td>Current Drawn from 24VDC output 3 (Large)</td><td>0</td></tr><tr><td>Current Drawn from POW24 (Large)</td><td>0</td></tr><tr><td>Current Drawn from SSR 1 @24VAC</td><td>0</td></tr><tr><td>Current Drawn from SSR 2 @24VAC</td><td>0</td></tr><tr><td>Current Drawn from SSR 3 @24VAC</td><td>0</td></tr><tr><td>Current Drawn from SSR 4 @24VAC</td><td>0</td></tr><tr><td>How many relay outputs are being used?</td><td>0</td></tr><tr><td>External device</td><td>None</td></tr><tr><td>External power supply is being used for SSR outputs?</td><td>No</td></tr><tr><td>Base Power Consumption **</td><td>2.0</td></tr><tr><td>Ethernet Power Consumption</td><td>0.0</td></tr><tr><td>T1L Power Consumption</td><td>0.0</td></tr><tr><td>UIO Power Consumption</td><td>0.0</td></tr><tr><td>Microset Power Consumption</td><td>0.0</td></tr><tr><td>Total Power Consumption from Aux Outputs</td><td>0.0</td></tr><tr><td>SSR 1 Power Consumption</td><td>0.0</td></tr><tr><td>SSR 2 Power Consumption</td><td>0.0</td></tr><tr><td>SSR 3 Power Consumption</td><td>0.0</td></tr><tr><td>SSR 4 Power Consumption</td><td>0.0</td></tr><tr><td>SSR Total Power Consumption</td><td>0.0</td></tr><tr><td>Relay's Coil consumption</td><td>0.0</td></tr><tr><td>TOTAL POWER OF CONTROLLER'S TRANSFORMER</td><td>2.0</td></tr></table>	Model	VLC8u8-T1L-BLE	Number of Ethernet Ports in use	1	Number of T1L Ports in use	0	Number of UIOs configured as AOx	0	Microset Device	None	Current Drawn from 24VDC output 1 (Small)	0	Current Drawn from 24VDC output 2 (Large)	0	Current Drawn from 24VDC output 3 (Large)	0	Current Drawn from POW24 (Large)	0	Current Drawn from SSR 1 @24VAC	0	Current Drawn from SSR 2 @24VAC	0	Current Drawn from SSR 3 @24VAC	0	Current Drawn from SSR 4 @24VAC	0	How many relay outputs are being used?	0	External device	None	External power supply is being used for SSR outputs?	No	Base Power Consumption **	2.0	Ethernet Power Consumption	0.0	T1L Power Consumption	0.0	UIO Power Consumption	0.0	Microset Power Consumption	0.0	Total Power Consumption from Aux Outputs	0.0	SSR 1 Power Consumption	0.0	SSR 2 Power Consumption	0.0	SSR 3 Power Consumption	0.0	SSR 4 Power Consumption	0.0	SSR Total Power Consumption	0.0	Relay's Coil consumption	0.0	TOTAL POWER OF CONTROLLER'S TRANSFORMER	2.0	<p>SKU: VLC8u8-T1L-BLE</p> <p>Power: 10 VA</p> <p>Loads Exercised:</p> <p>T1L Ports x 1</p>	<table><tr><td>Model</td><td>VLC8u8-T1L-BLE</td></tr><tr><td>Number of Ethernet Ports in use</td><td>2</td></tr><tr><td>Number of T1L Ports in use</td><td>0</td></tr><tr><td>Number of UIOs configured as AOx</td><td>8</td></tr><tr><td>Microset Device</td><td>Microset 4</td></tr><tr><td>Current Drawn from 24VDC output 1 (Small)</td><td>75</td></tr><tr><td>Current Drawn from 24VDC output 2 (Large)</td><td>75</td></tr><tr><td>Current Drawn from 24VDC output 3 (Large)</td><td>75</td></tr><tr><td>Current Drawn from POW24 (Large)</td><td>200</td></tr><tr><td>Current Drawn from SSR 1 @24VAC</td><td>0</td></tr><tr><td>Current Drawn from SSR 2 @24VAC</td><td>0</td></tr><tr><td>Current Drawn from SSR 3 @24VAC</td><td>0</td></tr><tr><td>Current Drawn from SSR 4 @24VAC</td><td>0</td></tr><tr><td>How many relay outputs are being used?</td><td>0</td></tr><tr><td>External device</td><td>None</td></tr><tr><td>External power supply is being used for SSR outputs?</td><td>No</td></tr><tr><td>Base Power Consumption **</td><td>2.0</td></tr><tr><td>Ethernet Power Consumption</td><td>0.0</td></tr><tr><td>T1L Power Consumption</td><td>0.0</td></tr><tr><td>UIO Power Consumption</td><td>8.8</td></tr><tr><td>Microset Power Consumption</td><td>0.0</td></tr><tr><td>Total Power Consumption from Aux Outputs</td><td>12.2</td></tr><tr><td>SSR 1 Power Consumption</td><td>0.0</td></tr><tr><td>SSR 2 Power Consumption</td><td>0.0</td></tr><tr><td>SSR 3 Power Consumption</td><td>0.0</td></tr><tr><td>SSR 4 Power Consumption</td><td>0.0</td></tr><tr><td>SSR Total Power Consumption</td><td>0.0</td></tr><tr><td>Relay's Coil consumption</td><td>2.8</td></tr><tr><td>TOTAL POWER OF CONTROLLER'S TRANSFORMER</td><td>40.0</td></tr></table>	Model	VLC8u8-T1L-BLE	Number of Ethernet Ports in use	2	Number of T1L Ports in use	0	Number of UIOs configured as AOx	8	Microset Device	Microset 4	Current Drawn from 24VDC output 1 (Small)	75	Current Drawn from 24VDC output 2 (Large)	75	Current Drawn from 24VDC output 3 (Large)	75	Current Drawn from POW24 (Large)	200	Current Drawn from SSR 1 @24VAC	0	Current Drawn from SSR 2 @24VAC	0	Current Drawn from SSR 3 @24VAC	0	Current Drawn from SSR 4 @24VAC	0	How many relay outputs are being used?	0	External device	None	External power supply is being used for SSR outputs?	No	Base Power Consumption **	2.0	Ethernet Power Consumption	0.0	T1L Power Consumption	0.0	UIO Power Consumption	8.8	Microset Power Consumption	0.0	Total Power Consumption from Aux Outputs	12.2	SSR 1 Power Consumption	0.0	SSR 2 Power Consumption	0.0	SSR 3 Power Consumption	0.0	SSR 4 Power Consumption	0.0	SSR Total Power Consumption	0.0	Relay's Coil consumption	2.8	TOTAL POWER OF CONTROLLER'S TRANSFORMER	40.0	<p>SKU: VLC8u8-T1L-BLE</p> <p>Power: 40 VA</p> <p>Loads Exercised:</p> <p>T1L Ports x 2</p> <p>Microset x 1</p> <p>UIOs x 8</p> <p>AUX OUT x 1</p> <p>POW 24</p> <p>Relays enabled</p>
Model	VLC8u8-T1L-BLE																																																																																																																						
Number of Ethernet Ports in use	1																																																																																																																						
Number of T1L Ports in use	0																																																																																																																						
Number of UIOs configured as AOx	0																																																																																																																						
Microset Device	None																																																																																																																						
Current Drawn from 24VDC output 1 (Small)	0																																																																																																																						
Current Drawn from 24VDC output 2 (Large)	0																																																																																																																						
Current Drawn from 24VDC output 3 (Large)	0																																																																																																																						
Current Drawn from POW24 (Large)	0																																																																																																																						
Current Drawn from SSR 1 @24VAC	0																																																																																																																						
Current Drawn from SSR 2 @24VAC	0																																																																																																																						
Current Drawn from SSR 3 @24VAC	0																																																																																																																						
Current Drawn from SSR 4 @24VAC	0																																																																																																																						
How many relay outputs are being used?	0																																																																																																																						
External device	None																																																																																																																						
External power supply is being used for SSR outputs?	No																																																																																																																						
Base Power Consumption **	2.0																																																																																																																						
Ethernet Power Consumption	0.0																																																																																																																						
T1L Power Consumption	0.0																																																																																																																						
UIO Power Consumption	0.0																																																																																																																						
Microset Power Consumption	0.0																																																																																																																						
Total Power Consumption from Aux Outputs	0.0																																																																																																																						
SSR 1 Power Consumption	0.0																																																																																																																						
SSR 2 Power Consumption	0.0																																																																																																																						
SSR 3 Power Consumption	0.0																																																																																																																						
SSR 4 Power Consumption	0.0																																																																																																																						
SSR Total Power Consumption	0.0																																																																																																																						
Relay's Coil consumption	0.0																																																																																																																						
TOTAL POWER OF CONTROLLER'S TRANSFORMER	2.0																																																																																																																						
Model	VLC8u8-T1L-BLE																																																																																																																						
Number of Ethernet Ports in use	2																																																																																																																						
Number of T1L Ports in use	0																																																																																																																						
Number of UIOs configured as AOx	8																																																																																																																						
Microset Device	Microset 4																																																																																																																						
Current Drawn from 24VDC output 1 (Small)	75																																																																																																																						
Current Drawn from 24VDC output 2 (Large)	75																																																																																																																						
Current Drawn from 24VDC output 3 (Large)	75																																																																																																																						
Current Drawn from POW24 (Large)	200																																																																																																																						
Current Drawn from SSR 1 @24VAC	0																																																																																																																						
Current Drawn from SSR 2 @24VAC	0																																																																																																																						
Current Drawn from SSR 3 @24VAC	0																																																																																																																						
Current Drawn from SSR 4 @24VAC	0																																																																																																																						
How many relay outputs are being used?	0																																																																																																																						
External device	None																																																																																																																						
External power supply is being used for SSR outputs?	No																																																																																																																						
Base Power Consumption **	2.0																																																																																																																						
Ethernet Power Consumption	0.0																																																																																																																						
T1L Power Consumption	0.0																																																																																																																						
UIO Power Consumption	8.8																																																																																																																						
Microset Power Consumption	0.0																																																																																																																						
Total Power Consumption from Aux Outputs	12.2																																																																																																																						
SSR 1 Power Consumption	0.0																																																																																																																						
SSR 2 Power Consumption	0.0																																																																																																																						
SSR 3 Power Consumption	0.0																																																																																																																						
SSR 4 Power Consumption	0.0																																																																																																																						
SSR Total Power Consumption	0.0																																																																																																																						
Relay's Coil consumption	2.8																																																																																																																						
TOTAL POWER OF CONTROLLER'S TRANSFORMER	40.0																																																																																																																						
<table><tr><td>Model</td><td>VLC16u8-T1L-BLE</td></tr><tr><td>Number of Ethernet Ports in use</td><td>1</td></tr><tr><td>Number of T1L Ports in use</td><td>0</td></tr><tr><td>Number of UIOs configured as AOx</td><td>0</td></tr><tr><td>Microset Device</td><td>None</td></tr><tr><td>Current Drawn from 24VDC output 1 (Small)</td><td>0</td></tr><tr><td>Current Drawn from 24VDC output 2 (Large)</td><td>0</td></tr><tr><td>Current Drawn from 24VDC output 3 (Large)</td><td>0</td></tr><tr><td>Current Drawn from POW24 (Large)</td><td>0</td></tr><tr><td>Current Drawn from SSR 1 @24VAC</td><td>0</td></tr><tr><td>Current Drawn from SSR 2 @24VAC</td><td>0</td></tr><tr><td>Current Drawn from SSR 3 @24VAC</td><td>0</td></tr><tr><td>Current Drawn from SSR 4 @24VAC</td><td>0</td></tr><tr><td>How many relay outputs are being used?</td><td>0</td></tr><tr><td>External device</td><td>None</td></tr><tr><td>External power supply is being used for SSR outputs?</td><td>No</td></tr><tr><td>Base Power Consumption **</td><td>2.2</td></tr><tr><td>Ethernet Power Consumption</td><td>0.0</td></tr><tr><td>T1L Power Consumption</td><td>0.0</td></tr><tr><td>UIO Power Consumption</td><td>0.0</td></tr><tr><td>Microset Power Consumption</td><td>0.0</td></tr><tr><td>Total Power Consumption from Aux Outputs</td><td>0.0</td></tr><tr><td>SSR 1 Power Consumption</td><td>0.0</td></tr><tr><td>SSR 2 Power Consumption</td><td>0.0</td></tr><tr><td>SSR 3 Power Consumption</td><td>0.0</td></tr><tr><td>SSR 4 Power Consumption</td><td>0.0</td></tr><tr><td>SSR Total Power Consumption</td><td>0.0</td></tr><tr><td>Relay's Coil consumption</td><td>0.0</td></tr><tr><td>TOTAL POWER OF CONTROLLER'S TRANSFORMER</td><td>2.2</td></tr></table>	Model	VLC16u8-T1L-BLE	Number of Ethernet Ports in use	1	Number of T1L Ports in use	0	Number of UIOs configured as AOx	0	Microset Device	None	Current Drawn from 24VDC output 1 (Small)	0	Current Drawn from 24VDC output 2 (Large)	0	Current Drawn from 24VDC output 3 (Large)	0	Current Drawn from POW24 (Large)	0	Current Drawn from SSR 1 @24VAC	0	Current Drawn from SSR 2 @24VAC	0	Current Drawn from SSR 3 @24VAC	0	Current Drawn from SSR 4 @24VAC	0	How many relay outputs are being used?	0	External device	None	External power supply is being used for SSR outputs?	No	Base Power Consumption **	2.2	Ethernet Power Consumption	0.0	T1L Power Consumption	0.0	UIO Power Consumption	0.0	Microset Power Consumption	0.0	Total Power Consumption from Aux Outputs	0.0	SSR 1 Power Consumption	0.0	SSR 2 Power Consumption	0.0	SSR 3 Power Consumption	0.0	SSR 4 Power Consumption	0.0	SSR Total Power Consumption	0.0	Relay's Coil consumption	0.0	TOTAL POWER OF CONTROLLER'S TRANSFORMER	2.2	<p>SKU: VLC16u8-T1L-BLE</p> <p>Power: 12 VA</p> <p>Loads Exercised:</p> <p>T1L Ports x 1</p>	<table><tr><td>Model</td><td>VLC16u8-T1L-BLE</td></tr><tr><td>Number of Ethernet Ports in use</td><td>2</td></tr><tr><td>Number of T1L Ports in use</td><td>0</td></tr><tr><td>Number of UIOs configured as AOx</td><td>16</td></tr><tr><td>Microset Device</td><td>Microset 4</td></tr><tr><td>Current Drawn from 24VDC output 1 (Small)</td><td>75</td></tr><tr><td>Current Drawn from 24VDC output 2 (Large)</td><td>75</td></tr><tr><td>Current Drawn from 24VDC output 3 (Large)</td><td>75</td></tr><tr><td>Current Drawn from POW24 (Large)</td><td>200</td></tr><tr><td>Current Drawn from SSR 1 @24VAC</td><td>0</td></tr><tr><td>Current Drawn from SSR 2 @24VAC</td><td>0</td></tr><tr><td>Current Drawn from SSR 3 @24VAC</td><td>0</td></tr><tr><td>Current Drawn from SSR 4 @24VAC</td><td>0</td></tr><tr><td>How many relay outputs are being used?</td><td>0</td></tr><tr><td>External device</td><td>None</td></tr><tr><td>External power supply is being used for SSR outputs?</td><td>No</td></tr><tr><td>Base Power Consumption **</td><td>2.2</td></tr><tr><td>Ethernet Power Consumption</td><td>0.0</td></tr><tr><td>T1L Power Consumption</td><td>0.0</td></tr><tr><td>UIO Power Consumption</td><td>17.6</td></tr><tr><td>Microset Power Consumption</td><td>0.0</td></tr><tr><td>Total Power Consumption from Aux Outputs</td><td>23.2</td></tr><tr><td>SSR 1 Power Consumption</td><td>0.0</td></tr><tr><td>SSR 2 Power Consumption</td><td>0.0</td></tr><tr><td>SSR 3 Power Consumption</td><td>0.0</td></tr><tr><td>SSR 4 Power Consumption</td><td>0.0</td></tr><tr><td>SSR Total Power Consumption</td><td>0.0</td></tr><tr><td>Relay's Coil consumption</td><td>2.8</td></tr><tr><td>TOTAL POWER OF CONTROLLER'S TRANSFORMER</td><td>58.0</td></tr></table>	Model	VLC16u8-T1L-BLE	Number of Ethernet Ports in use	2	Number of T1L Ports in use	0	Number of UIOs configured as AOx	16	Microset Device	Microset 4	Current Drawn from 24VDC output 1 (Small)	75	Current Drawn from 24VDC output 2 (Large)	75	Current Drawn from 24VDC output 3 (Large)	75	Current Drawn from POW24 (Large)	200	Current Drawn from SSR 1 @24VAC	0	Current Drawn from SSR 2 @24VAC	0	Current Drawn from SSR 3 @24VAC	0	Current Drawn from SSR 4 @24VAC	0	How many relay outputs are being used?	0	External device	None	External power supply is being used for SSR outputs?	No	Base Power Consumption **	2.2	Ethernet Power Consumption	0.0	T1L Power Consumption	0.0	UIO Power Consumption	17.6	Microset Power Consumption	0.0	Total Power Consumption from Aux Outputs	23.2	SSR 1 Power Consumption	0.0	SSR 2 Power Consumption	0.0	SSR 3 Power Consumption	0.0	SSR 4 Power Consumption	0.0	SSR Total Power Consumption	0.0	Relay's Coil consumption	2.8	TOTAL POWER OF CONTROLLER'S TRANSFORMER	58.0	<p>SKU: VLC16u8-T1L-BLE</p> <p>Power: 58 VA</p> <p>Loads Exercised:</p> <p>T1L Ports x 2</p> <p>Microset x 1</p> <p>UIOs x 16</p> <p>AUX OUT x 3</p> <p>POW 24</p> <p>Relays enabled</p>
Model	VLC16u8-T1L-BLE																																																																																																																						
Number of Ethernet Ports in use	1																																																																																																																						
Number of T1L Ports in use	0																																																																																																																						
Number of UIOs configured as AOx	0																																																																																																																						
Microset Device	None																																																																																																																						
Current Drawn from 24VDC output 1 (Small)	0																																																																																																																						
Current Drawn from 24VDC output 2 (Large)	0																																																																																																																						
Current Drawn from 24VDC output 3 (Large)	0																																																																																																																						
Current Drawn from POW24 (Large)	0																																																																																																																						
Current Drawn from SSR 1 @24VAC	0																																																																																																																						
Current Drawn from SSR 2 @24VAC	0																																																																																																																						
Current Drawn from SSR 3 @24VAC	0																																																																																																																						
Current Drawn from SSR 4 @24VAC	0																																																																																																																						
How many relay outputs are being used?	0																																																																																																																						
External device	None																																																																																																																						
External power supply is being used for SSR outputs?	No																																																																																																																						
Base Power Consumption **	2.2																																																																																																																						
Ethernet Power Consumption	0.0																																																																																																																						
T1L Power Consumption	0.0																																																																																																																						
UIO Power Consumption	0.0																																																																																																																						
Microset Power Consumption	0.0																																																																																																																						
Total Power Consumption from Aux Outputs	0.0																																																																																																																						
SSR 1 Power Consumption	0.0																																																																																																																						
SSR 2 Power Consumption	0.0																																																																																																																						
SSR 3 Power Consumption	0.0																																																																																																																						
SSR 4 Power Consumption	0.0																																																																																																																						
SSR Total Power Consumption	0.0																																																																																																																						
Relay's Coil consumption	0.0																																																																																																																						
TOTAL POWER OF CONTROLLER'S TRANSFORMER	2.2																																																																																																																						
Model	VLC16u8-T1L-BLE																																																																																																																						
Number of Ethernet Ports in use	2																																																																																																																						
Number of T1L Ports in use	0																																																																																																																						
Number of UIOs configured as AOx	16																																																																																																																						
Microset Device	Microset 4																																																																																																																						
Current Drawn from 24VDC output 1 (Small)	75																																																																																																																						
Current Drawn from 24VDC output 2 (Large)	75																																																																																																																						
Current Drawn from 24VDC output 3 (Large)	75																																																																																																																						
Current Drawn from POW24 (Large)	200																																																																																																																						
Current Drawn from SSR 1 @24VAC	0																																																																																																																						
Current Drawn from SSR 2 @24VAC	0																																																																																																																						
Current Drawn from SSR 3 @24VAC	0																																																																																																																						
Current Drawn from SSR 4 @24VAC	0																																																																																																																						
How many relay outputs are being used?	0																																																																																																																						
External device	None																																																																																																																						
External power supply is being used for SSR outputs?	No																																																																																																																						
Base Power Consumption **	2.2																																																																																																																						
Ethernet Power Consumption	0.0																																																																																																																						
T1L Power Consumption	0.0																																																																																																																						
UIO Power Consumption	17.6																																																																																																																						
Microset Power Consumption	0.0																																																																																																																						
Total Power Consumption from Aux Outputs	23.2																																																																																																																						
SSR 1 Power Consumption	0.0																																																																																																																						
SSR 2 Power Consumption	0.0																																																																																																																						
SSR 3 Power Consumption	0.0																																																																																																																						
SSR 4 Power Consumption	0.0																																																																																																																						
SSR Total Power Consumption	0.0																																																																																																																						
Relay's Coil consumption	2.8																																																																																																																						
TOTAL POWER OF CONTROLLER'S TRANSFORMER	58.0																																																																																																																						


Note: The Nominal Power Consumption does not include (SSR, Relay, UIO, AC/DC output). Only the controller is connected to transformer.

Note: The Maximum Power Consumption include (External Devices, Communication, Bluetooth Universal IO output and 24 VDC output, excluding the load on the SSRs and Relays).

Note: The Nominal Power Consumption does not include (SSR, Relay, UIO, AC/DC output). Only the controller is connected to transformer.

Note: The Maximum Power Consumption include (External Devices, Communication, Bluetooth Universal IO output and 24 VDC output, excluding the load on the SSRs and Relays).

Fig. 7 Power Consumption Details



CAUTION

Risk of Electric Shock: More than one disconnect switch may be required to de-energize the equipment before servicing. To Reduce the Risk of Fire or Electric Shock, Do Not Interconnect the Outputs of Different Class 2 Circuits.

Grounding

Building earth ground (terminal 1) is a functional grounding, and it does not offer shock protection from a hazardous voltage. Connect the building earth ground (terminal 1) to the panel ground using the proper cable as shown above. Ensure that the panel ground connects to a known earth ground.

Selecting a power supply wire

Using the correct wire size is critical for long power supply wiring runs. If the wire is too small, the resistance can be too high, resulting in a low voltage supply to the Unitary Controllers. This is known as line loss. The wire size is based on the length of the wire run and the current draw of the Unitary Controller to be powered.

Figure below describes the wire size based on maximum current draw and distance between the transformer and the Unitary Controller.




Fig. 8 Determining the appropriate wire size

For example, follow the below steps to determine the appropriate wire type to power a Unitary Controller with a transformer that is 110 feet from the Unitary Controller:

1. Find the maximum current drawn. For the Unitary Controller, the maximum current draw is 65 VA.
2. As shown in the above figure, find the intersection of the 65 VA line on the vertical axis (y) and 110 feet on the horizontal axis (x).
3. Read the diagonal line to the right of the intersection point.

In this example, use 12 AWG wire or larger. (A smaller AWG designation indicates larger wire.)




Fig. 9 Example of determining appropriate wire type

INPUT / OUTPUT WIRING

Wiring Requirements

NOTE:
When attaching two or more wires to the same terminal, other than 14 AWG (2.0 mm²), be sure to twist them together. Deviation from this rule can result in improper electrical contact.

Each terminal can accommodate the following gauge of wire:

- **Single wire:** From 22 AWG (0.3 mm²) to 18 AWG (1 mm²) solid or stranded
- **Multiple wires:** Up to two 18 AWG (1 mm²) stranded, with 1/4 watt wire-wound resistor
 - Prepare wiring for the terminal blocks, as follows:
 - Strip 1/2 in. (13 mm) insulation from the conductor.
 - Cut a single wire to 3/16 in. (5 mm). Insert the wire in the required terminal location and tighten the screw.
 - If two or more wires are being inserted into one terminal location, twist the wires together with a minimum of three turns before inserting them, see [Fig. 10](#).
 - Cut the twisted end of the wires to 3/16 in. (5 mm) before inserting them into the terminal and tightening the screw.
 - Pull-on each wire in all terminals to check for good mechanical connection.

NOTE:
Do not over-tighten the terminal screws to avoid deformation and damage to the terminal block. The maximum torque for the terminal screws is 4.4 in-lb (0.5 Nm).




Fig. 10 Attaching Two or More Wires at Terminal Block

Internal Wiring Examples

Internal Wiring Large Controller




Fig. 11 Internal Wiring Large controller

Internal Wiring Small Controller




Fig. 12 Internal Wiring Small controller

Identifying terminals and terminal wire

Each Unitary Controller label identifies wiring terminals by number and function. Terminals are numbered from top to bottom, beginning with one on the upper left side of the controller and continuing top-to-bottom on the right side.

Power supply terminals

Three terminals (pin 1,2,3) are used to connect the 24 VAC power supply to the Unitary Controller. These are always side-by-side and are usually located on the upper-left or right side of the controller.




Fig. 13. Power wiring terminals

Grounded terminals

Ground (GND) terminal (pin 1) is used for terminating the grounded leg of the 24 VAC circuit or BO return grounds.




Fig. 14 Grounded terminals



IMPORTANT:

Never terminate input signals to a GND terminal.

Common terminals

Common (COM) terminals (pin 19, 22, 33, 36, 41, 44, 47, 51, 53, 56, 59, 62, 64, 67, 70) (common ground, or input signal return ground) provide a low-impedance connection for input circuitry to the Unitary reference ground. Use these to terminate the return ground for inputs.




Fig. 15 Common terminals



IMPORTANT:

Input common terminals (those nearest to IN terminals) are internally connected to a separate input ground plane. To maximize input accuracy, always connect input return grounds only to these COM terminals. Do not connect outputs or power grounds to input COM terminals.

Universal inputs and outputs terminals

Use Universal Input terminals (32 to 38, 52 to 72) (in conjunction with adjacent COM terminals) to connect universal inputs.




Fig. 16 UIO terminals

24 VDC Source

The 24 VDC source provides low-current 24 VDC to power transducers or other sensors. For non-Unitary devices, this terminal provides a maximum 75 mA.




Fig. 17 24 VDC Source terminals

For more details refer [Terminal Connections on page 23](#) and Input / Output Wiring on page 18.

TERMINAL CONNECTIONS

All the terminals for this controller are removable.

Table 15 Terminal Connections

Terminal	Label	Description
POWER 24V		
1		Functional earth ground (Connected to building earth ground)
2	V0	Power supply voltage (connected to 24 V0)
3		Power supply voltage (connected to 24 VAC or VDC)
SPDT RELAY		
4	NC1	SPDT Relay 1 Normally Close (BO-21)
5	NO1	SPDT Relay 1 Normally Open (BO-21)
6	IN1	SPDT Relay 1 Input Power (BO-21)
7	NC2	SPDT Relay 2 Normally Closed (BO-22)
8	NO2	SPDT Relay 2 Normally Open (BO-22)
9	IN2	SPDT Relay 2 Input power (BO-22)
10	NC3	SPDT Relay 3 Normally Closed (BO-23)
11	NO3	SPDT Relay 3 Normally Open (BO-23)
12	IN3	SPDT Relay 3 Input power (BO-23)
13	NC4	SPDT Relay 4 Normally Closed (BO-24)
14	NO4	SPDT Relay 4 Normally Open (BO-24)
15	IN4	SPDT Relay 4 Input power (BO-24)
SPDT SSR		
16	AUX OUT	24 VAC or VDC output (depending on power supply)
17	SRIN	SSR power input (Connected to AUX OUT with a factory jumper)
18	SR1	Solid State Relay Output 1 (BO-31)
19	C	Common
20	SR2	Solid State Relay Output 2 (BO-32)
21	SR3	Solid State Relay Output 3 (BO-33)
22	C	Common
23	SR4	Solid State Relay Output 4 (BO-34)
UIO		
32	IO13	Universal Input / Output 13 (AI-13/BI-13/AO-13/BO-13)
33	C	Common
34	IO14	Universal Input / Output 14 (AI-14/BI-14/AO-14/BO-14)
35	IO15	Universal Input / Output 15 (AI-15/BI-15/AO-15/BO-15)
36	C	Common
37	IO16	Universal Input / Output 16 (AI-16/BI-16/AO-16/BO-16)
38	24 VDC OUT	Supplies 24 VDC, 75 mA of current

Table 15 Terminal Connections



Terminal	Label	Description
BACnet® IP CAT5/6 Model		
Port 1	Port 1	Ethernet IP 1, 10/100 Switched
Port 2	Port 2	Ethernet IP 2, 10/100 Switched
BACnet® IP T1L Model		
39	DA+	T1L Port 1 +
40	DA-	T1L Port 1 -
41		T1L Port 1 Common
42	DA+	T1L Port 2 +
43	DA-	T1L Port 2 -
44		T1L Port 2 Common
RS485 1		
45	+	RS485 Modbus +
46	-	RS485 Modbus -
47	COM	Connected to V0.
Power Output (PWR OUT)		
48	AUX OUT	24 VAC / VDC Auxiliary power output (connected to terminal 3)
49	V0	24 VAC / VDC Auxiliary Power output (connected to terminal 2)
Microset Bus (For Microset II and Microset 4)		
50	MSET	Microset/Microtouch (AI-0).
51	COM	Common
UIO		
52	IO1	Universal Input / Output 1 (AI-1/BI-1/AO-1/BO-1)
53	C	Common
54	IO2	Universal Input / Output 2 (AI-2/BI-2/AO-2/BO-2)
55	IO3	Universal Input / Output 3 (AI-3/BI-3/AO-3/BO-3)
56	C	Common
57	IO4	Universal Input / Output 4 (AI-4/BI-4/AO-4/BO-4)
58	IO5	Universal Input / Output 5 (AI-5/BI-5/AO-5/BO-5)
59	C	Common
60	IO6	Universal Input / Output 6 (AI-6/BI-6/AO-6/BO-6)
61	IO7	Universal Input / Output 7 (AI-7/BI-7/AO-7/BO-7)
62	C	Common
63	IO8	Universal Input / Output 8 (AI-8/BI-8/AO-8/BO-8)
64	C	Common
65	24 VDC OUT	Supplies 24 VDC, 75 mA of current
66	IO9	Universal Input / Output 9 (AI-9/BI-9/AO-9/BO-9)

Table 15 Terminal Connections

Terminal	Label	Description
67	C	Common
68	IO10	Universal Input / Output 10 (AI-10/BI-10/AO-10/BO-10)
69	IO11	Universal Input / Output 11 (AI-11/BI-11/AO-11/BO-11)
70	C	Common
71	IO12	Universal Input / Output 12 (AI-12/BI-12/AO-12/BO-12)
72	24 VDC OUT	Supplies 24 VDC, 75 mA of current

UIO Wiring Examples





Fig. 18 Universal IO Wiring Examples



NOTE:

- UL Standards recommend all wiring connections for the IO, SSR, 24 VAC / VDC circuits are restricted to the same room.
- Use a protective diode for any circuit that allows the current to flow forward because the current will not flow in the reverse direction. The diode protects the components responsive to the current flow through them in the wrong direction.

SSR (DO) Wiring Examples



Solid State Relay (SSR)



⚠ WHEN CONNECTING POWER TO THE UNITARY CONTROLLERS, CONNECT THE COM OF THE VAC SECONDARY CIRCUIT TO A KNOWN EARTH GROUND.

Fig. 19 SSR (DO) Wiring Examples

- NOTE:**
- SR IN (terminal 17, SSR power input) is connected to AUX OUT (terminal 16, 24 VAC~ output) by a jumper wire provided by the factory.
 - Remove the jumper if you want to power field devices with an external power supply - 24 VAC transformer or 20 VDC.
 - All terminals are protected against short circuit and 24 VAC.
 - Use wire only.

CAUTION

Risk of Electric Shock: More than one disconnect switch may be required to de-energize the equipment before servicing.

Auxiliary Wiring Examples




Fig. 20 Auxiliary Wiring Examples

NOTE:

The Auxiliary power output (terminals 48, 49) is supplied from the controller input power supply (terminals 3, 2 respectively). The polarity of the external devices must be checked with the controller input power supply. If the polarity is reversed, external devices may be damaged.

SPDT Relay Wiring Examples




Fig. 21 SPDT Relay Wiring Examples

MICROSET BUS

Alerton Unitary Controllers have dedicated Wall Modules bus compatible with Alerton wall modules such as Microtouch, Microset II & Microset 4. These compatible wall modules can be connected to the controller's wall module bus (terminals 50 and 51).

- The input from the Microset should always be connected to terminal 50.
- The maximum current provided at the Wall Module bus interface is 96 mA.

Microtouch

A Microtouch uses three conductor cable one for power supply and other two for input/common connections to all Unitary Controllers.

Wiring for the Microtouch is as follows:

Yellow wire: Terminates to any UIO 1-8 or 1-16 (10 k Ω space temperature thermistor).

White wire: Terminated to COM (Ground).

Red wire: Terminates to any UIO 1-8 or 1-16 (Setpoint bias).

The setpoint bias potentiometer is a 5 k Ω single-turn potentiometer that reads 1.9 k Ω to 2.8 k Ω as the setpoint bias lever travels from the C to H position.

For Microtouch connections 18 AWG, two conductors twisted shield cable is required. With the Alerton-recommended wire, the maximum distance is 250 feet.



NOTE:

A jumper is recommended for Microtouch configuration, jumper is connected between Microtouch 10K thermistor terminal and MSET terminal. This allows for option of connecting a Field Service Tool. Temperature reading will not be correct without jumper installed unless MV Object Microtouch type is used.

Microset II

A Microset II has three conductor connection to all Unitary Controllers.

Wiring for the Microset II is as follows:

Black wire: Terminal 1 on the MS4 to the terminal 50 labeled MSET.

White wire: Terminal 2 on the MS4 to the terminal 51 COM.

Orange wire: Terminal 3 on the MS4 to terminal 48 (Aux Out).

For Microset II connections, 18 AWG two conductor twisted shield cable is required. With Alerton-recommended wire, the maximum distance is 250 feet.

Microset 4

A Microset 4 has three conductor connection to all Unitary Controllers.

Wiring for the microset 4 is as follows:

Red wire: Terminal 1 on the MS4 to terminal 48 (Auxiliary Output).

White wire: Terminal 2 on the MS4 to the terminal 51 COM.

Black wire: Terminal 3 on the MS4 to the terminal 50 labeled MSET.

For Microset 4 connections, use 18 AWG shielded, twisted-pair cable for best results. With Alerton-recommended wire, the maximum distance is 250 feet.



NOTE:

The Alerton Unitary Controllers also support legacy microset wall modules such as MS-1010-BT, MS-1010H-BT, MS-1030-BT, MS-1030H-BT.

Wire shields and shield grounding

Use 18 AWG two-conductor twisted shield cable for all inputs and analog outputs to reduce electrical interference (noise). A single-point grounding scheme that uses the transformer or panel ground is optimum. Ground only one end of the shield drain wire.



CAUTION

Do not ground shields to any terminal on the Unitary Controller because any signal on the shield is routed through the Unitary Controller circuit board to earth ground. Improper grounding can cause equipment damage.

Microset II/ Microset 4 / Microtouch Wiring Examples




Fig. 22 Alerton Unitary Controller wiring with Microset 4 (Large Variant)




Fig. 23 Alerton Unitary Controller wiring with Microset 4 (Small Variant)





Fig. 24 Alerton Unitary Controller wiring with Microset II (Large Variant)










Fig. 27 Alerton Unitary Controller wiring with Microtouch (Small Variant)




Modbus LED Status


Table 17 Modbus LED Status

LED Status	Visual	Mode
Green LED permanent ON		Modbus Communication is healthy - Successful to read/write all of Modbus registers configured in the application.
Yellow LED permanent ON		Modbus Communication is not healthy - failure to read/write some of Modbus registers configured in the application.
Red LED permanent ON		Modbus Communication failure - failure to read/write all of the Modbus registers configured in the application.
LED OFF		No Modbus registers have been configured or found on the application.

IP T1L LED Status



Table 18 IP T1L LED Status

LED Status	Visual	Mode
Green LED permanent OFF		Link is up, Valid IP address is configured. Communication is healthy.
Yellow LED permanent OFF		Link is up, no valid IP address is configured.
LED OFF		Link is down.

 **NOTE:**
In the IP T1L network for example, 5 devices are connected in daisy chain like device 1, 2, 3 and so on. If the device 2 is powered off (Daisy chain connection not disturbed) the link from device 1 and device 3 is still up, and the IP T1L LED status also in solid green.

Service Pin LED Status

Table 19 Service Pin LED Status

LED Status	Visual	Mode
Green LED permanent ON		On Service PIN button Press
LED OFF		On release of Service PIN button

UNITARY CONTROLLERS CONFIGURATION

Compass Device Configuration

The configuration of the Unitary controller can be completed like most other Alerton controllers by doing the following:

**NOTE:**
A Compass Device Configuration of the Unitary Controller is compatible with version 2.2.3.7 and higher.

1. From the Compass menu, click **Device Manager**.
2. Click **Device Scan**.
3. Choose the option Scan configurable Alerton devices.
4. Click Scan.
5. As soon as the Unitary device appears, click Stop.
6. Click Configure.

Recovering from a Misconfiguration

If the communication with VLC is not possible due to incorrect or unknown configuration, then the user can use Compass “Scan for configurable devices” feature via BACnet/Ethernet.

Initial Screen





Fig. 29 Edit Device Configuration

Table 20 Device Configuration

Configuration Parameter	Values	Description	Default
Host name		Must be a valid host name, and special characters are also acceptable	VLC

**NOTE:**
Every time a change in configuration is sent to the device, a reboot is expected before new configurations take place. Once device comes back online, all new configurations will be effective. User can observe bi-color LED during this process. When the LED turns off for a few seconds it means the device is rebooting. The complete process will vary in time and is in direct proportion to the number of existing objects (trendlogs, schedules, alarms, etc.) stored in the device. Therefore, even after the Tri-color LED comes back on, the device might still not be reachable for some time. Refer Factory Reset Using the Service Button on page 8 for more details.

Data Persistence and Backup

All programmed objects (such as schedules, trendlogs and alarms), DDC, data values, and the ROC file execute in RAM and are periodically backed up in flash memory. Data is retained through power loss as follows:

- VLC16u8/VLC8u8 data is backed up every 5 minutes or less.
- Trend logs data is backed up every 15 minutes.
- Niagara has its own periodic writing schedule. This is configurable; the default is once per day.

Configuration parameters are stored in flash memory. Likewise, all configuration data is retained through power loss.

Configuration parameters can be saved in the DCF file and then sent to the Unitary. This facilitates off-site setup and easy replication of settings to other controllers in similar installations.

Ethernet and IP




Fig. 30 Edit Device Configuration, Ethernet, and IP Settings

Table 21 Ethernet and IP Settings

Configuration Parameter	Values	Description	Default
Config method for DNS server	None DHCPv4 SLAAC Manual	Method how DNS will be configured for this device.	None
Manual DNS Server 1 (IPv4/IPv6 addr)		Manual entry for DNS entry. Only valid if Manual was selected as the Config method for DNS server above.	
Manual DNS Server 2 (IPv4/IPv6 addr)		Manual entry for DNS entry. Only valid if Manual was selected as the Config method for DNS server above.	
ETH MTU		The Maximum Transmission Unit (MTU) in bytes. Default is 1500 (typical for Ethernet networks).	1500
IPv4 Info			
Enable IPv4	Y/N	Enable/Disable the IPv4 Protocol	Y
Configuration method for IPv4 address	DHCP Manual	How will IPv4 address be obtained	Manual
Manual IPv4 address		IP address input by default configuration was selected above	192.168.1.200

Table 21 Ethernet and IP Settings

Configuration Parameter	Values	Description	Default
Manual IPv4 netmask		Subnet mask input by default configuration was selected above.	255.255.255.0
Config method for IPv4 default gateway	DHCP Manual None	How will default gateway selection be set	None
Manual IPv4 default gateway		By default gateway input configuration was selected above.	0.0.0.0
Allow traffic to/from other subnets [ADVANCED]	Y/N	Security feature to prevent devices from another subnet from reaching this device.	N
IPv6 Info			
Enable IPv6	Y/N	Enable/Disable the IPv6 Protocol	N
Configuration method for IPv6 address	SLAAC Manual		SLAAC
Manual IPv6 address		IPv6 address input if manual IPv6 address configuration was selected above	::
Manual IPv6 prefix bits		Manual entry for IPv6 network prefix	64
Allow traffic to/from other subnets [ADVANCED]	Y/N	Security feature to prevent devices from another subnet reaching this device.	N

BACnet Configuration




Fig. 31 BACnet Configuration

Table 22 BACnet Configuration

Configuration Parameter	Values	Description	Default
Device Instance	1 to 30001	The numeric instance of the VLC as a device on the BACnet network (must be unique for the entire system).	30001
DDC write priority (9...16)	9 to 16	A higher priority for writing takes precedence over lower priorities. The highest priority is 1, the lowest is 16. These are also called indexes of the priority array. This table depicts the typical priorities used.	14
Default COV Resubscription Interval (minutes, 0=disable)	0 to 10	This value is the interval in minutes that the VLC will use for re-subscribing to external points to be notified on changes of value (if the external device does not support the change of value notifications, the VLC will default to polling). NOTE: A value of 0 will disable the VLC ability to send COV Subscriptions.	10
NR holdoff time (seconds, 10...900)	10 to 900	To enhance performance and reduce wasted bandwidth when devices are not present, or temporarily offline, the VLC will fall back to a periodic communications check for devices to which it has stopped receiving responses. The NR Holdoff Time specifies the time in seconds the VLC will wait after determining a device is offline before trying to talk to it again. It is recommended to set this value low for the initial setup (1-2min), then bump it up once everything is up and working. Minimum of 10 seconds, maximum of 900 seconds (15 minutes) default is 600 seconds (10 minutes).	600
Max_APDU_Length Upper Limit	1024 to 1476	Maximum BACnet message size the device can/will accept. Typically associated with complex data or read property multiple requests. For IPv6 installations, it is recommended to drop this down to 1440 or lower.	1476
Password for BACnet Backup NOTE: This setting is only available in the Device Configuration screens within Compass 2.2.0		This is the password used for the BACnet Device Communications Control (Backup Password limit is between 8 and 64 characters.	xxxxxxxx
Password for BACnet Restore and Restart/Control: NOTE: This setting is only available in the Device Configuration screens within Compass 2.2.0		This is the password used for the BACnet Device Communications Control (Enable/Disable communications, and Restore), and Reinitialize Device (Reinitialize Warmboot and Reinitialize Coldboot) services. Password limit is between 8 and 64 characters.	xxxxxxxx

BACnet Point Objects




Fig. 32 BACnet Point Objects

Table 23 BACnet Point Objects

Configuration Parameter	Values	Description	Default
Include diagnostic points in object list	Y/N	Diagnostic points in the 100,000+ range will be listed in the Object List property. NOTE: If enabled, diagnostic points will also be saved into the device's point data MDB file, which may not be desirable.	N

BACnet Network Configuration




Fig. 33 BACnet Network Connection

Table 24 BACnet Network Configuration

Configuration Parameter	Values	Description
BACnet Network Type	BACnet IPv4 BACnet IPv6 BACnet/Ethernet	Select BACnet Network Connection and then from the BACnet Network Type, select required network from the drop-down list.

BACnet/IPv4




Fig. 34 BACnet/IPv4

Table 25 BACnet/IPv4

Configuration Parameter	Values	Description	Default
Mode	Normal Register as foreign device	Controls the mode of participation on the BACnet network	Normal
Normal mode settings			
UDP Port		Specifies the UDP Port number to be used by BACnet/IPv4. The range is 1-65534, but many numbers are reserved or used for common services unrelated to BACnet (contact the site's IT department for any limitations and restrictions). The default value is 47808 (which corresponds to 0xBAC0 in hexadecimal).	47808
Disable Local Broadcast	Y/N	Prevent the VLC from sending and Broadcast messages on the specified IP network.	N
Register as foreign device mode settings			
Min auto-assigned local UDP port		Automatically assign the minimum UDP Port value to the Alerton controller while Registering as a Foreign Device.	49512
Max auto-assigned local UDP port		Defines the maximum UDP Port value for auto assigning to the Alerton controller when Registering as a Foreign Device.	65534
Register with BBMD at address/name		Input IP address or Host Name for BBMD to register with. NOTE: Host Name Lookup requires setting up a valid DNS Server reference.	
Register with BBMD on UDP port		Specifies the UDP Port number of the BBMD to which you want to register. The range is 1-65534, but many numbers are reserved, or used for common services unrelated to BACnet (contact the site's IT department for any limitations and restrictions). Default is the BACnet standard 47808 (which corresponds to 0 x BAC0 in hexadecimal).	47808
Reregistration interval (sec)	10-3600	Specifies frequency re-registration of the Alerton controller with the BBMD. Since Foreign Devices must register with a BBMD to enable broadcast traffic to be received from, and sent to the Foreign Device, and since Foreign device registration is not required to be persisted in the event of a BBMD reset, it is important to select a value for reregistration that balances data criticality with network performance. In most cases the default 300sec (5 minutes), reregistration interval is more than adequate for ensuring the foreign device has connectivity into the system, but in some cases where you have critical data being passed to/from the foreign device, you may want to bump the reregistration up to 60sec, or even the minimum value of 10 sec.	300

BACnet/IPv6




Fig. 35 BACnet/IPv6

Table 26 BACnet/IPv6

Configuration Parameter	Values	Description	Default
Mode	Normal Register as foreign device	Control the mode of participation on the BACnet network.	Normal
Use real VADDR for device instance 4194303	Y/N	<p>Enables/Disables the use of the device's real VADDR when the device instance is set to 4194303. The default setting is disabled.</p> <p>For IPv6 devices, the MAC address is a very large value. To shorten the values BACnet passes across the network and to simplify device identification a Virtual MAC is used that equals the devices Device Instance. In the event two IPv6 devices had the same device instance (as in the case of the default instance 4194303), this could result in difficulties communicating with and re-configuring the devices (as the devices Net and MAC would appear there same). For this reason, a random Virtual Address "VADDR" is chosen for devices with the default device instance 4194303 to ensure each device has a unique address. Enabling this feature will result in the VMAC getting set to the device's real instance of 4194303.</p> <p>NOTE: It is never recommended to use the default device instance, so enabling this feature should not be necessary.</p>	N
Normal mode settings			
UDP Port		Specifies the UDP Port number to be used by BACnet/IPv6. The range is 1-65534, but many numbers are reserved or used for common services unrelated to BACnet (contact the site's IT department for any limitations and restrictions). The default value is 47808 (which corresponds to 0xBAC0 in hexadecimal).	47808

Configuration Parameter	Values	Description	Default
Multicast prefix		Specifies the multicast prefix to be used by your IPv6 network. This multicast prefix defines the scope of the multicast transmission, or how far the multicast address will propagate (this is dependent on the network configuration and the Site setup, so contact the local IT specialist for specifics).	ff02::
Register as foreign device mode settings			
Min auto-assigned local UDP port		Automatically assign the minimum UDP Port value to the Alerton controller while Registering as a Foreign Device.	49152
Max auto-assigned local UDP port		Defines the maximum UDP Port value for auto assigning to the Alerton controller when Registering as a Foreign Device.	65534
Register with BBMD at address/name		The name or IPv6 address of BBMD to register with can be used. If the name is used, DNS must be configured and working properly.	
Register with BBMD on UDP port		Specifies the UDP Port number of the BBMD to which you want to register. The range is 1-65534, but many numbers are reserved, or used for common services unrelated to BACnet (contact the site's IT department for any limitations and restrictions).	47808
Reregistration interval (sec)	10-3600	Specifies how often the Unitary Controller will re-register with the BBMD. Since Foreign Devices must register with a BBMD to enable broadcast traffic to be received from, and sent to the Foreign Device, and since Foreign device registration is not required to be persisted in the event of a BBMD reset, it is important to select a value for reregistration that balances data criticality with network performance. In most cases the default 300sec (5 minutes), reregistration interval is more than adequate for ensuring the foreign device has connectivity into the system, but in some cases where you have critical data being passed to/from the foreign device, you may want to bump the reregistration up to 60sec, or even the minimum value of 10 sec.	300



NOTE:

In rare cases some controllers may enter a Non-Responsive state when configuring for IPv6 if previously configured for IPv4. If this occurs, power cycle the controller and it will restart configured for IPv6.

BACnet Compatibility




Fig. 36 BACnet Compatibility

Table 27 BACnet Compatibility

Configuration Parameter	Values	Description	Default
Enable extensions for large networks	Y/N	This feature attempts to space out initial Trendlog notifications on VLC that have many Trends setups with the same interval (to distribute the load on the server).	N
Relax date/time checking	Y/N	In BACnet Protocol Revision 13, the BACnet specification was updated to more closely define where wildcards can be used in Dates and Times. To meet the specification for a protocol beyond 13 the VLC had to enforce these new requirements, which made some of the default values use by Alerton Frontends to be no longer allowed. To maintain compatibility with Alerton workstation software older than Compass 1.4 Update 2.2.0, this option was added to disable the more restrictive wildcard checking.	N

Time Synchronization Configuration




Fig. 37 Time Synchronization Configuration

Table 28 Time Synchronization Configuration

Configuration Parameter	Values	Description	Default
Time synchronization using	BACnet only NTP only	This configuration item determines whether time sync is done using the BACnet protocol or NTP only.	BACnet only
Configuration method for NTP	Manual DHCPv4	This allows for the automatic configuration of the NTP servers using DHCP. The adapter on which DHCP is enabled should be specified here. The NTP server information can also be entered manually by choosing the “Manual” option here.	Manual
Manual Server 1 Manual Server 2	Any NTP server name or IP address within the LAN. This field allows manual configuration.	Two NTP server names or IP address can be configured. Ideally, the server shall be within the LAN. Ensure that the DNS server and Default GW are configured correctly.	
Minimum NTP polling time in sec	64	The minimum duration in seconds between each request from the client after the first update. The first-time update happens within 2 seconds on startup. This configuration is used for both Manual and DHCP options.	64

UTC Offset, Daylight saving, Latitude, Longitude




Fig. 38 UTC Offset, Daylight Savings, Lat & Lon

Table 29 TC Offset, Daylight Savings, Lat & Lon

Configuration Parameter	Values	Description	Default
Latitude	AV-101910	User input latitude of controller location	47.852429
Longitude	AV-101911	User input longitude of controller location	-122.2684254
Set UTC offset, minutes	.	Type the UTC offset, in minutes, that corresponds to the difference between	0
Daylight Saving Period	Disabled By date range	UTC and local standard time where the Alerton operates. Time zones to the West of the zero-degree meridian are positive values and those to the East are negative values. Coordinated Universal Time (UTC) is equivalent to Greenwich Mean Time, which refers to time kept on zero-degree meridian (Greenwich meridian). Use the UTC offset to specify the time zone in which the VLC is operating. Typical UTC offsets for the US are listed. Atlantic Standard Time: +240 Eastern Standard Time: +300 Central Standard Time: +360 Mountain Standard Time: +420 Pacific Standard Time: +480 Alaska Standard Time: +540 Hawaii-Aleutian Standard Time: +600 Samoa Standard Time: +660	By data range
NOTE: Additional parameters, DST START DATE & TIME, and DST END DATE & TIME fields are not accessible via the serial configuration.			

Modbus

Modbus Overview:

This hardware has built-in support for integrating Modbus functionality, allowing for seamless communication and control of external devices. It supports up to 100 AV and 100 BV objects, with the AV range spanning from AV-800 through AV-899 and BV-800 through BV-899. Additionally, the system can handle up to 10 MV (Multistate Value) objects, specifically from MV-0 through MV-9.

A total of up to 10 Modbus slave devices, such as the TR50, TC300, and DALI, can be mapped directly to these allocated registers, enabling flexible and scalable integration of multiple devices into the controller. This feature ensures enhanced connectivity and functionality for diverse HVAC applications.

The performance of Modbus will depend on the baud rate configuration and how long the Modbus server device takes to respond.

For example, if the Modbus server responds fast and immediately, it will take 15 milliseconds to read one register with a baud rate of 9600, thus 64 registers can be read every 1 second if the poll rate is configured as 1 second.

If more registers are configured then for each register read time will take more than 1 second. For example, if 128 registers are configured to be polled every 1 second with a baud rate of 9600, then 128 registers will get read every 2 seconds due to baud rate throughout limitation. In such case increasing 9600 to 19200 will speed up read periodicity to 1 second.

Similarly, for 200 registers polled every 1 second ideal baud rate configured should be 38400.

Modbus Configuration:




Fig. 39 Modbus Configuration

Table 30 Modbus Configuration

Configuration Parameter	Values	Description	Default
Enable Modbus		Enables for a Modbus serial network.	YES
Max retry count	0-9	Specifies the maximum number of retries that the VLC controller will use when attempting to talk to Modbus Slave Devices	3
NR holdoff time	1-60 min	Specifies the time in minutes the VLC controller will wait after determining a Modbus device is offline before trying to talk to it again.	10
Modbus baud rate		Specifies the baud rate for the Modbus serial network	9600
Modbus parity		Specifies the parity to be use on the Modbus serial network	Even

Configuration Parameter	Values	Description	Default
Modbus stop bits		Specifies the number of stop bits to use on the Modbus serial network	One
Max Registers per Message	1-7	Instead of reading one register per message user has the previlage to read max of 7 registers per message.	1

MRPM Configuration:

The present values for input registers are getting reset to zero when MRPM is configured more than 7 by user in DCF.

When the MRPM (Maximum Registers Per Message) is set to a value greater than 1, the controller optimizes read operations by grouping consecutive registers into a single request. For instance, if MRPM is set to 3 and the Modbus CSV file defines consecutive registers for a slave, the controller will attempt to combine three consecutive registers into one read request to that slave.

However, when MRPM exceeds 1, users must ensure that all configured registers for a slave in the CSV file are valid. If any register is invalid, it could cause the entire read request to fail, even for valid registers.

For Example:

SKU	Available Parameters
TR50-5D	Temperature, Humidity, CO2, PM2.5 and TVOC
TR50-5N	Temperature, Humidity, CO2, PM2.5 and TVOC
TR50-3D	Temperature, Humidity and CO2
TR50-3N	Temperature, Humidity and CO2
TR50-5D-U	Temperature, Humidity, CO2, PM2.5 and TVOC
TR50-3D-U	Temperature, Humidity and CO2

Modbus Mapping Registers								
Reg type	Addr	Name	Parameters Applicable on SKUs	Type/ Unit	Default Unit	Bits Num	Range	Scale
Input	1	Temperature	3N/3D/5N/5D	int 16	°F	16	32-122 °F 0-50 °C	0.1
Input	2	Humidity	3N/3D/5N/5D	int 16	% RH	16	0-100	0.1
Input	3	CO2	3N/3D/5N/5D	int 16	ppm	16	0-9999	0.1
Input	4	Particulates PM2.5	5N/5D	int 16	ug/m ³	16	0-5000	1
Input	5	TVOC	5N/5D	int 16	ppb	16	8-2820 ppb 16-5640 ug/m ³	1

Consider a scenario where MRPM is set to 4, and the CSV file for a **TR50-5D** IAQ Sensor device includes the following:

Slave Address	Type	Inst	Gateway String	Name	Descr
1	AV	800	1,3,2,*0.1	Temperature	ZoneTemperature
1	AV	801	1,3,3,*0.1	Humidity	Humidity
1	AV	802	1,3,4	CO2	ZoneCO2
1	AV	803	1,3,5	Particulates PM2	Particulates PM2
1	AV	804	1,3,6	TVOC	TVOC

R50-5D IAQ Sensor supports all the parameters configured in the csv file (Temperature, Humidity, and CO2, PM 2.5, TVOC) and there is will be no issue when reading the parameters from the sensors.

If the user configures MRPM as 4 and uses the same CSV file with a controller connected to the **TR50-3N** IAQ Sensor, which **supports only three sensors: Temperature, Humidity, and CO2**, the controller will attempt to read Temperature, Humidity, CO2, and PM2 in a single request. Since the PM2 sensor is not available in the 3N model, the TR50-3N will reject the request, leading to a failure to read Temperature, Humidity, and CO2 as well.

Sending Device Mapping CSV file to VLC Device

1. Copy the CSV file to the DDC folder (typically C:\Alerton\Compass\2.0\<my REP>\<my JOB>\DDC).
2. Open **Compass Device Manager** and double click the particular VLC model.




Fig. 40 Compass device manager

3. On the Add/Edit Device Profile dialog select the **Preferences** Tab.




Fig. 41 Preference

4. Under Preferences, click on the **CSV application Browser** and select the required CSV file which need to be uploaded.




Fig. 42 CSV file selection

5. Click **OK**, and navigate to Compass device manager page.
6. Select the particular VLC model and send the **Modbus Application**.




Fig. 43 Modbus application

Point Mapping CSV File Format

Refer to the below mentioned TR50 Modbus Register details, using these, CSV files can be created.

Category	RegType	Setup/ Runtime	Addr	Dir	Non- Volatile	Name	SKU	Typ/ Unit	Default Unit	Bits Num	Range	Scale	Default
Disp Values	Input	Runtime	1	R	V	Temperature	3N/3D/5N/ 5D	int16	°F	16	32-122 °F 0-50 °C	0.1	
Disp Values	Input	Runtime	2	R	V	Humidity	3N/3D/5N/ 5D	int16	% RH	16	0-100	0.1	
Disp Values	Input	Runtime	3	R	V	CO2	3N/3D/5N/ 5D	int16	ppm	16	0-9999	0.1	
Disp Values	Input	Runtime	4	R	V	Particular PM2.5	5N/5D	int16	ug/m ³	16	0-5000	1	
Disp Values	Input	Runtime	5	R	V	TVOC	5N/5D	int16	ppb	16	8-2820 ppb 16-5640 ug/m ³	1	
Disp Values	Input	Runtime	14	R	V	Particular PM1	5N/5D	int16	ug/m ³	16	0-5000	1	
Disp Values	Input	Runtime	24	R	V	Particular PM10	5N/5D	int16	ug/m ³	16	0-5000	1	
Disp Values	Input	Runtime	30	R	V	Air quality score	3N/3D/5N/ 5D	int16	signed	16	0-100	1	
Disp Values	Input	Runtime	80	R	NV	TAG Identifier Data	3N/3D/5N/ 5D	int16	string	64	SS-TR50	-	
Disp Values	Input	Runtime	96	R	NV	Host Firmware version	3N/3D/5N/ 5D	int16	signed/int32	32	00 00 00 01 99 99 99 99	-	
Disp Values	Input	Runtime	98	R	NV	BLE Firmware version	3N/3D/5N/ 5D	int16	signed/int32	32	00 00 00 01 99 99 99 99	-	

The format for creating and mapping the VLC device to Modbus Registers is as follows:

Slave Address	Type	Inst	Descr	Name	Units	Gateway String	Poll Int	COV Incr	Enumerations	CFA
1	AV	800	Temperature	Temperature		I,3,1,*0.1	1			L
1	AV	801	Humidity	Humidity		I,3,2,*0.1	1			D
1	AV	802	CO2	CO2		I,3,3	1			D
1	AV	803	cfgLedRing Brightness	cfgLedRing Brightness		I,4,3001	1			D
1	AV	807	Particulates PM	Particulates PM		I,3,4	1			D
1	AV	808	TVOC	TVOC		I,3,5	1			D
1	AV	809	ParticulatesPM1	ParticulatesPM1		I,3,14	1			D
1	AV	810	BLEFirmwareVersion	BLEFirmwareVersion		I,3,98	1			D
1	AV	811	BLEFirmwareUpdateStatus	BLEFirmwareUpdateStatus		I,3,115	1			D
1	MV	800	TempOutOfRange	TempOutOfRange		O,4,2200	1		1: For normal 2: For offnormal	D
1	MV	801	HumiOutOf-Range	HumiOutOf-Range		O,4,2201	1		1: For normal 2: For offnormal	D
1	MV	802	CO2Out-OfRange	CO2Out-OfRange		O,4,2202	1		1: For normal 2:For high limit 3:For high high limit	D
1	MV	803	PM25OutOf-Range	PM25OutOf-Range		O,4,2203	1		1: For normal 2:For high limit 3:For high high limit	D
1	MV	804	TVOCOutOf-Range	TVOCOutOf-Range		O,4,2204	1		1: For normal 2:For high limit 3:For high high limit	D
1	MV	805	AQILevel	AQILevel		O,4,2205	1		1 = For normal 2 = For Moderate limit 3 = For Unhelthy limit	D
1	BV	800	cfgTemperature-Unit	cfgTemperature-Unit		O,0,4000	1			D
1	BV	801	cfgLEDAndLCDEnable	cfgLEDAndLCDEnable		O,0,4020	1			D
1	BV	802	cfgModbusAuto-Baudrate Enable	cfgModbusAuto-Baudrate Enable		O,0,5000	1			D
1	BV	803	cfgModbusFrameCntClear	cfgModbusFrameCntClear		O,0,5001	1			D
1	BV	804	cfgLocalDetectionEnable	cfgLocalDetectionEnable		O,0,5040	1			D

Type: This is the BACnet Point type in the VLC device to which the Modbus Register will get mapped (options are AV, BV,MV).

Inst: This is the BACnet Point instance in the VLC device to which the Modbus Register will get mapped.

Gateway String: This is the Mapping to the Modbus Register.

NOTE: Gateway String **DOES NOT** contain Node (Slave), address.

Name: This is the BACnet Point Name.

Descr: This is the BACnet Point Description.

Units: This is the BACnet Point Units.

Poll Int: This is the interval at which the Modbus Register will get polled on the Modbus Network. This can be set individually on a point by point basis, or if set to 0, it will use the Default Poll Interval defined for the VLC device (set in Device Mapping file).

NOTE: There are many items that determine the correct Polling Interval (Baud rate, number of devices and number of points per device). Starting with higher (slower) values is recommended.

COV Incr: This is the BACnet Change of Value (COV), Increment for the Point. This only applies for Analog points and is used for BACnet COV Notifications (see BACnet COV).

Enumerations: This is a list of Enumerations (and their associated State Text values), for mapping Modbus Register values to/from BACnet Multi-State points. If there is a Modbus Register that represents a set of specific States, you can define an enumeration for each state that will be shown in the BACnet multi-state point.

NOTE: If a Modbus Register returns a value that not match a defined enumeration, the multi-state point will remain at the last read state and change to a reliability of "Configuration Error".

Sending Point Mapping CSV to VLC Device

1. Use Unitary IP Builder tool and the instructions within the tool to create VLC Modbus and related files and activities.




Fig. 44 Modbus Application

2. Give the required Device Instance, Gateway strings, Point Type values and **save** the Modbus application in DDC folder.
3. Open Compass Device Manager.
4. On the Add/Edit Device Profile dialog select the **Preferences** Tab.
5. On the Preferences Tab, click the "**Browse...**" button in the Application section.
6. Select the Point Mapping file with the same Device Instance you created above and click **OK**.
7. From the Main Device Manager dialog highlight Device Instance and click "**Send...**".
8. On the Send Data from Disk to Device(s) dialog select the "DDC or CSV" option, and then click **Send**.

Syslog

Syslog is a standard protocol to send system log messages from the controller to a server, allowing the admin to collect and analyze logs from various network devices in a single location for monitoring, troubleshooting, and security analysis. Syslog is used to prevent the cyber attack. For example, if someone is trying to access the controller from a third-party tool then the Syslog feature will capture if there is any application change in the controller, trying to login via BLE, or trying to access the controller with the wrong Passcode. These messages are captured in the Syslog server.

Syslog Configuration:

Syslog Configuration enables the audit logging feature via an audit logging server. Whenever an audit event happens, the controller will send the information to the Syslog server.

To capture the audit logging event in the external Syslog server, run a Syslog server on the PC. Enable the IP address, either IPv4 or IPv6, in the controller. If the controller is in IPv4, then only IPv4 will work. If the controller is in IPv6, then only IPv6 will work. If the controller is already working on IPv4, then enable Syslog IPv4 as **YES**. Once the IP address is enabled, mention the UDP port number. The standard UDP port number is 514. If the user wants to change the port number, then use the same port number mentioned on the server side. This is the basic configuration to enable the Syslog server. Once this configuration is done, the audit logging events will be pushed to the Syslog server.
Example: Bluetooth connection, Bluetooth login failure

Below are the details about the logs that are supported by Syslog server:

SLno	Facility	Severity	ProclD	MsgID	message
1	LOG_FACILITY_AUTHPRIV	LOG_SEVERITY_WARNING	BLE_AUTHENTICATION	BLE_LOGIN_FAIL	BLE: Login Attempt failure!
2	LOG_FACILITY_AUTHPRIV	LOG_SEVERITY_ERR	BLE_AUTHENTICATION	BLE_LOGIN_LOCKED	BLE: Login Attempt max retry failure! retry after 30 mins
3	LOG_FACILITY_USER	LOG_SEVERITY_ERR	ROC_DOWNLOAD	ROC_DOWNLOAD_FAIL	ROC update: received invalid chunk!
4	LOG_FACILITY_USER	LOG_SEVERITY_ERR	ROC_DOWNLOAD	ROC_DOWNLOAD_FAIL	ROC update: Failed! File size is too big!
5	LOG_FACILITY_USER	LOG_SEVERITY_ERR	ROC_DOWNLOAD	ROC_DOWNLOAD_FAIL	ROC update: Flash partition failure!
6	LOG_FACILITY_USER	LOG_SEVERITY_ERR	ROC_DOWNLOAD	ROC_DOWNLOAD_FAIL	ROC Update: Communication Dropped! Timeout waiting on ROC file!
7	LOG_FACILITY_DAEMON	LOG_SEVERITY_INFO	LOAD_CONFIGURATION	LOAD_CONFIGURATION_REBOOT	New DCF file received, controller will reboot.
8	LOG_FACILITY_ALERT	LOG_SEVERITY_WARNING	WATCHDOG	WATCHDOG_TRIGGER_REBOOT	Watchdog not serviced by (specific thread name)
9	LOG_FACILITY_AUTHPRIV	LOG_SEVERITY_INFO	BLE_AUTHENTICATION	BLE_LOGIN_SUCCESS	BLE: Login success.

Fig. 45 Logs supported by Syslog server

Syslog server implementation is followed by RFC standard **5424**.

Syslog server running on a PC example, **Syslog watcher Manager**.




Fig. 46 Syslog Configuration

Table 31 Syslog Configuration

Configuration Parameter	Values	Description	Default
IPv4			
Enable Syslog	Y/N	Enable/Disable the IPv4 Syslog Protocol	N
Syslog server IP Address		IP address input by default configuration was selected above	192.168.1.212
Syslog server UPD port		Specifies the UDP Port number to be used by BACnet/IPv4	514
IPv6			
Enable Syslog	Y/N	Enable/Disable the IPv6 Syslog Protocol	Y
Manual IPv6 address		IPv6 address input if manual IPv6 address configuration was selected above	2001::b53d:16c3:a748:5f04
Manual IPv6 prefix bits		Manual entry for IPv6 network prefix	64
Syslog server UPD port		Specifies the UDP Port number to be used by BACnet/IPv6	514

BLE Settings

The controllers that support BLE can be used to configure the BLE settings using the following steps. As part of BLE settings, the user can enable/disable the BLE, and set a Passcode within the range that the Passcode is valid for the BLE connection. This Passcode is used by the mobile application to log into the controller.

- 1. From the Device Manager, select the **Controller**, and click **Edit**.
- 2. On the **Capabilities** tab, select **Supports Bluetooth** for BLE controllers.




Fig. 47 BLE Supports

- 3. From the Device Manager, Select **Controllers** and Go to **Advanced** and then select **Set BLE PassCode**.

NOTE:
From the Compass Device Manager, the user can select a Controller in bulk or a single.





Fig. 48 BLE Settings

4. Before enabling or disabling the Bluetooth, a **Time sync** is required.



5. From Push Bluetooth Setting, **Enable** the Bluetooth, Select ☒ **Set BLE Pass Code**. Choose the **Start Date** and **End Date**. Set Pass Code and Click **Send**.




Fig. 49 Push Bluetooth Settings



NOTE:

From the Start Date, set the Pass Code End Date to the next day.
For example;
Start Date - 21/08/2024,
End Date - 22/08/2024.

If the Passcode expires or has expired by the end date, the user must perform the operation from step 3.

Table 32 BLE Configuration

Configuration Parameter	Values	Description	Default
Bluetooth	-	Enable or Disable	
Set BLE Pass Code	-	Enable or Disable	Disable
Day of starting validity password	11-06-2024	-	-
Last day of validity password	11-06-2024	-	-
BLE Pass Code	-	8 number characters	None

**NOTE:**

The correct time should be set in the controller using time sync from Compass before setting the BLE PIN. For more information about time sync, refer to Compass 2.2.3 Installation and Upgrade Guide 31-00314-05.

Configuring all Inputs and Outputs (Templates)

Configuring the I/O for the VLC controller is different from other Alerton products. Please be sure to read through this section in its entirety. The Alerton/Standard templates are used for configuring the I/O of the VLC controllers.

Follow the below steps for navigating to the VLC configuration page:

1. From the Compass, Click Device Manager.




Fig. 50 Compass page

2. Select the required VLC controller from the device manager list and Press **F12**.




Fig. 51 Device Manager

3. It displays the device properties of the VLC8u8-IP-BLE controller. Navigate to the left and click **VAV-IP/VLC IP**.




Fig. 52 VLC Configuration Page

4. From the Device Properties, Select **VLC-8u8** or **VLC-16u8**.




Fig. 53 Device Properties

5. Click the **UIO Configuration (AI/BI)** and **UIO Configuration (AO/BO)** on the VLC top display.

ALERTON COMPASS 2 PASSY

VLC16u8-T1L Device Properties

Object Name: *device 2010* Location: *device 2010*

Description: *device 2010* Instance: *device 2010*

Device Information

Firmware	1.0.0.2 ble 0.0.0.8
ROC	1.0.0.2 ble 0.0.0.8
object-identifier	device 2010
system-status	operational
protocol-version	1
protocol-revision	18
max-APDU-length-accepted	1476
segmentation-supported	segmented-both
APDU-segment-timeout	5000
APDU-timeout	5000
number-of-APDU-retries	3
max-master	"Unknown Property"
max-info-frames	"Unknown Property"
Firmware	1.0.0.2 ble 0.0.0.8
ROC	1.0.0.2 ble 0.0.0.8
DDC file	REP1 JOB1 4V0010 1 *42230010*
System Status	operational
Bluetooth Status	Enabled * Bluetooth Status Applicable only for the BLE Variant

Data/Time

local-time	01:27:37 PM
local-date	11/06/2024
utc-offset	0
daylight-savings-status	false

Misc

Boot Loader	1.0.2.4
System Status	operational
Maintenance Image	1.0.0.2

ALERTON

Fig. 54 VLC Top Display

NOTE: On the primary top display for the Unitary Controller the user can access to all related device templates (i.e., VLC Parameters, AVs, BVs, Alarms, Trendlogs etc.) for configuring the Unitary Controller.

NOTE: The Hardware mode and Data Presentation mode (AI only) must be selected from the input configuration screen.

6. Clicking on Hardware Mode brings you to the I/O configuration screen Input/Output (**Outputs**) for the Unitary Controller.




Fig. 55 Unitary Hardware Mode I/O Configuration (Outputs)

NOTE:
The usage of the UIO as an output is indicated by an Unknown Objects.

7. Clicking on Hardware Mode brings you to the I/O configuration screen Input/Output (**Inputs**) for the Unitary Controller.




Fig. 56 Unitary Hardware Mode I/O Configuration (Inputs)

8. Clicking on **Inputs/Outputs Mode**, navigates to the Unitary Device Object and Description screen.




Fig. 57 Unitary Device Object and Description

Inputs

Device Units

A setting option of English or Metric that determines the scaling of the input and the input units. Example: (°F) for English and (°C) for Metric.




Fig. 58 Device Units

Microset Detection Mode

There are 4 options available in Microset Detection Mode: (1) Reserved, (2) Auto Detect, (3) Always Connected, (4) Disabled.

(1) Reserved: Reserved is for future use. Controller won't accept this value.

(2) Auto detect: (same as Microset AutoDetect = enabled in DDC headers) - this will poll every 12 seconds to see if a Microset is present.

NOTE:

For steady green status LED indication, Microset detection mode=Auto Detect is required. The only exception is if the Res(PB/Pulse)/10k Therm type is used, in which case "disabled" mode should be selected.

(3) Always Connected: (new setting) – Set if a Microset is present. This setting will switch AI-0 to be a temperature sensor and will attempt to talk to the sensor right away. This eliminates the state of power-up where the Microset hasn't yet been detected and odd numbers are displayed.

(4) Disabled: Users can set this option to prevent the "Status LED" from flashing Red when the Microset is disconnected from the controller. When this option is enabled, the "Status LED" will display green as long as no other active alarms exist.




Fig. 59 Microset detection mode

NOTE:

For MicroTouch configurations using Res(PB/Pulse)/10k Therm type, the jumper cannot be used and there is no option to use FST.

For MicroTouch configurations using Res(PB/Pulse)/10k Thermistor type, the option to use the after hours mode with button press is lost.

Hardware Input Mode

Here the hardware mode of physical terminals can be set as analog input, binary input. The Universal Input (UIO) terminals on the VLC are input and can be set up for resistance, push-button, voltage (0-10 V), or current (0-20 mA). Terminal IN0/MSET on the VLC is the only terminal to accept a Microtouch or Microset for input. Terminal IN0 on VLC is the only terminal that cannot be set for pulse input. All other Universal Input Terminals can be configured for pulse input.




Fig. 60 Hardware input mode



NOTE:

The UIO present value will be retained if the user changes the hardware mode to some other type and reverts to the previous configuration (For example - If UIO-2 is configured as "Pulse Totalizer" and the present value is 34 and if the user now changes UIO-2 to AO and then reverts to "Pulse totalizer" again after some time, the present value is retained at 34 and continues from that point instead of starting from 0).

Data Presentation Mode

Defines how the input data is presented under Input Value for analog inputs. The default is counts like other VAVs but can be set to several other possible modes to provide a more user-friendly view of the input data reading.

Based on this setting, under the Input Values for Input Scaling, the low and high values will display the proper engineering unit. For example, if the input is set to a resistance input, and the data presentation mode is set to engineering units, the input values will display in Ohms. Likewise, if the input is set to voltage, setting the data presentation mode again to engineering units, the Input Values would be displayed as Volts.

Any latest firmware version 1.2.0.2 or above enhanced support for the data presentation mode, including compatibility with Type-III configurations and dynamic parameter points.




Fig. 61 Data Presentation Mode

NOTE:
The unknown objects listed indicates that the UIO is being used as an output.

Pulse Value

Pulse value is a configuration parameter when using a pulse input, this setting will provide the value for every pulse. For example, if the hardware mode is set to pulse totalizer it will count the number of pulses and multiply it against the pulse value. If a pulse value is set to 12 to indicate 12 gallons used every time it pulses, the totalizer will show how many gallons have been used over the total number of pulses counted.

Pulse Time Base

Pulse Time Base is used as a configuration parameter when using a pulse input of consumption rate. The pulse time base is indicated in seconds. In conjunction with pulse value, using the gallons example from above, a time interval can be applied. For example, if set to 60, every pulse will indicate gallons per minute, if set to 1, every pulse will indicate gallons per second.




Fig. 62 Pulse Value and Time Base

Input Scaling

All inputs can be scaled via a 2-point scaling mechanism by defining Input Value – Low (X1), Input Value – High (X2), Output Value – Low (Y1), and Output Value – High (Y2). The default is X1=0, X2=1, Y1=0, Y2=1.

For example, an Analog Input (AI) is set to voltage (0-10 V) to measure inches water column and that setting is -0.5 to 1.5 you would set the input low value to 0, input high value to 10, then the output low value to -0.5 and the output high to 1.5 – the AI is now displaying inches water column.

Another example, if a temperature reading is reading a degree high, scaling could be set up to adjust the output value reading – set the output value low to -1 and output value high to 0, the output of the temperature reading should read 1 degree lower.




Fig. 63 Input scaling

Object Units

The object units display the desired units for an analog input present value. For example, if set to Liters, the values will display as Liters in the unit.





Fig. 64 Analog inputs units

Outputs

Hardware Mode

Universal Input / Output (UIO) Terminals in addition to the input modes supported by as noted above, can also support analog output and binary output. For more information on this BO type, see the section below on Binary Outputs.

**NOTE:**
The Present Value remains for some UIOs BACnet objects regardless of the hardware mode (specifically AOs and BOs). It's recommended to set present value to 0 prior to changing hardware mode.

Output Scaling

Like input scaling, outputs are scaled via a 2-point scaling mechanism as well. For example, if we set Input Value – Low (X1) to 0, Input Value – High (X2) to 100, and then Output Value – Low (Y1) to 0 and Output Value – High (Y2) to 100, as we command the AO from 0 to 100 percent DDC signal, it will take the output value and scale it between 2 and 10 VDC. So, if outputting a current output, it'll be between 4 and 20 milliamps. Outputs can be scaled however you want depending on the output type and range.





Fig. 65 Output scaling

**NOTE:**
The Hardware Status (HW Status) section values are calculated after all scaling and has been applied on the controller. This Output Scaling feature removes the need for using a two-point linear scaler in DDC.

Out of Service (For Inputs and Outputs)

Out of Service is now supported directly for AIs/AOs and BIs/BOs and useful as a troubleshooting aid. For inputs, setting Out of Service to TRUE decouples the physical input from what the device is reading. The input now behaves like an AV while in this state. This helps test control routines without having to re-write DDC.

While in **Out of Service** mode, the **Out of Service** flag is set to TRUE, the **Fault** flag is set to TRUE, and **Reliability** will be set to OPEN LOOP. For example, if a temperature sensor goes bad. The AI can be placed into Out of Service mode and the present value can be manually set to a typical running value and everything will run as normal until you replace the temperature sensor. Once the sensor is replaced, return the point to normal operation and the sensed value will now be used.

Out of Service mode for outputs behaves much the same as inputs, the software is decoupled from the hardware and the hardware settings will remain at their last value and allow for testing of control routines.



NOTE:

Ensure that any manually adjusted outputs are returned to a controlled state before returning to service as the adjusted outputs will be treated as the last value and controlled as such.

Placing an input or output into Out of Service

Placing an input or output into Out of Service mode is simple but performed a couple of different ways because available screen real estate of the template.

For inputs on the VLC, you can use the context menu to navigate to the object Properties template using the following steps:

9. Locate the terminal of the point to be put into Out of Service mode, in the image below it is AI 2 which is configured as an Analog Input.
10. Right-click on the present value of that **AI 2** to raise the context menu.
11. Select **Displays** and click **Analog Input Template**.




Fig. 66 Accessing the Analog Input Template

12. Navigate to Out_of_Service property and change False to True.




Fig. 67 AI 2 Object properties

To set the Out_of_Service property for the analog outputs, locate the output terminal AO 2 in Hardware status (HW), right-click to bring up the context menu, and navigate to the analog output Template to change the property from False to True.

Out_of_Service can also be Enabled/Disabled by selecting the “Out_of_Service” checkbox on the input and output configuration screens.



NOTE:

Out_of_Service is used when there is failure in the field sensor.

Binary Outputs

These binary outputs are different in that they switch between the minimum and maximum output values – or 0. Power for BO is only supplied by the base controller’s power. Typical usage for the BOs is controlling pilot relays.

When the Universal Inputs Outputs are configured as Binary Outputs using the Hardware Mode selection box, the rest of the configuration is done in the Output Config Page.

In the Output Config Page, you can view the status of the Binary Output is Off (shown as a Zero ~ Green Animation dim) or On (shown as a One ~ Green Animation bright). Binary Outputs can be configured with Minimum Off and On times and the status of these timers is shown.



NOTE:

The Minimum ON and OFF enforcement is done at Priority 6 in the priority array for the BO. As such, the present value should reflect this as long as the present value is not being commanded at a priority higher than 6 (in which case the Min ON/OFF would NOT be enforced).

Also shown is priority array index value 8 which is commonly placed on templates for operator overrides to quickly determine if the point is in override or not.




Fig. 68 Universal I/O - Binary Output - Configuration and Scaling

Output Scaling

Identical to input scaling except rather than scaling the input value, the scaling here applies to the output values. It is a 2-point linear scale.

NETWORK TOPOLOGIES

Ring topology can be a cost-effective solution for networks required to tolerate a single cable failure. To create a ring topology, only one Ethernet Switch (with RSTP support) and n cables are needed, where n is the total number of devices in the ring (including the Ethernet Switch).

Daisy Chain topology

There are two scenarios in daisy chain network topology:

(1) Daisy Chain Topology in IP CAT5/6 Network:

In the IP CAT5/6 network daisy chain connection type, if any of the devices in the network fails, the devices beyond the failed device also fail. For example, there are 10 devices in a network, and device number 1 is the client, connected to device number 2, and device number 2 is connected to device number 3, and so on. If the device 5 fails to function, device 6, 7, 8, 9, and 10 also fails to communicate with the client device.




Fig. 69 IP CAT5/6 Daisy chain topology

(2) Daisy Chain Topology in IP T1L Network:

Daisy-chaining IP T1L Unitary controllers offer a high level of network resiliency, even in case of device failure. As an example, if one controller in the network fails, the device beyond the failed device should be able to communicate with the other functional devices. Depending on the cable type and assuming the distance between functional nodes does not exceed the maximum stated above, the maximum number of offline IP T1L devices on the bus varies between 2 and 10 for daisy-chaining to remain functional.

Assuming that for the cable type used and based on the distance between functional devices, the fail-safe daisy-chaining stops to work beyond 2 offline controllers, then the devices downstream the failed controllers will not be able to communicate. For example, there are 10 devices in a network, and device number 1 is the client, connected to device number 2, and device number 2 is connected to device number 3, and so on. If the devices 5,6,7 fails to function, then the devices 8, 9, and 10 will also fail to communicate with the client device. This is because each controller in the power fail mode shortens the two IP T1L ports to make the connection resilient. However, shorting introduces internal resistance, which introduces attenuation to the signal. Thus, consecutive device failures add attenuation to the signal, such that the controller beyond it fails to communicate.

In a daisy chain configuration, A maximum of 100 Alerton Unitary Controllers can be connected in a daisy chain configuration; However, it is recommended that the number of controllers daisy chained be limited to 25-30.




Fig. 70 IP T1L Daisy chain topology

NOTE: Do not include RSTP enabled device in a non-RSTP daisy chain network. For example, if the user is using the controller in daisy chain network where RSTP is not enabled, the user should not include RSTP enabled devices in between the daisy chain network.

Ring network topology

If the Unitary Controller is connected in a redundant ring, it requires one spanning tree protocol-supported Ethernet switch as a part of the ring. This switch will connect the Unitary Controller to the IP network. The loop-free topology ensures that there aren't any broadcast storms or duplicate frame transmissions.

The maximum number of controllers connected in the ring network topology is 39 with one switch. The switch manages the connection of the loop.

NOTE: It is recommended that the ROC update be performed on a batch size of 25 or lesser on an RSTP loop. Exceeding this limit in a single batch may cause some devices to enter NR state.

For optimal performance and bus traffic, it is recommended to limit the number of controllers to less than 39.




Fig. 71 IP CAT5/6 Ring Topology




Fig. 72 IP T1L Ring Topology

NOTE: Due to RSTP inherent nature, once the Unitary Controller reboots there is a short period of time (less than 1 min) that the network topology requires to stabilize and assign proper port roles to each bridge. This characteristic may result in requiring an additional attempt at performing the ROC upgrade in RSTP topologies. Therefore, retry updating the device whenever this occurs. An alternative solution is to disable the bridge that creates the ring topology during the upgrade of the devices; the bridge can be re-enabled once the upgrade process is completed.

IMPORTANT: Proper configuration of gateway parameters on IP devices is crucial for stable network functionality. Incorrect settings can lead to devices becoming unresponsive and disconnected from the network. When a device is placed on a network with multiple subnets, avoid setting the Gateway Method to None. If set to Manual, ensure the gateway's IP matches your network's gateway.

RSTP

Introduction

Rapid spanning Tree Protocol (RSTP) is a link layer network protocol that prevents bridge loops and flooding in local networks with redundant connections. To ensure a loop-free topology, RSTP disables some connections leaving a single active path between any two devices. These disabled connections can be used as a backup path in case of active connection failure. The former STP protocol has been superseded by RSTP – Rapid Spanning Tree Protocol, which can respond to topology changes faster than STP.

RSTP works by first nominating a single device to be the Root Bridge. The nominated Root Bridge device acts as an anchor point for the system. It gives all other bridges a reference point for choosing the best path to open and connect for routing. Bridge Protocol Data Units (or BPDUs), are passed between bridge ports to communicate Root Bridge and local port information. BPDUs are key to managing the RSTP network as they are used to assign the Port Roles of all the ports on the Bridge devices. The RSTP resides on layer 2 (data link) of the OSI 7-layer model.



CAUTION

When adding Unitary Controllers with RSTP turned on, ensure that the entire network runs RSTP. Please note that if any link in the existing network runs just STP, then RSTP functions as STP on that single link. RSTP is backward compatible with STP; however, If there exists just a single link running STP, then the advantage of “rapid convergence” offered by RSTP is lost, and the network will take longer to converge (possibly up to 50 seconds) whenever there is a change in network topology. The best choice is always to segregate different protocols.

Only enable RSTP in the Unitary controllers if there are redundant paths in the network. This has an impact on firmware download situations. When RSTP is enabled, all the switch ports are turned off when the Unitary Controller reboots. This will result in a temporary loss of connectivity when there are no redundant links in the network.

To ensure that the RSTP protocol functions correctly within each network, RSTP must be turned ON for all Unitary Controllers.

RSTP Scenario




Fig. 73 RSTP Scenario

In the above scenario, the lines represent additional connections that facilitate an alternative path (loop) for the Unitary Controllers labeled A through D. For example, if a device Alerton Unitary Controller A fails, then it will check for the closest controller as a second NIC in the Workstation; in addition, the connection between other two controllers will establish a new path for the controllers on the bottom row. By adding a second NIC to the Workstation, the Unitary Controller provides an alternative route if Alerton Unitary Controller A fails; without this connection, Unitary Controller a would be a risk. This simple network provides each controller with two different paths to the Workstation.

Root Bridge Features

1. Only one Root Bridge per network.
2. Automatically assigned to the device that has the lowest Bridge ID.
3. Bridge ID = Bridge Priority and MAC address (note the MAC address is used in the event of tied Bridge Priorities).
4. Bridge Priority is a configurable property, the default value is 49152 and is adjusted in increments of 4096.
5. MAC address is the NICs non-configurable MAC address.

Root Bridge Selection

There are both advantages and disadvantages if the Root Bridge is selected automatically. But, careful consideration must be taken when deciding which Ethernet Switch or Unitary Controller is the nominated device to take on this responsibility. The risk of allowing the devices to select the Root Bridge automatically is the potential for the Root Bridge to get assigned to a device that may need to be in the most logical location on the network. Making the switch or Unitary Controller closest to the Core Network connection, the Root Bridge would make the most sense. In addition, consider system redundancy and which device would be the most sensible backup in case the Root Bridge lost power; the whole point of RSTP is to facilitate redundancy.

Root Bridge Example 1

In this example, Unitary Controller A takes on the responsibility of being the Root Bridge due to having a lower Root Priority (28672).




Fig. 74 Root Bridge Example 1

Root Bridge Example 2

In this example, Unitary Controller B takes on the responsibility of the Root Bridge. With the Root Priority values equal, it compares MAC addresses and nominates the device with the lowest MAC address. This example highlights the impracticality of allowing the Unitary Controllers to negotiate amongst themselves which device is the Root Bridge.




Fig. 75 Root Bridge Example 2

Port Roles

Once the Root Bridge device is determined, the selected device will set its ports to the Designated Port Role. Designated Ports will generate and receive Bridge Protocol Data Unit (BPDU) messages. BPDU messages are essential to all devices that make up the RSTP network. BPDU messages contain the Root Bridge device Bridge ID and a Cost to Path parameter that accumulates the further a device is from the Root Bridge. BPDU message generation is repetitive and created within 2 seconds of each other. When receiving the BPDU messages, the Non-Root Bridge devices will assign the Root Port role to the port closest to the Root Bridge device; this is determined by comparing the Cost to Path values on each connected port. In the root bridge example 2, if the Unitary Controller B is declared the Root Bridge, its two populated ports default to Designated Ports. Via BPDU message, the Unitary controllers A and C will assign Root Port (RP) roles to the ports directly connected to Unitary Controller B. The remaining ports will default to the Designated Port (DP) role and generate their own BPDU messages. Unitary Controller D will compare the BPDU messages received on both ports to determine the most efficient path to the Root Bridge. Unitary Controller D could have a tied Cost to Path score for either of their ports as both have a valid path to the Root Bridge across an equal number of segments. If a Cost to Path is tied, the lowest Bridge ID will be nominated as the Root Port.

Port Status

The Port Status provides feedback on what condition the port is. Ports will be in one of three states:

1. **Learning:** Port is mapping but not sending data yet.
2. **Forwarding:** Port is functioning correctly and sending data.
3. **Discarding:** Port is not sending data, typically indicating that a loop has been detected and the Port Role is set to Alternative Port.

RSTP Configuration




Fig. 76 RSTP Enable/Disable and set Bridge priority

The Ethernet and IP configuration contains:

4. Enable Rapid Spanning Tree Protocol.
5. RSTP Bridge Priority, select the Bridge Priority from the drop-down (values 0...61440), the Bridge Priority values are set in blocks of 4096.

Table 33 RSTP Configuration

Menu	Values	Description	Default
Enable/ Disable Rapid Spanning Tree Protocol	Enable / Disable	Enable / Disable RSTP	Disable
Bridge Priority	0...61440	Controls which VLC node / Managed switch is the root bridge. The Bridge Priority is set in increments of 4096 between the ranges of 0 to 61440 (For example 4096, 8192, 12288...)	49152

RSTP Diagnostics

The AV's 170000 to 170099 are reserved for RSTP Diagnostics regardless of whether RSTP has been enabled or not. Allocated Diagnostic AV's for the Unitary Controller are:

AVs	Description
AV 170000	Spanning Tree type. RSTP is supported by VLC. Displays "RSTP" when enabled and displays "None" when RSTP is disabled.
AV 170001	Bridge ID – Shows the Bridge priority followed by the MAC ID of the node. Example: 49152-00:60:2D:08:00:67
AV 170002	Bridge Priority – Priority of the Bridge. Lower values result in the node being elected Root Bridge
AV 170003	Root Bridge ID – Bridge priority followed by the MAC ID of the Root Bridge of the entire network.
AV 170004	Hello Time – Maximum time in seconds between consecutive BPDU messages (also called the heartbeat time). BPDU messages may come in faster during network Syncing. Hello time is always 2 seconds.
AV 170005	Max Age – Max age of IP VLC devices are dynamic and can be auto configured to root bridge's Max age setting.
AV 170006	Forward Delay – Forward delay of IP VLC devices are dynamic and can be auto configured to root bridge's forward delay setting.
AV 170007	Number of Days, Hours, Minutes, and Seconds since the last Topology Change in the network. Topology change happens when non-Edge ports move to a forwarding state.



NOTE:

Max age and Forward delay fields of VLC devices are dynamic and auto configures to root bridge's Max age and Forward delay setting.

For setups exceeding 20 devices in RSTP, users must configure the MaxAge and Forward-Delay as 40 and 21, respectively, on the root device. These settings will dynamically propagate to all connected VLC devices. If a VIP device is designated as the root device, it's advisable to limit connections to fewer than 20 devices to avoid conflicts with the default RSTP values configured in the VIP device, which could lead to connectivity issues.

Information for each port is represented in AVs and BVs:

AVs	Description
AV 170100	Spanning tree mode that the link works in. This can be "None" when RSTP is disabled or link is down "RSTP" when RSTP is enabled and the node connected is using RSTP or "STP" when RSTP is enabled and the node connected is using STP.
AV 170101	Adapter. Always eth0.
AV 170102	Port RSTP Role – Role that the port is playing in the Rapid Spanning Tree network. "Disabled" – Port is disabled. "Root" – Port leads to the "Root Bridge". "Designated" – Port connects other nodes to Root Bridge. "Alternate" – Port discarding traffic. "N/A" – Link is down.
AV 170103	Port RSTP status – Status of the port. "Learning" – Port is learning MAC address, but not forwarding traffic. "Discarding" – Port is discarding traffic as there is a loop in the network. "Forwarding" – Port is sending and receiving traffic. "N/A" – Link is down.

AVs	Description
AV 170104	Neighbor Bridge ID – The Bridge ID that this port is connected to. “N/A” – Link is down “Bridge ID” – The bridge ID of the neighbor sending traffic to this port is displayed. “Edge” – Neighbor is not participating in the RSTP network.

BVs	Description
AV 170200	Spanning tree mode that the link works in. This can be “None” when RSTP is disabled or link is down “RSTP” when RSTP is enabled and the node connected is using RSTP or “STP” when RSTP is enabled and the node connected is using STP.
AV 170201	Adapter. Always eth0.
AV 170202	Port RSTP Role – Role that the port is playing in the Rapid Spanning Tree network. “Disabled” – Port is disabled. “Root” – Port leads to the “Root Bridge”. “Designated” – Port connects other nodes to Root Bridge. “Alternate” – Port discarding traffic. “N/A” – Link is down.
AV 170203	Port RSTP status – Status of the port. “Learning” – Port is learning MAC address, but not forwarding traffic. “Discarding” – Port is discarding traffic as there is a loop in the network. “Forwarding” – Port is sending and receiving traffic. “N/A” – Link is down.
AV 170204	Neighbor Bridge ID – The Bridge ID that this port is connected to. “N/A” – Link is down “Bridge ID” – The bridge ID of the neighbor sending traffic to this port is displayed. “Edge” – Neighbor is not participating in the RSTP network.
BV 170100	Ethernet Link

Device Templates and Graphics can be used to display Diagnostic AV data to assist with troubleshooting or managing the RSTP network. When RSTP is disabled the STP Type shows “None” which indicates that RSTP has been disabled in the Device Configuration.

Troubleshooting RSTP

If it is determined that some Unitary controllers are responding very slowly or not at all, check the steps listed below:

1. Check that all Unitary Controllers and other switches on the network have RSTP enabled. If using Diagnostic graphics (AV-170000) for each Unitary Controller the “Spanning Tree Type” should display “RSTP” if RSTP is enabled.
2. If any managed switch is used ensure that “RSTP” is enabled.
3. Verify that all the Unitary Controllers have the same Root Bridge ID (AV-170001).
4. Use AV-170007 to check the time elapsed since the last Topology change, use this as an indicator to see how frequently the RSTP structure is changing. This indicates how long the network has been stable.

Tested Network Switches

RSTP network testing has been performed with the following managed switches:

- Cisco: 500 Series
- D-Link: DGS-1010-28
- Netgear: GS108Tv2 and GS418TPP

OBJECTS AND PROPERTY REFERENCES

Objects in the VLC8u8 Unitary Controllers

Object (Instance Range)	Function
AI (0)	Analog input corresponding to physical UIO input IO0 (MSET Physical Input)
AI-1...8	Analog inputs corresponding to physical UIO inputs IO1 through IO8
AO-1...8	Analog outputs corresponding to physical UIO outputs IO1 through IO8
BI-1...8	Binary inputs corresponding to physical UIO inputs IO1 through IO8
BO-1...8	Binary outputs corresponding to physical UIO outputs IO1 through IO8
BO-21...24	Binary outputs corresponding to physical SPDT outputs DO1 through DO4
BO-31...34	Binary outputs corresponding to physical SSR outputs SR1 through SR4
AV-0...89	General Purpose DDC
AV-90...110	Microset DDC – supports Microset, Microset-II, and Microset 4
AV-130...169	General Purpose DDC – without priority array
AV-170-177	General Purpose DDC – WITH priority array
BV-0...63	General Purpose DDC
BV-64...87	Microset DDC – supports Microset, Microset-II, and Microset 4
BV-99	Disables 0.5°F deadband between AV-95 & AV-96 (ON = AV-96 can equal AV-95)
BV-101	Enable/Disable Bluetooth (Active = Bluetooth Enabled, Inactive = Bluetooth Disabled)
BV-130...177	General Purpose DDC – without priority array
BV-178...193	General Purpose DDC – WITH priority array
MV-0...10	General Purpose DDC
MV-70	Microset/Microtouch Detect Mode
MV-71	Device English/Metric
MV-101...108	UIO-1...8 Hardware Input Mode Selection
MV-201...208	AI-1...8 Data Presentation Mode
AV-301...308	AI-1...8 Input Scaling X1
AV-351...358	AI-1...8 Input Scaling X2
AV-401...408	AI-1...8 Input Scaling Y1
AV-451...458	AI-1...8 Input Scaling Y2
AV-501...508	AI-1...8 Pulse Value
AV-531...538	AI-1...8 Pulse Value (Time Base)
AV-561...568	AI-1...8 Pulse Value (Pulse Count)
AV-601...608	AO-1...8 Output Scaling X1
AV-651...658	AO-1...8 Output Scaling X2
AV-701...708	AO-1...8 Output Scaling Y1
AV-751...758	AO-1...8 Output Scaling Y2
AV-800...899	Reserved for Modbus Integration

Object (Instance Range)	Function
BV-800...899	Reserved for Modbus Integration
MV-800...809	Reserved for Modbus Integration
Calendar	Describes a list of calendar dates, special event dates, holiday dates, and date ranges.
Device	Provides general information about a device.
Event Enrollment ⁽¹⁾	Defines an event and connects the occurrence of the event to the transmission of an event notification. Primarily used for alarms in Compass 2.2.0
File (0)	Provides information about the real-time operating code (ROC) file.
File (1024)	Provides information about the current DDC file.
File (2048)	Provides information about the DDC trap file.
Notification Class	Stores a list of available recipients for the distribution of event notifications (alarms, trend-log gathering).
Program 0	Stores information about the ROC/controller program.
Program 1024	Stores program status information about the current DDC program.
Schedule ⁽¹⁾	Controls designated properties by periodic schedule that may recur during a range of dates.
Zones ⁽¹⁾	Proprietary Alerton object containing the individual properties and references required to support the optimum start and tenant activity features of Compass 2.2.0
Trendlogs ⁽¹⁾	BACnet Trendlog objects.

Objects in the VLC16u8 Unitary Controllers

Object (Instance Range)	Function
AI-0	Analog input corresponding to physical UIO input IO0 (MSET Physical Input)
AI-1...16	Analog inputs corresponding to physical UIO inputs IO1 through IO16
AO-1...16	Analog outputs corresponding to physical UIO outputs IO1 through IO16
BI-1...16	Binary inputs corresponding to physical UIO inputs IO1 through IO16
BO-1...16	Binary outputs corresponding to physical UIO outputs IO1 through IO16
BO-21...24	Binary outputs corresponding to physical SPDT outputs DO1 through DO4
BO-31...34	Binary outputs corresponding to physical SSR outputs SR1 through SR4
AV-0...89	General Purpose DDC
AV-90...110	Microset DDC – supports Microset, Microset-II, and Microset 4
AV-130...169	General Purpose DDC – without priority array
AV-170-177	General Purpose DDC – WITH priority array
BV-0...63	General Purpose DDC
BV-64...87	Microset DDC – supports Microset, Microset-II, and Microset 4
BV-99	Disables 0.5°F deadband between AV-95 & AV-96 (ON = AV-96 can equal AV-95)
BV-101	Enable/Disable Bluetooth (Active = Bluetooth Enabled, Inactive = Bluetooth Disabled)
BV-130...177	General Purpose DDC – without priority array
BV-178...193	General Purpose DDC – with priority array
MV-0...10	General Purpose DDC
MV-70	Microset/Microtouch Detect Mode
MV-71	Device Units Selection (English / Metrics)
MV-101...116	UIO-1...16 Hardware Input Mode Selection
MV-201...216	AI-1...16 Data Presentation Mode
AV-301...316	AI-1...16 Input Scaling X1
AV-351...366	AI-1...16 Input Scaling X2
AV-401...416	AI-1...16 Input Scaling Y1
AV-451...466	AI-1...16 Input Scaling Y2
AV-501...516	AI-1...16 Pulse Value
AV-531...546	AI-1...16 Pulse Value (Time Base)
AV-561...576	AI-1...16 Pulse Value (Pulse Count)
AV-601...616	AO-1...16 Output Scaling X1
AV-651...666	AO-1...16 Output Scaling X2
AV-701...716	AO-1...16 Output Scaling Y1
AV-751...766	AO-1...16 Output Scaling Y2
AV-800...899	Reserved for Modbus Integration
BV-800...899	Reserved for Modbus Integration
MV-800...809	Reserved for Modbus Integration
Calendar	Describes a list of calendar dates, special event dates, holiday dates, and date ranges.

Object (Instance Range)	Function
Device	Provides general information about a device.
Event Enrollment ⁽¹⁾	Defines an event and connects the occurrence of the event to the transmission of an event notification. Primarily used for alarms in Compass 2.2.0
File (0)	Provides information about the real-time operating code (ROC) file.
File (1024)	Provides information about the current DDC file.
File (2048)	Provides information about the DDC trap file.
Notification Class	Stores a list of available recipients for the distribution of event notifications (alarms, trend-log gathering).
Program 0	Stores information about the ROC/controller program.
Program 1024	Stores program status information about the current DDC program.
Schedule ⁽¹⁾	Controls designated properties by periodic schedule that may recur during a range of dates.
Zones ⁽¹⁾	Proprietary Alerton object containing the individual properties and references required to support the optimum start and tenant activity features of Compass 2.2.0
Trendlogs ⁽¹⁾	BACnet Trendlog objects.

(1) Event Enrollment (Alarms), Schedule, Zones, and Trendlogs support only internal points. External points cannot be referenced.


NOTE:

It is not recommended to modify or add additional devices zone schedules under the Unitary Controller.


NOTE:

If multiple notifications occur within a 1-second time frame, some COV notifications will be missed. Nevertheless, the DDC Engine will execute the DDC Logic within a time frame of 500 milliseconds which involves reading physical inputs (AI, BI, AO, BO, MV), processing the code, and writing to the outputs (AV, AO, BV, BO, MV). During point data save operation, the user has to select "VLC calibration factors, box sizes, zero cutoffs" field in order to get proper commissioning report. Point data write operation for VLC parameters using "VLC calibration factors, box sizes, zero cutoffs" field will be ignored and will not update. Instead "Present values, priority arrays, relinquish defaults" field helps in writing VLC parameters.

AV-105 Microtouch lever value should always be set to zero until user has configured and connected Microtouch.

Properties of VLC AI Objects

Property	W	Type	Example	Remarks
Description	Yes	Character string		Initially set to something like "AI n. "Example: Occupied Set Point
Object- Identifier		BACnet® Object Identifier		This property consists of the object- type property and the object instance, which is a numeric code that identifies the object of interest. Example: AI 1.
Object- Name	Yes	Character string		Initially set to "AI n" CANNOT BE SET BLANK. Example: AI 1
COV-Increment	Yes	Real	0	If the present value changes by this amount or greater, then a change-of- value notification is sent to sub- scribed devices.
Present- Value	Yes	Real		The range is 3×10^{38} (six significant digits of resolution) Example: 76.4
Units	Yes	Enumerated	no-units	Indicates the unit of measure, in BACnet® engineering units, that the AI is expressed in. Example: Deg F

Status Properties	W	Type	Default Value	Remarks
Event-State		Enumerated	"normal"	
Out-Of- Service	Yes	Boolean	FALSE	De-couples the Physical Input from the Logical Input, allowing the user to write to the present-value and reliability properties for Testing or Override.
Status-Flags		Bit string		A four-position bit string that indicates the status of the AI. If status bit=1, then the status is TRUE.

Properties of VLC AO Objects

Property	W	Type	Example	Remarks
Object- Identifier		BACnet® Object Identifier	AO n	This property consists of the object-type property and the object instance, which is a numeric code that identifies the object of interest.
Object- Name	Yes	Character string	AO n	CANNOT BE SET BLANK. Example: HGT CMD.
Object- Type		Enumerated	AO	
Present- Value	Yes	Real		Example: 76.4%
Description	Yes	Character string	AO n	Example: Heating Valve Command.
Status- Flags		Bit string		A four-position bit string that indicates the status of the AO. If status bit=1, then the status is TRUE.
Event- State		Enumerated	"normal"	
Reliability	[Yes]	BACnet® Reliability		Normally is Read-Only and reports "no fault detected". Gets set to "Open Loop" (and is writable), when Out-of-Service is set to TRUE.
Out-Of- Service	Yes	Boolean	FALSE	Decouples the Physical Output from the Logical Output, allowing the user to Test the AO control logic without affecting the physical Output.

Property	W	Type	Example	Remarks
Units	Yes	Enumerated	no units	Indicates the unit of measure, in BACnet® engineering units, that the AO is expressed in. Example: Volts.
Priority- Array	Yes	BACnet® Priority Array	all null	16 index prioritized array of AO Commands.
Relinquish-Default	Yes	Real	0.0	Value of the AO Present-Value when the Priority-Array is all NULL.
Reliability-Evaluation- Inhibit	Yes		FALSE	Disables the Reliability reporting when set to OFF.
Property- List				List of all supported properties of an Object (except Object- Identifier, Object-Name, Object-Type, and Property-List, which are always required for ALL BACnet® Objects).
Alert-Interface-Value				Value of Physical AO.

Properties of VLC AV Objects

Property	W	Type	Example	Remarks
Description	Yes	Character string		Initially set to "AV n". Example: Occupied Set Point.
Object- Identifier		BACnet® Object Identifier		This property consists of the object-type property and the object instance, which is a numeric code that identifies the object of interest. Example: AV 1.
Object- Name	Yes	Character string		Initially set to something like "AV n" CANNOT BE SET BLANK. Example: AV 001.
Object- Type		Enumerated	AV	Example: AV.
Property- List				

Core Properties	Write	Type	Default Value	Notes
COV-Increment	Yes	Real	0	If the present value changes by this amount or greater, then a change-of-value notification is sent to subscribed devices.
Present- Value	Yes	Real	0	The range is 3×1038 (six significant digits of resolution) Example: 76.4
Priority- Array	Yes	BACnet® Priority Array	all null	Only present on user AVs with priority array (AV 170..177).
Relinquish-Default	Yes	Real	0	Only present on user AVs with priority array (AV 170..177).
Units	Yes	Enumerated	no-units	Indicates the unit of measure, in BACnet® engineering units, that the AV is expressed in. Example: Deg F.

Status Properties	Write	Type	Default Value	Remarks
Event-State		Enumerated		
Status-Flags		Bit String		A four-position bit string that indicates the status of the AV. If status bit=1, that status is TRUE.

Properties of Microset VLC AV Objects

Property	W	Type	Example	Remarks
Description	Yes	Character string		These are initially set (upon reset to factory defaults) to the default values shown in the section on Microset point allocations but can be changed to other values thereafter. Example: Occupied Set Point.
Object- Identifier		BACnet® Object Identifier		This property consists of the object-type property and the object instance, which is a numeric code that identifies the object of interest. Example: AV 1.
Object- Name	Yes	Character string		These are initially set (upon reset to factory defaults) to the default values shown in the section on Microset point allocations but can be changed to other values thereafter, CAN NOT BE SET TO BLANK. Example: AV 1.
Object- Type		Enumerated	AV	Example: AV
Property- List				

Core Properties	Write	Type	Default Value	Notes
COV-Increment	Yes	Real	0.0	If the present value changes by this amount or greater, then a change-of-value notification is sent to subscribed devices.
Present- Value	Yes	Real		The range is 3 x 1038 (six significant digits of resolution) Example: 76.4
Units	Yes	Enumerated		Indicates the unit of measure, in BACnet® engineering units, that the AV is expressed in. Example: Deg F.

Status Properties	Write	Type	Default Value	Remarks
Event-State		Enumerated		
Status-Flags		Bit String		A four-position bit string that indicates the status of the AV. If status bit=1, that status is TRUE.

Properties of VLC BI Objects

Property	W	Type	Example	Remarks
Object- Identifier		BACnet® Object Identifier	BI n	This property consists of the object-type property and the object instance, which is a numeric code that identifies the object of interest.
Object- Identifier		BACnet® Object Identifier	BI n	This property consists of the object-type property and the object instance, which is a numeric code that identifies the object of interest.
Object- Name	Yes	Character string	BI n	CANNOT BE SET BLANK. Example: Exh Fan.
Object- Type		BACnet® Object Type	BI	Example: BI
Present- Value	[Yes]	BACnet® Binary BV		Example: Active.
Description	Yes	Character string	BI n	Example: Exhaust Fan Status.
Status-Flags		Bit string		A four-position bit string that indicates the status of the BI. If status bit=1, then the status is TRUE.
Event-State		Enumerated	“normal”	
Reliability	[Yes]	BACnet® Reliability		Normally is Read-Only and reports “no fault detected”. Gets set to “Open Loop” (and is writable), when Out-of-Service is set to TRUE.
Out-Of- Service	Yes	Boolean	FALSE	Decouples the Physical Input from the Logical Input, allowing the user to write to the present-value and reliability properties for Testing or Override.
Polarity		BACnet® Polarity	“normal”	Indicates the polarity of the BI (normal or reversed).
Inactive- Text	Yes	Character string		Specifies Text that can be used when BI is Inactive.
Active-Text	Yes	Character string		Specifies Text that can be used when BI is Inactive.
Change-Of- State-Time		BACnet® Date Time		Indicates the Time of the last State Change.
Change-Of- State-Count	Yes	Unsigned		Indicates the total number of State Changes (can be reset to 0).
Time-Of- State-Count- Reset		BACnet® Date Time		Indicates the time of the last State Count reset.
Elapsed-Active-Time	Yes	Unsigned32		Indicates the total Elapsed Active Time in seconds (can be reset to 0).
Time-Of- Active-Time-Reset		BACnet® Date Time		Indicates the time of the last Elapsed Active Time reset.
Reliability-Evaluation- Inhibit	Yes	Boolean	FALSE	Does nothing for BI.
Property- List				List of all supported properties of an Object (except Object- Identifier, Object-Name, Object-Type, and Property-List, which are always required for ALL BACnet® Objects).

Properties of VLC BO Objects

Property	W	Type	Example	Remarks
Object- Identifier		BACnet® Object Identifier	BO n	This property consists of the object-type property and the object instance, which is a numeric code that identifies the object of interest.
Object- Name	Yes	Character string	BO n	CANNOT BE SET BLANK. Example: Exh Fan.
Object- Type		BACnet® Object Type	BO	
Present- Value	Yes	BACnet® Binary BV		Example: Active.
Description	Yes	Character string	BO n	Example: Circulation Pump Command.
Status-Flags		Bit string		A four-position bit string that indicates the status of the BO. If status bit=1, then the status is TRUE.
Event-State		Enumerated	“normal”	
Reliability	Yes	BACnet® Reliability		Normally is Read-Only and reports “no fault detected”. Gets set to “Open Loop” (and is writable), when Out-of-Service is set to TRUE.
Out-Of- Service	Yes	Boolean	FALSE	Decouples the Physical Input from the Logical Input, allowing the user to write to the present-value and reliability properties for Testing or Override.
Polarity		BACnet® Polarity	“normal”	Indicates the polarity of the BO (normal or reversed).
Inactive- Text	Yes	Character string		Specifies Text that can be used when BO is Inactive.
Active-Text	Yes	Character string		Specifies Text that can be used when BO is Inactive.
Change-Of- State-Time		BACnet® Date Time		Indicates the Time of the last State Change.
Change-Of- State-Count	Yes	Unsigned		Indicates the total number of State Changes (can be reset to 0).
Time-Of- State-Count- Reset		BACnet® Date Time		Indicates the time of the last State Count reset.
Elapsed-Active-Time	Yes	Unsigned32		Indicates the total Elapsed Active Time in seconds (can be reset to 0).
Time-Of- Active-Time-Reset		BACnet® Date Time		Indicates the time of the last Elapsed Active Time reset.
Minimum- Off-Time	Yes	Unsigned32	0	Specifies the Minimum Time the BO will be held OFF when transitioning from ON to OFF (minimum Time Enforced at Priority 6 in priority-array).
Minimum- On-Time	Yes	Unsigned32	0	Specifies the Minimum Time the BO will be held ON when transitioning from OFF to ON (minimum Time Enforced at Priority 6 in priority-array).
Priority- Array	Yes	BACnet® Priority Array	all null	16 index prioritized array of BO Commands.
Relinquish-Default	Yes	BACnet® Binary BV	Inactive	Value of the BO Present-Value when the Priority-Array is all NULL.
Reliability-Evaluation-	Yes	Boolean	FALSE	Disables the Reliability reporting when set to OFF.

Property	W	Type	Example	Remarks
Property- List				List of all supported properties of an Object (except Object- Identifier, Object-Name, Object-Type and Property-List, which are always required for ALL BACnet® Objects).
Aler-Inter- face- Value		BACnet® Binary BV		Value of Physical BO.

Properties of VLC BV Objects

Property	W	Type	Example	Remarks
Description	Yes	Character string	BV n	Initially set to "BV n".
Object- Identifier		BACnet® Object Identifier		This property consists of the object-type property and the object instance, which is a numeric code that identifies the object of interest. Example: BV 1.
Object- Name	Yes	Character string	BV n	Initially set to "BV n".
Present-Value	Yes	Enumerated	Inactive	
Priority- Array	Yes	BACnet® Priority Array	all null	Only present on user BV with priority array (BV 40 and BV 178..193).
Relinquish- Default	Yes	REAL	Inactive	Only present on user BV with priority array (BV 40 and BV 178..193).

Status Property	Write	Type	Default Value	Remarks
Event-State		Enumerated		Example: Normal
Status-Flags		Bit String		A four-position bit string that indicates the status of the object. If status bit=1, that status is TRUE. Example: In Alarm=0, Fault=0, Overridden=0, Out of Service=0

Property	W	Type	Example	Remarks
Change-Of- State-Count	Yes			Indicates the total number of State Changes (can be reset to 0).
Change-Of- State-Time				Indicates the Time of last State Change.
Elapsed-Active-Time	Yes			Indicates the total Elapsed Active Time in seconds (can be reset to 0).
Time-Of- Active- Time-Reset				Indicates the time of the last Elapsed Active Time reset.
Time-Of- State- Count- Reset				Indicates the time of the last State Count reset.

Properties of Microset VLC BV Objects

Property	W	Type	Example	Remarks
Description	Yes	Character string		These are initially set (upon reset to factory defaults) to the default values shown in the section on Microset point allocations but can be changed to other values thereafter.
Object- Identifier		BACnet® Object Identifier		
Object- Name	Yes	Character string		These are initially set (upon reset to factory defaults) to the default values shown in the section on Microset point allocations but can be changed to other values thereafter. CAN- NOT BE BLANK.
Object- Type		Enumerated	BV	
Property- List				

Core Properties	Write	Type	Default Value	Remarks
Present-Value	Yes	Enumerated	Inactive	

Status Property	Write	Type	Default Value	Remarks
Event-State		Enumerated		
Status-Flags		Bit String		A four-position bit string that indicates the status of the object. If status bit=1, that status is TRUE. Example: In Alarm=0, Fault=0, Overridden=0, Out of Service=0

Properties of the VLC Device Objects

Property	W	Type	Example	Remarks
apdu-segment-timeout	Yes	Unsigned	6000	The time after transmission of a “segment” until the lack of a reply means it was assumed to be lost (in milliseconds, 1000 = 1 sec). Default = 6000.
apdu- timeout	Y	Unsigned	6000	The time after transmission of an APDU until the lack of a reply means it was assumed to be lost. The APDU time-out value for this device in milliseconds (1000 = 1 sec). Default = 6000.
application-software- version		Character string	1.0.0	Indicates the ROC file version.
daylight- savings-status	Y	Boolean	FALSE	Indicates whether daylight savings is in effect (TRUE) or not (FALSE). Not used at present.
description	Y	Character string	Second floor controller	Assigned by the user to de- scribe the device’s function.

Property	W	Type	Example	Remarks
device-address-binding		List		Empty.
firmware- revision		Character string	1.0.0	Indicates the VLC boot code Version.
local-date	Y	Date	Sunday, 02/24/ 2002	Indicates date: day of the week, month/day/year. Writable through Time Sync.
local-time	Y	Time	10:15:56.00 am	Indicates the time stored in the device. Writable through Time Sync.
location	Y	Character string	East Wing	Indicates the physical location of the device.
max-apdu- length-accepted		Unsigned	1476	The maximum message packet size that the device can handle.
model- name		Character string	To be added	Assigned by the vendor to indicate the device model.
number-of- apdu-retries	Y	Unsigned	3	The number of times a message is resent after it is assumed to be lost.
object- identifier		BACnet® Object_Identifier	Device 4194303	This property consists of the object-type property and the device instance, which is a numeric code that identifies the device of interest.
object-list		Array		An array whose elements list the object-identifier properties of all objects the device supports.
object- name		Character string	Device 4194303	No two devices are permitted to have the same object name.
object-type		Enumerated	Device	
protocol- object-types-supported		Bit string	<Bit string>	An internally used bit string. Indicates which BACnet® object types reside in the device.
protocol- services-supported		Bit string	<Bit string>	An internally used bit string. Indicates which BACnet® services the device can process.
protocol- version		Unsigned	18	Indicates the version of the BACnet® protocol supported by the device.
segmentation-supported		Enumerated	segmented both	Device is capable of segmenting both transmission and reply messages.
system- status		Enumerated	Operational	Other possible values are operational - read-only, download-required, download-in-progress, non-operational.
utc-offset	Y	Signed	0	Coordinated Universal Time offset, in minutes. Not used at present.
vendor- identifier		Unsigned	18	A unique code assigned by ASHRAE to the manufacturer, in this case, Alerton.
vendor- name		Character string	Alerton	Indicates the device manufacturer.

Properties of VLC Event - Enrollment Objects

Property	W	Type	Example	Remarks
acked- transitions	Y	bit string	To-offnormal=1, To-fault=1, To -normal=1	Indicates whether the corresponding transitions have been acknowledged. A 1 indicates that the transition was acknowledged.
description	Y	Character string	Event enrollment 0	A description assigned to describe the object's function.
event- enable	Y	bit string	To-offnormal=1 , To-fault=1, To- normal=1	Indicates whether notifications are enabled for these event transition types. A 1 indicates that the transition is reported. Set in the Event Enrollment Editor at the operator workstation.
event- parameters		BACnet® Event Parameter	change_of_ bitstring	
event-state		Enumerated	NORMAL	Indicates the current state of the event.
event-type	Y	Enumerated	CHANGE_OF_ BITSTRING	Indicates the type of event algorithm to be used to detect events.
notification-class		Enumerated	1	Indicates the notification class to be used for event transitions. Set in the Event Enrollment Editor at the operator workstation.
notify-type		Unsigned	alarm	Indicates whether the object is set up for alarms or events.
object- identifier		BACnet_Ob- ject_Identifier	Event-enrollment 0	Consists of the object-type property and the object in- stance, which is a numeric code that identifies the object of interest.
object- name		Character string	Alarm	Assigned at the operator workstation.
object- property- reference	Y	Boolean	FALSE	Indicates whether the file has been saved for backup.
object-type		Event enrollment		

Properties of VLC File Objects

Property	W	Type	Example	Remarks
archive	Y	Boolean	FALSE	Indicates whether the file has been saved for backup.
description	Y	Character string	ROC File	A description assigned to describe the object's function.
file-access- method		Enumerated	stream access	
file-size		Unsigned	983040	The of the file, in bytes.
file-type		Character string	ROC	Also, DDC or TRAP.
modification-date		Time	4/29/2020 10:22:20:00a	The data and time the file was last modified.
object- identifier		BACnet_Ob- ject_Identifier	file 0	This property consists of the object-type property and the object instance, which is a numeric code that identifies the object of interest.

Property	W	Type	Example	Remarks
object- name		Character string	File 0	
object-type		Enumerated	file	
read-only		Boolean	TRUE	Indicates whether the file can be written to by BACnet® services.

Properties of VLC Notification-Class Objects

Property	W	Type	Example	Remarks
ack- required	Y	Bit string	To offnormal=1, to fault=1, to normal=1	Indicates whether an acknowledgment is required for event transitions. A 1 indicates that acknowledgment is required. Set up at the operator workstation.
description	Y	Character string	Alarm Handler	An editable description of the object's location and function.
object- identifier	Y	BACnet_Object_Identifier	Notification- class 1	This property consists of the object-type property and the object instance, which is a numeric code that identifies the object of interest.
object- name	Y	Character string	Alarm Handler 1	
object-type	Y	Enumerated	Notification- class	
recipient- list	Y	List	<List of BACnet Destination>	Lists the devices that receive notification when the notification class transitions. Set up at the operator workstation.
priority	Y	Array of Unsigned		Indicates the priority to be used for event notifications for TO-OFFNORMAL, TO-FAULT, and TO-NORMAL events, respectively.

Properties of VLC Program Objects

Property	W	Type	Example	Remarks
description	Y	Character string	Occupied Setpoint	A description assigned to describe the object's function.
description- of-halt		Character string	Program halted by request	
instance-of		Character string	MYREP MYJOB Sun- rise901*000000 *	Header information for the file. Program 0 does not support this property.
object- identifier		BACnet_ Object_Identifier	program 1024	This property consists of the object-type property and the object instance, which is a numeric code that identifies the object of interest.
object- name		Character string	Program Object 1024	
object-type		Enumerated	Program	
out-of- service		Boolean	FALSE	
program- change	Y	Enumerated	READY	Used to command the program state. A program can be stopped using the HALT command, for example, and started again with RESTART.
program- location		Character string	DDC Sequence= 60	Set when program stops.
program- state		Enumerated	RUNNING	Possible states include RUNNING, IDLE, HALTED.
reason-for- halt		Enumerated	PROGRAM	
status-flag		Bit string	In alarm=0, fault=0, overridden=0, out of service=0	A four-position bit string that indicates the status of the object. If a status bit =1, that status is TRUE.

Properties of VLC Scheduled Objects

Property	W	Type	Example	Remarks
description	Y	Character string	Weekend Gym	A description assigned to describe the object's function.
effective- period	Y	Sequence	<BACnet Date Range>	Assigned in schedule setup at the operator workstation.
exception- schedule	Y	Sequence	<Array of BAC- net Special Event>	Assigned in schedule setup at the operator workstation.
list-of- property- references	Y	List	<List of BACnet Object Property Reference>	The list of objects that this schedule commands.
object- identifier		BACnet Object Identifier	schedule 0	This property consists of the object-type property and the object instance, which is a numeric code that identifies the object of the interest.
object- name	Y	Character string	schedule 000	Assigned in schedule setup at the operator workstation.
object-type	Y	Enumerated	schedule	
present- value	Y		ACTIVE	Indicates the value most recently written to a referenced object property. May be analog, binary, or other. depending on the controlled property.

Property	W	Type	Example	Remarks
priority-for- writing	Y	Unsigned	16	Assigned in schedule setup at the operator workstation.
weekly- schedule	Y	Sequence	<Array of BAC- net Daily Schedule>	Assigned in schedule setup at the operator workstation.

Properties of VLC Trendlog Objects

Property	W	Type	Example	Remarks
acked_ transitions		BACnet Event-TransitionBits	111	Conveys flags that indicate the receipt of acknowledgements for events.
buffer_size	Y	Unsigned32	256	The maximum number of records the log file can hold.
client_cov_increment	Y	Double	1.00 {ok}	The amount of change required to cause a log record to be written. Only non-negative numbers allowed.
cov_resubscription_interval	Y	Integer	300	How often the trendlog resubscribes to the monitored point. Units are seconds. Valid values are 1 to 86,400 inclusive.
description	Y	Character-String	Device 65555, BODESC_0	Description of the trendlog.
event_enable	Y	BACnet Event-Transition Bits	001	Enables or disables reporting of TO-FAULT and TO-NORMAL events.
event_state			Normal, Fault, Offnormal, HiLimit, LowLimit, Life Safety Alarm	
event_time_stamps		BACnetARRAY [3] of BACnetTimeStamp	[1] ****_**_**_** **. **.** ** [2] _. ****_**_**_** **. **.** ** [3] 2020- 03-25- Wed 13:22:28.00	The time an event occurred.
last_notify_record		Unsigned32	441785	Sequence number of the log record that triggers a notification.
log_buffer		BACnetLog-MultipleRecord		A list of BACnetLog- MultipleRecord records. Only readable through ReadRange service
log_device_object_property	Y	BACnetARRAY of BACnetDeviceObjectPropertyReference	BO 11,proprietary1135	Specifies the properties to be logged. May reference only internal objects.
log_interval	Y	Unsigned	0	The interval at which monitored properties are logged. Set to zero for TRIGGERED Logging_Type.
logging_type	Y	BACnetLoggingType	Polled, COV, Triggered	Specifies whether records are collected by polling or by triggered acquisition.
notification_class	Y	Unsigned	1	The notification class used when handling event notifications.

Property	W	Type	Example	Remarks
notification_threshold	Y	Unsigned32	80	Specifies the number of records (since the last notification) at which a notification is sent.
notify_type	Y	BACnetNotifyType	Alarm, Event, Ack Notification	Defines if notifications will be events or alarms.
object_identifier		BACnetObjectIdentifier	Trend-log 1	A numeric identifier for the associated object.
object_name	Y	Character String	Trendlog 30	The name of the trendlog object. Default is "Trendlog n".
object_type		BACnetObjectType	TREND- LOGMULTIPLE	The object type of the trendlog.
record_count		Unsigned32	256	Represents the number of log records currently in the Log_ Buffer.
records_since_notification		Unsigned32	27	The number of log records since the last notification.
start_time	Y	BACnetDate-Time	****_**_**_*** **.*.*** **	The date and time that logging will start.
stop_time	Y	BACnetDate-Time	****_**_**_*** **.*.*** **	The date and time that logging will stop.
stop_when_full	Y	Boolean	False	Specifies whether logging should stop when the log buffer is full. TRUE stops logging. FALSE causes the oldest log records to be overwritten.
total_record_count		Unsigned32	441973	Total number of log records collected by the Trend Log Multiple object since creation. Wraps back to 1 after reaching 2(to the power 32) - 1.
trigger	Y	Boolean	False	Causes the trendlog to log a record when the value of the trigger property is changed from FALSE to TRUE.

Properties of VLC Zone Objects

Property	W	Type	Example	Remarks
Object- Identifier		BACnet Object Identifier	Zone n	This property consists of the object-type property and the object instance, which is a numeric code that identifies the object of interest.
Object- Name	Yes	Character string	Zone n	CANNOT BE SET BLANK. Example: Bob Off
Object- Type		BACnet Object Type	Zone	
Present- Value		Enumerated	UnOcc	Status Types: Occupied, Unoccupied, Warmup, Cooldown and Tenant Override
Description	Yes	Character string		Example: Bob's Office
Status- Flags		Bit string		A four-position bit string that indicates the status of the BO. If status bit=1, that status is TRUE.
Units	Yes	Enumerated	Deg F	Indicates the unit of measure, in BACnet engineering units, that the Zone is expressed in. Example: Deg F
Aler-Ref- Device	Yes	BACnet Object Identifier		Device Instance to which the Zone is Linked.

Property	W	Type	Example	Remarks
Aler- Weekly-Sched- Inputs		Enumerated		Weekly Schedule Status
Aler- Weekly-Sched- Objects		BACnet Object Property Reference		Weekly Schedule Reference
Aler-Holiday-Sched-Inputs		Enumerated		Holiday Schedule Status
Aler-Holiday-Sched-Objects		BACnet Object Property Reference		Holiday Schedule Reference
Aler-Event- Sched-Inputs		Enumerated		Event Schedule Status
Aler-Event- Sched-Objects		BACnet Object Property Reference		Event Schedule Reference
Priority- for-Writing	Yes	Unsigned	13	Priority at which the Zone Object writes to Commanded Objects.
Aler-Persistence-Rate	Yes	Unsigned	300	Frequency (in seconds), at which the Zone Object writes to Commanded Points (range 60-300).
Aler-Re- fresh-Rate	Yes	Unsigned	300	Frequency (in seconds), at which the Zone Object reads Input Points (range 10-900).
Aler-Opti- mum-Start-Mode	Yes	Enumerated	"none"	Status Options: None, Standard, and Manual.
Aler-Maxi- mum-Ad- vance- Time	Yes	Unsigned	240	Maximum Time (in minutes), that Optimum Start may Start Zone.
Aler-OA- Temp-Reference	Yes	BACnet Object Property Reference	AV-103	Reference to BACnet Object containing OA Temp.
Aler-OA- Temp-Value		Real		Value of Outside Air Temp Sensor.
Aler-Humidity-Reference	Yes	BACnet Object Property Reference		Reference to BACnet Object containing Humidity.
Aler-Humidity- Value		Real		Value of Humidity Sensor
Aler-OA- Limit	Yes	Real	65	Used for Optimum Start
Aler-Building-Mass	Yes	Real	4	Used for Optimum Start
Aler- Warmup-Factor	Yes	Real	1	Used for Optimum Start
Aler-Cool- down-Factor	Yes	Real	1	Used for Optimum Start
Aler-Alt- Warmup-Factor	Yes	Real	0	Used for Optimum Start
Aler-Alt- Cooldown-Factor	Yes	Real	0	Used for Optimum Start
Aler-Tuning-Factor	Yes	Real	0.5	Used for Optimum Start
Aler-Cooling-Temp-Rate	Yes	Real	3	Used for Optimum Start

Property	W	Type	Example	Remarks
Aler-Heating-Temp-Rate	Yes	Real	3	Used for Optimum Start
Aler-Occupied-Cmd-Value		Enumerated		
Aler-Occupied-Cmd-Ref				
Aler-Occupied-Cmd-Ref	Yes	BACnet Object Property Reference		
Aler- Warmup- Cmd-Value		Enumerated		
Aler- Warmup- Cmd-Ref	Yes	BACnet Object Property Reference		
Aler-Cool- down- Cmd-Value		Enumerated		
Aler_Cool- down_ Cmd_Ref	Yes	BACnet Object Property Reference		
Aler-Zone- Temp-Value		Real		
Aler-Zone- Temp-Reference	Yes	BACnet Object Property Reference		
Aler-Occ- Htg-SP-Value		Real		
Aler-Occ- Htg-SP-Reference	Yes	BACnet Object Property Reference		
Aler-Occ- Clg-SP-Value		Real		
Aler-Occ- Clg-SP-Reference	Yes	BACnet Object Property Reference		
Aler-Tenant-Over-ride-Value		Enumerated		
Aler-Tenant-Over-ride- Reference	Yes	BACnet Object Property Reference		
Aler- Refresh	Yes	Boolean		Force Refresh
Aler- Diagnostics		Octet String		
Aler-Tenant-	Yes	BACnet Object Property Reference		
Activities- Recipient				
Aler-Zone- Main-Truth- Table		Octet String		
Aler-Zone-Command- Mode	Yes	Enumerated	Binary	Types: Binary or MultiState

DIAGNOSTIC AVS AND BVS

The present-value property of the diagnostic AVs and BVs listed are reserved to provide operating information about the VLC8u8-IP and VLC16u8-IP. You can reference these present values on data displays or in DDC to assist in troubleshooting and fault detection.

VLC specific Diagnostic Templates are included in the Compass 2.2.0 Alerton/Standard library and the latest versions are available for download from the Alerton ASN.

Point		Property	Description Property	Pres Val	Units (Not BACnet)	Clearable
Misc. Global Items						
AV	100000	System reboot count				
AV	100006	System log				
AV	100007	Firmware update log				
AV	100010	Free Memory				
AV	100015	Device certificate				
DDC Status						
AV	100030	DDC State				
AV	100031	DDC Read/Exec/Write Time				
AV	100032	DDC Expanded Size				
AV	100033	DDC Temp RAM Storage				
AV	100034	DDC Branch Points Used				
AV	100035	DDC Temp Priority Arrays				
AV	100036	DDC Property Access - Total				
AV	100037	DDC Property Access - Reads				
AV	100038	DDC Property Access - Writes				
Property Requesting						
AV	100060	Property requests per second				
AV	100061	Property cycle time				
AV	100065	Total BACnet/IP Packets dropped				
Versions						
AV	100080	Boot loader version				
AV	100081	Maintenance image version				
AV	100082	Normal image (ROC) version				
AV	100088	Product serial number				
AV	100089	Reboot Log				
AV	100090	Hardfault Log				
AV	100091	WatchDog Log				
AV	100092	Free Memory Size Heap				
Ethernet Stats						
AV	100100	Ethernet Enabled				

Point		Property	Description Property	Pres Val	Units (Not BACnet)	Clearable
AV	100101	Ethernet Speed				
AV	100102	Ethernet Duplex				
AV	100103	Ethernet RX Frames				
AV	100104	Ethernet TX Frames				
AV	100105	Ethernet RX Bytes				
AV	100106	Ethernet TX Bytes				
AV	100107	Ethernet RX Errors				
AV	100108	Ethernet TX Errors				
AV	100109	Ethernet RX Dropped				
AV	100110	Ethernet TX Dropped				
AV	100111	Ethernet Collisions				
AV	100112	Ethernet MAC - A				
AV	100119	Ethernet DHCP Enabled				
AV	100120	IP Address				
AV	100124	Ethernet Net Mask				
AV	100128	Ethernet Default Gateway - A				
AV	100132	Ethernet DNS Server - A				
AV	100136	Ethernet DNS Server 2 - A				
AV	100140	Ethernet DHCPv4 Info Received				
AV	100141	Ethernet DHCPv6 Info Received				
AV	100142	Ethernet SLAAC info received				
AV	100143	Ethernet IPv6 Addresses				
BACnet/Ethernet						
AV	100300	BACnet/Ethernet Enabled				
AV	100301	BACnet/Ethernet Network number				
AV	100302	BACnet/Ethernet BACnet Port ID				
AV	100303	BACnet/Ethernet Frames Received				
AV	100304	BACnet/Ethernet Frames Transmitted				
AV	100305	BACnet/Ethernet bytes Received				
AV	100306	BACnet/Ethernet bytes transmitted				
AV	100307	BACnet/Ethernet Dropped packets				
BACnet/IP						
BV	101100	BACnet/IP Enabled				

Point		Property	Description Property	Pres Val	Units (Not BACnet)	Clearable
BV	101101	BACnet/IP BBMD enabled				
BV	101102	BACnet/IP local broadcasts disabled				
BV	101103	BACnet/IP adapter open				
BV	101104	BACnet/IP registered with foreign device				
AV	101100	BACnet/IP network number				
AV	101101	BACnet/IP mode				
AV	101102	BACnet/IP adapter				
AV	101103	BACnet/IP UDP port				
AV	101104	BACnet/IP foreign BBMD address				
AV	101108	BACnet/IP foreign F124BBMD UDP Port				
AV	101109	BACnet/IP foreign BBMD Re-registration interval				
AV	101116	BACnet/IP IP address				
AV	101120	BACnet/IP IP Netmask				
AV	101124	BACnet/IP frames received				
AV	101125	BACnet/IP frames transmitted				
AV	101126	BACnet/IP bytes received				
AV	101127	BACnet/IP bytes transmitted				
AV	101128	BACnet/IP dropped packets				
AV	101129	BACnet/IP BDT Entries				
AV	101130	BACnet/IP FDT Entries				
AV	101131	BACnet/IP BACnet Port ID				
Other Miscellaneous						
AV	101900	Local year4 - value in four digits, ex. 2024				
AV	101901	Local BACnet year - value based on 1900 as the base, ex. 124 = 2024				
AV	101902	Local year2 - value in two digits, ex. 24				
AV	101903	Local month - value in the range of 1-12, ex. Feb = 2				
AV	101904	Local date of month - value in the range 1-31				
AV	101905	Local BACnet day of week - Monday = 1...Sunday = 7				
AV	101906	Local day of week - Sunday = 1...Saturday = 7				

Point		Property	Description Property	Pres Val	Units (Not BACnet)	Clearable
AV	101907	Local hours - value in the range of 0-23				
AV	101908	Local minutes - value in the range of 0-59				
AV	101909	Local seconds - value in the range of 0-59				
AV	101910	Local latitude				
AV	101911	Local longitude				
AV	101912	Uptime total				
AV	101913	Uptime SS				
AV	101914	Uptime MM				
AV	101915	Uptime HH				
AV	101916	Uptime days				
BACnet Objects						
AV	106006	Calendar Object Count				
AV	106009	Event Enrollment Object Count				
AV	106015	Notification Class Object Count				
AV	106017	Schedule Object Count				
AV	106020	Trend Log Object Count				
AV	106204	Alerton Demand limiter object count				
AV	106205	Alerton Zone Object Count				
AV	106206	Alerton Device Comm Fail Count				
Modbus Configuration Points						
BV	130000	Present value	Modbus enable			
BV	139200	Description	Last exception received			
AV	100008	Description	Modbus error report			
AV	130001	Present value	COM Baud Rate			
AV	130002	Description	COM Parity			
AV	130003	Present value	COM Bits			
AV	130004	Description	COM Mode			
AV	139003	Present value	Number of Mapped Points			
AV	139004	Present value	Number of Mapping Errors			
AV	139200	Present value	Messages Transmitted			
AV	139201	Present value	Messages Received			
AV	139202	Present value	NR Count			

Point		Property	Description Property	Pres Val	Units (Not BACnet)	Clearable
AV	139204	Present value	Special Errors			

When compass web user interface reports NR value or No Entry for a device then the following resolution will help them to get the data read from the device. This can also happen when the user is downloading a ROC file, restart the device or during maintenance of the device.

Symptoms	Cause	Resolution
No Entry	Appears if: <ul style="list-style-type: none"> The device is not in device manager, or The number of devices in device manager exceeds the license limit. 	1. Perform a device scan and save results to device manager table from the device manager. Refer to the “Scanning for devices” section in the workstation interface user guide.
		2. Delete the devices from the device manager table until the device limit is no longer exceeded.
NR value	The device is not communicating: <ul style="list-style-type: none"> When in offline, or The device Net/Mac is incorrect due to renumbering. 	Use reinitialize device icon from the vertical menu on the left within the web user interface. This allows the reinitialization of a single device and does not require one to be at the primary compass workstation. Refer the “Device Reinitialize” section in the browser interface user guide.

REGULATORY INFORMATION

FCC Regulation

This device complies with Part 15 of the FCC Rules. Operation is subject to the following two conditions:

- (1) this device may not cause harmful interference, and
- (2) this device must accept any interference received, including interference that may cause undesired operation.



NOTE:

This equipment has been tested and found to comply with the limits for a Class B digital device, pursuant to Part 15 of the FCC Rules. These limits are designed to provide reasonable protection against harmful interference when the equipment is operated in a commercial environment. This equipment generates, uses, and can radiate radio frequency energy and, if not installed and used in accordance with the instruction manual, may cause harmful interference to radio communications. Operation of this equipment in a residential area is likely to cause harmful interference, in which case the user will be required to correct the interference at his own expense.

Changes or modifications not expressly approved by the party responsible for compliance could void the user's authority to operate the equipment.

However, there is no guarantee that interference will not occur in a particular installation.

If this equipment does cause harmful interference to radio or television reception, which can be determined by turning the equipment off and on, the user is encouraged to try to correct the interference by one or more of the following measures:

- Reorient or relocate the receiving antenna.
- Increase the separation between the equipment and receiver.
- Connect the equipment into an outlet on a circuit different from that to which the receiver is connected.
- Consult the dealer or an experienced radio or TV technician for help.

Canadian Regulatory Statement

This device contains licence-exempt transmitter(s)/receiver(s) that comply with Innovation, Science and Economic Development Canada's licence-exempt RSS(s). Operation is subject to the following two conditions:

- (1) This device may not cause interference.
- (2) This device must accept any interference, including interference that may cause undesired operation of the device.


L'émetteur/récepteur exempt de licence contenu dans le présent appareil est conforme aux CNR d'Innovation, Sciences et Développement économique Canada applicables aux appareils radio exempts de licence. L'exploitation est autorisée aux deux conditions suivantes:

- (1) L'appareil ne doit pas produire de brouillage;
- (2) L'appareil doit accepter tout brouillage radioélectrique subi, même si le brouillage est susceptible d'en compromettre le fonctionnement.

CAN ICES-3 (B)/NMB-3(B).

CE Statement

The WLAN function for this device is restricted to indoor use only when operating in the 5150 to 5350 MHz frequency range.



AT	BE	BG	CH	CY	CZ	DE	DK	EE	EL	ES
FI	FR	HR	HU	IE	IS	IT	LI	LT	LU	LV
MT	NL	NO	PL	PT	RO	SE	SI	SK	TR	

Fig. 77 CE Statement

Professional Installation Warning

- This device must be professionally installed, this should be noted on grantee.
- To maintain compliance, only the antenna types that have been tested shall be used, which is listed in Table 2 on page 3.
- This device requires significant technology engineering expertise to understand the tools and relevant technology, which is not readily available to the average consumer. Only a person professionally trained in the technology is competent.
- This device is not directly marketed or sold to general public.

Wireless Connectivity

The Bluetooth Low Energy (BLE) chip is used for the secure BLE communication with apps (wiring verification). It works at a frequency of ~2400 MHz. A mobile app is used to establish a secure BLE connection to the controller via BLE. After establishing a secure connection with the controller's mobile app, the controller will exchange cable verification data over BLE in an encrypted format.

Table 34 Connectivity Frequency Range

Parameter	Specification
Connectivity	Bluetooth
Frequency Range	2.4 GHz
E.I.R.P for CE (Effective Isotropic Radiated Power)	20 mW
E.I.R.P for FCC/IC (Effective Isotropic Radiated Power)	20 mW

BLE Certifications

Table 35 BLE Certification Numbers

SKUs	FCC ID	IC ID
VLC8u8-IP-BLE VLC8u8-T1L-BLE VLC16u8-IP-BLE VLC16u8-T1L-BLE	2A8LT-24NM001	12252A-24NM001

Standards and Compliance

- CE mark
- UL916 Energy Management Equipment
- UL/ULC 60730-1
- FCC/IC Product Class B,
- UL2043
- Plenum tested (according to UL 2043)



NOTE:

- At the end of the product life, dispose of the packaging and product in an appropriate recycling center.
- Do not dispose of the device with the usual domestic refuse.
- Do not burn the device.

Approvals and Certifications

- UL 60730-1, Standard for Automatic Electric Controls for Household and Similar Use, Part 1: General Requirements
- CAN/CSA-E60730-1:02, Standard for Automatic Electrical Controls for Household and Similar Use, Part 1: General Requirements
- Complementary listing for UL916, CSA C22.2 No. 205;
- IP CAT5/6 and IP T1L Unitary models as BACnet[®] Advanced Application Controller (B-AAC); (BTL Certification is in progress)
- CE-approved
- FCC part 15B-Class B.
- ISED ICES-003 Class B
- RoHS conformity



WEEE Directive 2012/19/EC Waste Electrical and Electronic Equipment directive

At the end of the product life, dispose of the packaging and product in an appropriate recycling center. Do not dispose of the device with the usual domestic refuse. Do not burn the device.

Article 33 Communication

REGULATION (EC) No 1907/2006 OF THE EUROPEAN PARLIAMENT AND OF THE COUNCIL of 18 December 2006

Concerning the Registration, Evaluation, Authorization, and Restriction of Chemicals (REACH) Honeywell takes compliance with REACH very seriously.

According to Article 33, "Duty to communicate information on substances in articles":

- Any supplier of an article containing a substance meeting the criteria in Article 57 and identified in accordance with Article 59(1) in a concentration above 0.1% weight by weight (w/w) shall provide the recipient of the article with sufficient information, available to the supplier, to allow safe use of the article including, as a minimum, the name of that substance.
- On request by a consumer, any supplier of an article containing a substance meeting the criteria in Article 57 and identified in accordance with Article 59(1) in a concentration above 0.1% weight by weight (w/w) shall provide the consumer with sufficient information, available to the supplier, to allow safe use of the article including, as a minimum, the name of that substance.

Our duty is to inform you that the substance(s) listed below may be contained in these products above the threshold level of 0.1% by weight of the listed article.

Table 36 Alerton Unitary Controllers Containing Lead (Pb)

Product / Part Name	Substance Name
VLC8u8-IP VLC8u8-IP-BLE VLC8u8-T1L VLC8u8-T1L-BLE VLC16u8-IP VLC16u8-IP-BLE VLC16u8-T1L VLC16u8-T1L-BLE	Lead (Pb)

- We confirm that our products do not use any other REACH restricted materials during the manufacturing, storage or handling process.

ABBREVIATIONS

Table 37 Abbreviations

Abbreviation	Definition
SSR	Solid State Relay
IP	Internet Protocol
RTU	Remote Terminal Unit
BMS	Building Management Solutions
VLC	Visual Logic Control
UIO	Universal IO
NEMA	National Electrical Manufacturers Association
SDRAM	Synchronous dynamic random-access memory
QSPI	Quad Serial Peripheral Interface
DHCP	Dynamic Host Configuration Protocol
EIRP	Effective Isotropic Radiated Power
SMA	Sub miniature push
CMOS	Complementary Metal Oxide Semiconductor
TTL	Transistor Logic

RELATED TECHNICAL LITERATURE

Table 38 Related Technical Literature

Title	Reference
Alerton Unitary Controller Product Data sheet	31-00696
Alerton Unitary Controller Installation Instructions	31-00737
Alerton Unitary Controller Security Guide	31-00529
Compass Programmers Guide	31-00215

The material in this document is for information purposes only. The content and the product described are subject to change without notice. Honeywell makes no representations or warranties with respect to this document. In no event shall Honeywell be liable for technical or editorial omissions or mistakes in this document, nor shall it be liable for any damages, direct or incidental, arising out of or related to the use of this document. No part of this document may be reproduced in any form or by any means without prior written permission from Honeywell.

ALERTON

715 Peachtree St NE
Atlanta, Georgia 30308
www.alerton.com

31-00738-02 | Rev. 08-25
© 2025 Honeywell International Inc.

ALERTON
Smarter Buildings Start Here