


Class 6000 MMU 24 Meter Configuration

Position	Voltage*	Tag**
1	_____	_____
2	_____	_____
3	_____	_____
4	_____	_____
5	_____	_____
6	_____	_____
7	_____	_____
8	_____	_____
9	_____	_____
10	_____	_____
11	_____	_____
12	_____	_____
13	_____	_____
14	_____	_____
15	_____	_____
16	_____	_____
17	_____	_____
18	_____	_____
19	_____	_____
20	_____	_____
21	_____	_____
22	_____	_____
23	_____	_____
24	_____	_____



Customer Name: _____

Job Name: _____

Layout #: _____

Order #: _____

*Specify 120/208-240 or 277/480 This information is REQUIRED for factory pre-wiring to the line voltage terminal block input(s)

If single phase, specify a single pole or double pole circuit. If single phase is being fed from a three phase source please note which phases to connect to the terminal A, B or C.

**Each factory meter label can include a custom "Tag" at no additional cost, Tag must be no more than 11 characters long. For example Suite 101, LP1, RTU and etc.

