

BACnet MSTP FCU Controller

BACNET PROTOCOL IMPLEMENTATION CONFORMANCE STATEMENT (PICS)

Date: 14-Jan-2021

Vendor Name: Honeywell International Inc.

Product Name: BACnet MSTP FCU CONTROLLER

Product Model Numbers: CLMERL4N, CLMERL6N, CLMERL8N, CLMERS4N, CLMERS5N, CPO-RL4N, CPO-RL5N, CPO-RL6N, CPO-RL8N, CPO-RS3N, CPO-RS4N, CPO-RS5N, AL-RL4N, AL-RL6N, AL-RL8N, AL-RS4N, AL-RS5N, WEB-RL6N, WEB-RS5N

Applications Software Version: Beats MSTP FCU Application

Firmware Revision: 2.0.1.03

BACnet Protocol Revision: 1.14

Product Description:

The BACnet MSTP Compact VAV; a Variable Air Flow controller, provides flexible, freely programmable and demand-led control that delivers tangible benefits to reduce energy spends and drives new levels of functionality and efficiency in today's buildings. With scalable and freely programmable BACnet MS/TP-based VAV controllers, smart engineering & commissioning tools, and SYLK technology, multiple and flexible configurations can be achieved to address specific applications

BACnet Standardized Device Profile (Annex L):

- BACnet Operator Workstation (B-OWS)
- BACnet Building Controller (B-BC)
- BACnet Advanced Application Controller (B-AAC)
- BACnet Application Specific Controller (B-ASC)
- BACnet Smart Sensor (B-SS)
- BACnet Smart Actuator (B-SA)

BACnet Interoperability Building Blocks Supported (Annex K):

Data Sharing:

DS-RP-A	Read Property-A
DS-RP-B	Read Property-B
DS-RPM-B	Read Property Multiple-B
DS-WP-A	Write Property-A
DS-WP-B	Write Property-B
DS-WPM-B	Write Property Multiple-B
DS-COV-A	Change of Value-A
DS-COV-B	Change of Value-B

Alarm and Event Management:

AE-N-I-B	Alarm & Event Notification Internal-B
AE-ACK-B	Alarm & Event Acknowledgement-B
AE-INFO-B	Alarm & Event Information-B

Scheduling:

SCHED-I-B	Scheduling Internal-B
-----------	-----------------------

Trending

--	--

Device Management

DM-DDB-A	Dynamic Device Binding-A
DM-DDB-B	Dynamic Device Binding-B
DM-DOB-B	Dynamic Object Binding-B
DM-DCC-B	Device Communication Control-B
DM-PT-A	Private Transfer-A
DM-PT-B	Private Transfer-B
DM-TS-B	Time Synchronization-B
DM-UTC-B	Universal Time Synchronization-B
DM-RD-B	Reinitialize Device-B
DM-LM-B	List Manipulation -B

Standard Object Types Supported:

Object Type	Dynamically creatable	Dynamically deletable
Analog Input		
Analog Output		
Analog Value		
Binary Input		
Binary Output		
Binary Value		

Calendar		
Device		
Multistate Output		
Multistate Value		
Notification Class		
Schedule		

General Limits

- Object_Name size = 40 characters
- Description size = 132 characters
- Password size for Device Communication Control = 20 characters

Analog Input

Property name	R=Required O=Optional P=Proprietary	Writable	Property ID, Range, Data Type; other remarks
Object_Identifier	R		
Object_Name	R		
Object_Type	R		0
Present_Value	R		
Description	O		
Status_Flags	R		
Event_State	R		
Reliability	O		Possible conditions are: <ol style="list-style-type: none"> 1. no_fault_detected 2. open_loop 3. shorted_loop OPEN_LOOP (for 2 - 10V inp.)
Out_Of_Service	R	writable	
Units	R		
COV_Increment	O	writable	
Time_Delay	O	writable	range of 0 to 86400s
Notification_Class	O	writable	range of 0 to 3
High_Limit	O	writable	
Low_Limit	O	writable	
Deadband	O	writable	
Limit_Enable	O	writable	
Event_Enable	O	writable	
Acked_Transitions	O		
Notify_Type	O	writable	
Event_Time_Stamps	O		
Event_Detection_Enable	O		
Property_List	R		

Analog Output

Property name	R=Required O=Optional P=Proprietary	Writable	Property ID, Range, Data Type; other remarks
Object_Identifier	R		
Object_Name	R		
Object_Type	R		1
Present_Value	W	Writable	
Description	O		
Status_Flags	R		
Event_State	R		
Out_Of_Service	R	Writable	
Units	R		
Priority_Array	R		
Relinquish_Default	R	Writable	
COV_Increment	O	Writable	
Time_Delay	O	Writable	range of 0 to 86400s
Notification_Class	O	Writable	range of 0 to 3
High_Limit	O	writable	
Low_Limit	O	writable	
Deadband	O	writable	
Limit_Enable	O	writable	
Event_Enable	O	writable	
Acked_Transitions	O		
Notify_Type	O	writable	
Event_Time_Stamps	O		
Event_Detection_Enable	O		
Property_List	R		

Analog Value

Property name	R=Required O=Optional P=Proprietary	Writable	Property ID, Range, Data Type; other remarks
Object_Identifier	R		
Object_Name	R		
Object_Type	R		2
Present_Value	R	writable	
Description	O		
Status_Flags	R		
Event_State	R		
Reliability	O		Possible conditions are: 1. no_fault_detected 2. unreliable_other
Out_Of_Service	R	writable	
Units	R		
COV_Increment	O	writable	
Property_List	R		

Binary Input

Property name	R=Required O=Optional P=Proprietary	Writable	Property ID, Range, Data Type; other remarks
Object_Identifier	R		
Object_Name	R		
Object_Type	R		3
Present_Value	R		
Description	O		
Status_Flags	R		
Event_State	R		
Out_Of_Service	R	writable	
Polarity	R		
Inactive_Text	O		
Active_Text	O		
Change_Of_State_Time	O		
Change_Of_State_Count	O	writable	
Time_Of_State_Count_Reset	O		
Time_Delay	O	writable	range of 0 to 86400s
Notification_Class	O	writable	range of 0 to 3
Alarm_Value	O	writable	
Event_Enable	O	writable	
Acked_Transitions	O		
Notify_Type	O	writable	
Event_Time_Stamps	O		
Event_Detection_Enable	O		
Property_List	R		

Binary Output

Property name	R=Required O=Optional P=Proprietary	Writable	Property ID, Range, Data Type; other remarks
Object_Identifier	R		
Object_Name	R		
Object_Type	R		4
Present_Value	W	writable	
Description	O		
Status_Flags	R		
Event_State	R		
Out_Of_Service	R	writable	
Polarity	R		
Inative_Text	O		
Active_Text	O		
Change_Of_State_Time	O		
Change_Of_State_Count	O	writable	
Time_Of_State_Count_Reset	O		
Priority_Array	R		
Relinquish_Default	R	writable	
Time Delay	O	writable	(range of 0 to 86400s)
Notification Class	O	writable	range of 0 to 3
Feedback Value	O		If Feedback_Value is present
Event_Enable	O	writable	
Acked_Transitions	O		
Notify_Type	O	writable	
Event_Time_Stamps	O		
Event_Detection_Enable	O		
Property_List	R		

Binary Value

Property name	R=Required O=Optional P=Proprietary	Writable	Property ID, Range, Data Type; other remarks
Object_Identifier	R		
Object_Name	R		
Object_Type	R		5
Present_Value	R	writable	
Description	O		
Status_Flags	R		
Event_State	R		
Reliability	O		Possible conditions are: 1. no_fault_detected 2. unreliable_other
Out_Of_Service	R	writable	
Inactive_Text	O		
Active_Text	O		
Property_List	R		

Calendar

Property name	R=Required O=Optional P=Proprietary	Writable	Property ID, Range, Data Type; other remarks
Object_Identifier	R		
Object_Name	R		
Object_Type	R		6
Present_Value	R		
Description	O		
Date_List	R	writable	
Property_List	R		

Device

Property name	R=Required O=Optional P=Proprietary	Writable	Property ID, Range, Data Type; other remarks
Object_Identifier	R		
Object_Name	R	writable	
Object_Type	R		8
System_Status	R		
Vendor_Name	R		"Honeywell International Inc. "
Vendor_Identifier	R		17
Model_Name	R		
Firmware_Revision	R		
Application_Software_Version	R		
Location	O	writable	
Description	O	writable	
Protocol_Version	R		1
Protocol_Revision	R		14
Protocol_Services_Supported	R		
Protocol_Object_Types_Supported	R		
Object_List	R		
Max_APDU_Length_Accepted	R		
Segmentation_Supported	R		
Max_Segmenst_Accepted	O		
Local_Time	O	writable	
Local_Date	O	writable	
UTC_Offset	O	writable	
Daylight_Saving_Status	O		
APDU_Segment_Timeout	O		
APDU_Timeout	R		
Number_Of_APDU_Retries	R		
Max_Master	O	writable	
Max_Info_Frames	O	writable	
Device_Address_Binding	R		
Database_Revision	R		
Active_COV_Subscriptions	O		
Last_Restart_Reason	O		
Time_Of_Device_Restart	O		
Serial_Number	O		
Profile_Name	O		
Property_List	R		
Proprietary Property	R		1026 ; adtCharString ; 8 characters. Used for Bootloader Version

Multistate Output

Property name	R=Required O=Optional P=Proprietary	Writable	Property ID, Range, Data Type; other remarks
Object_Identifier	R		
Object_Name	R		
Object_Type	R		14
Present_Value	W	writable	
Description	O		
Status_Flags	R		
Event_State	R		
Out_Of_Service	R	writable	
Number_Of_States	R		
State_Text	O		
Priority_Array	R		
Relinquish_Default	R	Writable	
Property_List	R		

Multistate Value

Property name	R=Required O=Optional P=Proprietary	Writable	Property ID, Range, Data Type; other remarks
Object_Identifier	R		
Object_Name	R		
Object_Type	R		19
Present_Value	R	writable	
Description	O		
Status_Flags	R		
Event_State	R		
Reliability	O		Possible conditions are: 1. no_fault_detected 2. unreliable_other
Out_OF_Service	R	writable	
Number_Of_States	R		
State_Text	O		
Property_List	R		

Notification Class

Property name	R=Required O=Optional P=Proprietary	Writable	Property ID, Range, Data Type; other remarks
Object_Identifier	R		
Object_Name	R		
Object_Type	R		15
Description	O		
Notification_Class	R		
Priority	R	writable	
Ack_Required	R	writable	
Recipient_List	R	writable	
Property_List	R		

Schedule

Property name	R=Required O=Optional P=Proprietary	Writable	Property ID, Range, Data Type; other remarks
Object_Identifier	R		
Object_Name	R		
Object_Type	R		17
Present_Value	R	writable	
Description	O		
Effective_Period	R	writable	
Weekly_Schedule	O	writable	
Exception_Schedule	O	writable	
Schedule_Default	R	writable	
List_Of_Object_Property_References	R		
Priority_For_Writing	R	writable	
Status_Flags	R		
Reliability	R		Possible conditions are: 1. no_fault_detected 2. configuration_error
Out_Of_Service	R	writable	
Property_List	R		

Proprietary Objects Supported:

Object Type	Object Type ID
DDC Command Object	512
Output Reference	513
Input Reference	514

DDC Command Object

Property name	R=Required O=Optional P=Proprietary	Writable	Property ID, Range, Data Type; other remarks
Object_Identifier	R		
Object_Name	R		
Object_Type	R		512
Present Value	O		
DDC_Command	P		1024

Input Reference

Property name	R=Required O=Optional P=Proprietary	Writable	Property ID, Range, Data Type; other remarks
Object_Identifier	R		
Object_Name	R		
Object_Type	R		514
Description	O		
Present_Value			85 Any May be Boolean Unsigned Real
Reliability			103 Possible unreliable conditions are: UNRELIABLE_OTHER, COMMUNICATION_FAILURE
Status_Flags			111
Units			117
Property List	R		

Output Reference

Property name	R=Required O=Optional P=Proprietary	Writable	Property ID, Range, Data Type; other remarks
Object_Identifier	R		
Object_Name	R		
Object_Type	R		513
Description	O		
Present_Value			85 Any May be Boolean Unsigned Real
Priority_For_Writing			
Reliability			103 Possible unreliable conditions are: UNRELIABLE_OTHER, COMMUNICATION_FAILURE
Status_Flags			111
Property List	R		

Segmentation Capability:

- Segmented requests supported Window Size 4
- Segmented responses supported Window Size 4

Data Link Layer Options:

- BACnet IP, (Annex J)
- BACnet IP, (Annex J), Foreign Device
- ISO 8802-3, Ethernet (Clause 7)
- ATA 878.1, 2.5 Mb. ARCNET (Clause 8)
- ATA 878.1, RS-485 ARCNET (Clause 8), baud rate(s) _____
- MS/TP master (Clause 9), baud rate(s): 9600, 19200, 38400, 57600, 76800
- MS/TP slave (Clause 9), baud rate(s): _____
- Point-To-Point, EIA 232 (Clause 10), baud rate(s): _____
- Point-To-Point, modem, (Clause 10), baud rate(s): _____
- LonTalk, (Clause 11), medium: _____
- Other: _____

Device Address Binding:

Is static device binding supported? (This is currently necessary for two-way communication with MS/TP slaves and certain other devices.) Yes No

Networking Options:

- Router, Clause 6 - List all routing configurations, e.g., ARCNET-Ethernet, Ethernet-MS/TP, etc.
- Annex H, BACnet Tunneling Router over IP
- BACnet/IP Broadcast Management Device (BBMD)
Does the BBMD support registrations by Foreign Devices? Yes No

Character Sets Supported:

Indicating support for multiple character sets does not imply that they can all be supported simultaneously.

- ISO 10646 (UTF-8) IBM™/Microsoft™ DBCS ISO 8859-1
- ISO 10646 (UCS-2) ISO 10646 (UCS-4) JIS X 0208

Honeywell

Manufactured for and on behalf of the Environmental and Combustion Controls Division of Honeywell Technologies Sàrl, Rolle, Z.A. La Pièce 16, Switzerland by its Authorized Representative

Automation and Control Solutions

Honeywell International Inc.
1985 Douglas Drive North
Golden Valley, MN 55422
USA

<http://www.honeywell.com>

Honeywell Limited-Honeywell Limitee
35 Dynamic Drive
Scarborough, Ontario M1V 4Z9
Canada

<http://www.honeywell.ca>

Honeywell GmbH
Böblinger Straße 17
71101 Schönaich
Germany

<http://europe.hbc.honeywell.com>

Printed in Germany

Subject to change without notice