METASYS®

Literature Errata

File Here:

FC-2000 Technical Manual
Installation Section

No. 2 (FAN 406)

DATE: July 25, 2000
SUBJECT: Power Supply UL Listing and Device Compatibility
FROM: Facility Management System Marketing Team
TO: *FC-2000 Technical Manual* Holders *(FAN 406)*

All Fire System Power Supplies that were UL Listed as "Regulated" are Now Listed as "Special Application"

Prior to 1996, the power supplies listed below were originally Underwriters Laboratories (UL) Listed as "Regulated" concerning their compatibility with notification appliances. These power supplies are electrically regulated, but they are not in compliance with current UL standards for regulated power supplies and are therefore, UL Listed as Special Application power supplies. Remove references to the phrase "UL Listed as a Regulated Power Supply" from all product literature and change to "UL Listed as a Special Application Power Supply" for the power supplies identified in Table 1:

Table 1: Special Application Power Supplies

Part Numbers Affected	Description or Product Name
APS-6R	Auxiliary Power Supply
AVPS-24	Auxiliary Power Supply
CHG-120	Remote Battery Charges
FCPS-24	Field Charger/Power Supply
MPS-24A	Main Power Supply
MPS-24B	Main Power Supply
NR45-24	Remote Battery Charger

--continued on back--

Use power supplies Listed as “Special Application” only with devices that are Listed by Underwriters Laboratories or by the manufacturer as being compatible with them. Do not use devices not listed on the compatibility chart with these power supplies.

Device Compatibility

Please refer to the *Device Compatibility Technical Bulletin (LIT-445180)* to be sure your equipment meets UL requirements and is Compatibility Listed for use with the specific control unit module (i.e., M510CJ, M502MJ, XPC-8, XPM-8, etc.) and 2-wire conventional smoke detectors.