Honeywell

FIRE-LITE ALARMS

One Fire-Lite Place
Northford, CT 06472-1610 USA

203-484-7161
203-484-7118 Fax
www.firelite.com

September 04, 2015

Re: IPGSM-4G Firmware Update

Fire-Lite has been informed of an issue with IPGSM-4G and the IPGSM-4GC Commercial Fire Alarm Communicators with the following firmware


Radio Models	Firmware Version Affected
IPGSM-4G	3.0.0 to 3.0.2

Please review the accompanying Honeywell Security Bulletin for specific details on the aforementioned issue and the recommended corrective actions.

For Technical Questions or to request an upgrade kit, please contact technical support at 1-800-627-3473 or at firelite.tech@honeywell.com.

Please contact the Honeywell Security Products Americas at 1-800-222-6525 if you have any technical questions pertaining to this notice.

Sincerely,



Kenneth W. Gentile
Product Manager