Gamewell FCI FIRE CONTROL INSTRUMENTS by Honeywell

Technical Bulletin

Date: August 3, 2010

No. T10.6

To: All Gamewell-FCI Distributors

E3 Series PM-9 Power Supply Tech Tip



Customers receiving PM-9 series power supply should be aware of its new look.

- The first change is the PC board is **RED.** This was done as part of the manufacturing process to identify changing from the older rev to the new PM-9 Series product. This will revert back to green when the stock of red boards become depleted (probably with in a couple of months).
- Be sure to check all labels, shipping cartons, install sheets and PC boards. These are clearly marked with product labels. This ensures that you have the correct product that was ordered.
- Finally, the product label that is now placed on the back of the PC board is being moved to the front center of the PC board for easy identification after installation.

KEY POINT: CUSTOMERS SHOULD RELY ON THE PRODUCT LABELS.

Below is a list of labels and where they are found on the product.

Item no.	Carton	Install Sheet	Product Label (on back of pcb)	JMP2	Listing	Input Voltage
PM-9	Labeled “PM-9”	Titled “PM-9”	Labeled “PM-9”	intact	UL	120 VAC
PM-9G	Labeled “PM-9G”	Titled “PM-9G”	Labeled “PM-9G”	cut	UL	220 VAC
PM-9-C	Labeled “PM-9-C”	Titled “PM-9-C”	Labeled “PM-9-C”	intact	ULC	120 VAC

Contact Gamewell-FCI Technical Support if you have any questions regarding this bulletin.

Sincerely,

Robert Gomersall
Product Manager
Gamewell-FCI