Gamewell FCI FIRE CONTROL INSTRUMENTS by Honeywell

Technical Bulletin

No. TTB07.1

Date: January 17, 2007

To: All Gamewell-FCI Distributors

New 7100 Series MCOM Board now shipping

All 7100 series panels manufactured after December 1st, 2006 include changes and modifications necessary for UL 864 9th edition. To support master box use with the updated 7100 control, a new version MCOM (Municipal Circuit Option Module) is necessary. Effective immediately, all MCOM modules shipped will incorporate 9th edition changes. This module (Rev D) is compatible with new panels and with a slight modification is also compatible with legacy 7100 control panels. MCOM modules (Rev C) and earlier are not compatible with 7100 panels (Rev F) and later.

Modifying the updated MCOM module to work with (Rev C) and earlier simply requires removing resistor R6 (see picture below). No other modifications are necessary.

If you have any questions regarding this upgrade please contact technical support at your convenience.

Regards,

Jim Kimpel
Product Manager
Gamewell-FCI

R6

