GENT
by Honeywell

Technical Bulletin	TB 10001

To: Systems Integrators	Date: 24/10/2001
	Status: Active
	Type: SI

Product – Part affected:
Vigilon - Laptop commissioning software Version V1.03

Details:
We have recently supplied you with the latest Vigilon Windows commissioning software version V1.03.

This new commissioning tool includes over 30 known bug fixes and tool enhancements. These include the ability to support panels with sub loops and the option to transmit labels only. To view the complete list of fixes select C:/Program Files/Caradon Gent/Commissioning Tool/ReleaseNote103 after loading the software from the disc provided.

The tool has been in use for a month and we are aware of only 1 software bug which is as follows:
Software bug: In Command Build set up, if the action is Timeslot On the program will return the prompt 'Incorrect / missing data'.
Temporary fix procedure: Set up the action as a Delay, complete all the fields and Save. Re-enter the Command Build and change the action to On, the program will then allow the data to be saved.

Further enhancements are proposed to speed up the operation of the tool. Proposals include the ability to transmit specific data, i.e. sectors and specifying communication to a stand alone panel, thus removing the need to transmit 255 Master Sectors and Master Group data. All future changes are subject to full testing and approval.

We will communicate details of new software releases as soon as they are available.

Action:

Name: Paul Smith