GENT
by Honeywell

Technical Bulletin	TB 10009

To: System Integrators, Gent Services	Date: 27/09/2002
	Status: Active
	Type: Gent/SI

Product – Part affected:
S-cubed software requirements for 3400 & Vigilon panels

Details:
The S-Cubed sounder strobe will only work on:
BS panels with LCC v3.70, I/O v3.72, LPC v3.80
EN54 panels with LCC v4.10, I/O v4.05, LPC v4.10.

For strobe only devices the software needs to be as above but the loop at v3.81 and v4.11 respectively

Action:
All new panel and upgrade kits will be sent out with the latest software releases.
Ensure panel software is of a suitable level to run the devices. If not upgrade panel software.

Name: Peter Dodge