GENT
by Honeywell

| Technical Bulletin | TB 10018 |
|---|---|

| To: System Integrators, Gent Services | Date: 08/12/2003 |
|---|---|
| | Status: Active |
| | Type: Gent/SI |

| Product – Part affected: |
|---|
| Vigilon EN54 Zonal door |
| **Details:** |
| Using the new zonal display door on EN54 Vigilon panels.<br>If the standard Vigilon EN54 LCC chip is used then the display and LED's will flicker and the buzzer will crackle. |
| **Action:** |
| The new Zonal door for EN54 panels also required a new LCC to be used.<br>The new LCC chip is part number 2211-137 |

**Name:** Peter Dodge