GENT
by Honeywell

Technical Bulletin	TB 10020

To: System Integrators, Gent Services	Date: 10/12/2003
	Status: Active
	Type: Gent/SI

Product – Part affected: Commissioning tool V1.14 stopping upload at last device on loop
Details: When uploading to a safe addressed loop the comm. tool stops and hangs on the last device on the loop. This is because the last device on the loop has a number lower than the number of devices on that loop.
Action: This problem is being looked into and a fix will be available shortly. In the short term, if the last device is re-safed so that it is the highest numbered device on that loop then this will allow the upload to continue.

Name: Peter Dodge