GENT
by Honeywell

Technical Bulletin	TB 10027

To: System Integrators, Novar Gent Services	Date: 21/04/2004
	Status: Active
	Type: Gent/SI

Product – Part affected:
Vigilon / 3400 Commissioning tool release V1.16

Details:
Problems have been found with commissioning tool V1.14. This version sometimes stops down loading part way through on safe addressed systems and can cause memory corrupts on S3 sounders when safe addressing systems only.

Action:
Upgrade all Commissioning tools to the latest version 1.16. A CD containing the new commissioning tool is being despatched to nominated personnel at each Gent 24 system integrator and all Novar service senior engineers.

Name: Peter Dodge