GENT
by Honeywell

Technical Bulletin	TB 10028

To: System Integrators, Novar Gent Services	Date: 07/05/2004
	Status: Inactive
	Type: Gent/SI

Product – Part affected:
Vigilon / 3400 Commissioning tool V1.16
Details:
A Problem has been highlighted with commissioning tool V1.16 where it does not send sector link back to the panel.
Action:
This is currently under investigation. We recommend that after all uploads the sector linking is checked on the panel. Please look out for further technical bulletins on this issue

Name: Peter Dodge