GENT
by Honeywell

Technical Bulletin	TB 10030

To: System Integrators, Novar Gent Services	Date: 03/06/2004
	Status: Active
	Type: Gent/SI

Product – Part affected:
Label limits on Vigilon / 3400 commissioning tool

Details:
It has been brought to our attention that it is possible to add more than 270 labels per loop on the commissioning tool. However on upload to the panel only the first 270 labels are actually sent to the panel.

Action:
This is only a problem on loops with a large amount of interfaces.
If you are using a lot of interfaces on a loop, after upload of the labels, check at the panel to make sure the last label has been received by the panel.
A modification is being made to the next version of commissioning tool so that a pop up window will appear once 270 labels is reached on a loop.

Name: Peter Dodge