GENT
by Honeywell

Technical Bulletin	TB 10049

To: System Integrators, Novar Gent Services	Date: 25/02/2005
	Status: Active
	Type: Gent/SI

Product – Part affected:
Vigilon Power supplies, earthing changes

Details:
Changes have been made to the vigilon power supply so that it complies to current EN54 standards. A conversions Kit is supplied with the PSU to enable the PSU to be used in either the old style or new style back box.
The change effects the way the incoming earthing is connected to the PSU PCB

Action:
Please find attached a PDF with details of the changes. This PDF and the conversion pack will be supplied with all new PSU's

4188-823 issue 1 2-05 conversion kit.

Name: Peter Dodge