GENT
by Honeywell

Technical Bulletin	TB 10051

To: System Integrators, Novar Gent Services	Date: 08/03/2005
	Status: Active
	Type: Gent/SI

Product – Part affected:
EN54 new MCC card.
Details:
Note, that to comply with EN54 second edition the following change has been made. When disabling a device or string of devices if this includes sounders then these will also be disabled therefore giving no output. Even pressing sound alarms will not activate these sounders.
Action:
Ensure all relevant personal are aware.

Name: Peter Dodge