GENT
by Honeywell

Technical Bulletin	TB 10055

To: System Integrators, Novar Gent Services	Date: 27/04/2005
	Status: Active
	Type: Gent/SI

Product – Part affected:
Vigilon / 3400 Commissioning Tool V1.18

Details:
A number of problems when commissioning sites with Squad / Scube

Action:
On sites that do not have any Squad devices please continue to use V1.16 (This is available from Technical Support)

Testing of V1.19 should be completed by Friday 29th of April. An update will be issued then.

Any issues with commissioning site with Squad devices then please contact Technical Support on 0116 2462000 or technical.support@gent.co.uk

Name: Peter Dodge