GENT
by Honeywell

| Technical Bulletin | TB 10058 |
|---|---|

| To: System Integrators, Novar Gent Services | Date: 11/05/2005 |
|---|---|
| | Status: Active |
| | Type: Gent/SI |

**Product – Part affected:**
New release of commissioning tool, V1.19

**Details:**
This tool fixes the issue of corrupting S3 and S4 devices and several other minor problems. Copies of this tool are being sent out to all SI's and senior engineers today.

Please note with old config files the following error message appears when opening the devices config page. "The Microsoft jet database engine cannot find the input table or query 'GenericEeprom'. Make sure it exists and that it's name is spelled correctly." This is talking about a new database that has been added in this version, please ignore the message. Once this file is saved with the new comm. tool the database will be created and the message will no longer appear.

**Action:**
Please ensure any engineer working on sites with S4 devices upgrades to this tool (v1.19) before carrying out any work.

**Name:** Peter Dodge