GENT
by Honeywell

Technical Bulletin	TB 10059

To: System Integrators, Novar Gent Services	Date: 12/05/2005
	Status: Active
	Type: Gent/SI

Product – Part affected:
S-quad base (S4-700) instructions

Details:
It has been reported that the incorrect wiring instructions have been supplied with some S-quad bases (S4-700). This shows the wiring for the 8000 system, and will not allocate if connected to the Vigilon system.

The stock of bases at Leicester have been sample checked and no incorrect instructions found.

Action:
It has been reported that the incorrect wiring instructions have been supplied with some S-quad bases (S4-700). This shows the wiring for the 8000 system, and will not allocate if connected to the Vigilon system.

The stock of bases at Leicester have been sample checked and no incorrect instructions found.

Name: Peter Dodge