GENT
by Honeywell

Technical Bulletin	TB 10072

To: System Integrators, Novar Gent Services	Date: 21/10/2005
	Status: Active
	Type: Gent/SI

Product – Part affected: Commissioning tool V1.20 adding interface
Details: When adding a loop powered interface you now get asked if this is a programmable interface. This option is for future enhancements.
Action: When prompted with this question say the interface is not programmable “NO”

Name: Peter Dodge