GENT
by Honeywell

Technical Bulletin	TB 10079

To: System Integrators, Novar Gent Services	Date: 03/01/2006
	Status: Active
	Type: Gent/SI

Product – Part affected:
New BS door release

Details:
Current production of BS vigilon panels and Repeat panels is now being done with doors with an 8 line LCD that look very similar to the EN vigilon door (smaller screen and 12 indication LED's).
The new doors will work in conjunction with existing panels on a network.
Zonal LED's exist but these are not operational.

Here are photos which highlight the difference

Repeat inner door EN.jpg Repeat inner door BS (V3+).jp

Note relating to photographs:
EN door has graphic for Sounder (3rd LED down on RHS) and Delay (4th LED down on LHS)
BS does not have graphics or LED's for either of these functions.

Action:
Please make sure all engineers and sales are aware of these changes.

Name: Peter Dodge