GENT
by Honeywell

Technical Bulletin	TB 10086

To: Gent by Honeywell, System Integrators & SMS	Date: 20/4/06
	Status: Active
	Type: SI / SMS

Product – Part affected:
Corruption of devices from using commissioning tool V1.19

Details:
The new Commissioning tool v1.20 has now been out for over 6 months. However people are still using the old commissioning tool v1.19 which is known can corrupt S4 and S3 devices.

As of the 1st June 2006 any faulty devices returned that are found to have been corrupted by the use of comm. tool v1.19 will not be accepted under warranty.

Action:
Please ensure all relevant staff are aware of this.
Ensure all engineer PC's are running the latest version of commissioning tool v1.20

Name: Peter Dodge