GENT
by Honeywell

Technical Bulletin	TB 10099

To: Gent by Honeywell, System Integrators & SMS	Date: 10/11/06
	Status: Active
	Type: SI / SMS

Product – Part affected:
Adding interface on commissioning tool V1.20

Details:
When adding a loop powered interface to the commissioning tool you are asked the question is this a programmable interface. This question relates to an interface product that is not released. Always answer this question as "No"

If you incorrectly answer this question then you will corrupt the interface and this can not be fixed.

This will be made simpler in the next release of comm. tool (V1.21)

Action:
Ensure all commissioning engineers are aware of this.

Name: Peter Dodge