GENT
by Honeywell

Technical Bulletin	TB 10102

To: Gent by Honeywell, System Integrators & SMS	Date: 28/11/06
	Status: Active
	Type: SI / SMS

Product – Part affected:
Class change over run with S3 and S4 devices

Details:
We have had a few sites displaying problem when using class change (CC) and S3, S4 devices.
After the CC has ended on some occasions one of the devices continues to sound.
This is currently being investigated.

Action:
As a temporary resolution while this is being investigated. A second command build can be set up to do a silence signal, 4 seconds after the CC has finished. This will resolve any issue on site for the time being.
For more information on this setup please contact Technical Support

Name: Peter Dodge