GENT
by Honeywell

Technical Bulletin	TB 10105

To: Gent by Honeywell, System Integrators & SMS	Date: 04/1/07
	Status: Active
	Type: SI / SMS

Product – Part affected:
Commissioning tool v1.20, CB actioning delay blocks

Details:
With comm. tool v1.20 it has been found that if you try and use a CB to delay a delay block this does not work. The use of stop and end as actions do operate correctly.

If you set the CB delay action, on the panel then this functions correctly.

Any upload with comm. tool v1.20 will stop this working correctly.

Action:
Ensure all engineers are aware of this issue.

When using comm. tool v1.20 and CB to action delay block; ensure correct operation after uploading.

This issue has been fixed in Comm tool v1.21

Name: Peter Dodge