GENT
by Honeywell

Technical Bulletin	TB 10110

To: Gent by Honeywell, System Integrators & SMS	Date: 5/7/07
	Status: Active
	Type: SI / SMS

Product – Part affected:
Vigilon, Vigilon Compact and Repeat Panels new display,
VIG1, VIG1-24, VIG1-72, COMPACT-24-N, VIG-RPT,
(Includes all V3+ variants and replacement doors)

Sentri Control and repeat Panels
SENTRI, SENTRI-RPT

Details:
Changes have been made to the display used on all variants of vigilon control panels and repeat panels

After feedback about the display used on these products the following changes have been made.
A new display is now being used that offers better contrast between text and background.

Also the method to adjust the contrast has reverted back to the variable resistor on the top left of the display board when looking at the back on the door.
The menu for adjusting the contrast will still be available to support the old doors. But will have not effect if adjusted with the new door.
There is no change to the compatibility of doors as a result of this change

Action:
Ensure all engineers are aware of these changes.

Name: Peter Dodge