GENT
by Honeywell

Technical Bulletin	TB 10129

To: Gent by Honeywell, System Integrators & SMS	Date: 7/1/2009
	Status: Active
	Type: SI / SMS

Product – Part affected:
Vigilon / Sentri, mimic Panel, New MRC V1.03

Details:
MRC software, V1.03.
This software is not to be used on MRC's fitted to mimic panels
On zonal mimic panels this software can cause an additional zone to be displayed in a fire condition.

Action:
People that have been shipped this version of software in a mimic will be contacted directly.
If you have the version of software in a mimic please contact us to arrange an upgrade.
V1.04 will be released in the next couple of weeks

Name: Peter Dodge