GENT
by Honeywell

Technical Bulletin	TB 10130

To: Gent by Honeywell, System Integrators & SMS	Date: 3/2/2009
	Status: Active
	Type: SI / SMS

Product – Part affected:
Vigilon / Sentri, new MRC (mimics & repeats from April 2008 onwards) software release V1.04

Details:
New software release V1.04.
Fixes the issue on zonal mimic panel that can course an additional zone to light up when a fire occurs.
This version can also be used on repeat panel with v1.02 or lower. No additional fixes have been made since v1.03 for this product. Although the default user code has been changed to '2222' from '2'. Disabling of devices, sounders & master sector has been moved to customer access level. These were requirements by standards.

Action:
Upgrade mimics & repeat panel where necessary. This software can be used in place of V1.03 as required by TB10128.

This new software is available from Gentexpert in the download section under "Panel & Devices upgrade software" then "MRC", along with instructions on how to carry out the upgrade. You will also need the mimic comm. tool; this is also available from Gentexpert.

Name: Peter Dodge