GENT
by Honeywell

Technical Bulletin	TB 10133

To: Gent by Honeywell, System Integrators & SMS	Date: 9/3/2009
	Status: Active
	Type: SI / SMS

Product:
Release of new commissioning tool software (V1.25).

Details:
Version 1.25 of the commissioning tool is now available in the download area of www.gentexpert.co.uk

The release is being made to include a number of additional features 7 fixes which are summarised in the following list:

- Fixes issue with O2HSP where changes to the devices could set the devices to an invalid config.
- Added support for mains powered DAU for compact VA
- Added support for additional I/O lines, needed for 12 way key switch interface.
- Added support for new S4 beams
- EN54 configurations will not allow the input of a domain 0
- Fixed issue where sometimes S4 & S3 MK2 device signals were set to “00”
- Fixed issue when selecting multiple devices with the “ctrl key” would set some to invalid configurations
- Fixed issue with mains powered interfaces on safe addressed systems sectoring moving up one devise each time you save the devices config page if they were safe addressed out of order.
- Fixes issue in where command builds were not being added if the apostrophe character was used.
- Enabled PA zone 2 functionality in ACC config page
- Fixes issue where long labels would not scroll if they where longer than the display window
- Added additional device disablement options to command builds (sounder and sensor)
- Fixes issue where O2HSP+MLwould prevent retrievals from reliably working
- When starting new retrieval comm. tool blanks existing configuration before starting retrieval.
- Fixes issue where you could not enter monitored line labels over 11 characters
- Fixes issue when adding or removing master sectors, where the master sector linking was not adjusted correctly
- Fixes issue in micro DAU where you were able to set two options to priority 7
- Fixes issue on S4-715 when adding monitor lines or there label not being saved.

Licences for the old comm. tool (v1.23) will only continue to be issues until the 29 May 2009. After this date only licences for comm. tool v1.25 or higher will be issued

Action:

Ensure all commissioning PC are updated to this latest version

Name: Peter Dodge