GENT
by Honeywell

Technical Bulletin	TB 10134

To: Gent by Honeywell, System Integrators & SMS	Date: 13/3/2009
	Status: Active
	Type: SI / SMS

Product:
Commissioning tool (V1.25), incorrect version.

Details:
The version of commissioning tool 1.25 I originally uploaded on to Gentexpert was a pre release version.
Anyone who downloaded the comm. tool between 10-12/3/09 will have received this incorrect pre release version.
This version does not have all the bug fixes stated in TB10133. You may have problems talking with very old vigilon panels and inserting mains powered interfaces.


All the people that downloaded the comm. tool between these dates have been contacted and informed of this mistake.

The correct version of comm. tool v1.25 has now been uploaded (13/3/09)

Action:
Anyone receiving a copy of comm. tool v1.25 from a colleague should ensure they have the correct version.

The zip file should be called “CommTool_125-1.zip”

Once the comm. tool is installed if you look in the top tool bar “help” “about this tool”
It should says “1.25-1 General release (26/02/09)”



Sorry for any inconvenience this may have cause

Name: Peter Dodge