GENT
by Honeywell

Technical Bulletin	TB 10144

To: Gent by Honeywell & System Integrators.	Date:7/08/2009
	Status: Active
	Type: SI

Product:
Nano. Release of new software, v1.41.

Details:
Nano software release v1.41

This resolved the issue where certain loop setups can cause the panel screen to blank out. as per TB10142

Action:
We recommend that all existing site with software v1.39 (shipped 23rd March 2009 to 1st August 2009) are upgrade to v1.41.

The new software will be sent out to all SI's that have brought Nano's between the above date in the form of an SD card.

The SD card can be used to update as many Nano panels as you have. Instructions on how to update the panels will be included with the SD cards but is also covered in the Nano commissioning manual.

Name: Peter Dodge