GENT

by Honeywell

Technical Bulletin	TB 10146

To: Gent by Honeywell & System Integrators.	**Date:**28/10/2009
	Status: Active
	Type: SI

Product:
Vigilon, using device test mode.

Details:
In the panel menu with free blocks turned on you can select to put a particular devices into test rather then a zone. (some old panels have this option without free blocks being turned on)
Doing this will NOT put the panel test LED on; this could lead to engineers forgetting to turn this function off.

Action:
We would recommend only using zone test mode as this does put the test LED on and therefore reminds engineers to turn this function off.

Name: Peter Dodge