Technical Bulletin	TB 10149

To: Gent by Honeywell & System Integrators.	Date:1/11/2009
	Status: Active
	Type: SI

Product: Comm tool, interface channel labels.
Details: When using the comm. tool to add interface channel labels only the first 32 characters are shown even when using tokenised words. Adding the label at the panel works fine.
Action: Viewing the label at the front of the panel will show you what label will be displayed. After uploading the full configuration from the comm. tool, if you then just upload the labels with the comm. tool this will send the full label (with any tokenised words) to the panel. Comm. tool v1.27 will have this issue fixed.

Name: Peter Dodge