GENT
by Honeywell

Technical Bulletin	TB 10161

To: Gent by Honeywell, System Integrators	Date: 18/06/10
	Status: Active
	Type: SI

Product – Part affected:
Nano comm. tool V2

Details:
In TB:10159 "Release of Nano MK2" it mentions the release of the new Nano comm. tool V2 and that this will work with old MK1 Nano panel. However it did not mention that once a MK1 panel has been uploaded from a V2 comm tool that the old V1 comm tool will no longer work on that MK1 panel.

Due to this, support (licences) for the Nano comm tool V1 will no longer be given after the 30th July

Action:
Ensure engineers are aware of this issue.
We would recommend engineers upgrade to the latest Nano comm. tool V2.0.7.1 ASAP.

Name: Peter Dodge