PDF-XChange
Click to buy NOW!
www.docu-track.com

GENT
by Honeywell

Technical Bulletin	TB 10182

To: Gent by Honeywell, System Integrators	Date: 28/11/12
	Status: Active
	Type: SI

Product – Part affected:
Vigilon, 12V 21Ah Batteries

Details:
Our supplier of batteries for the Vigilon range of panels has made an unapproved change to battery 4015-602 (12V 21Ah). A batch of new batteries received on 28-May-2012 has terminals that support an M6 size of battery cable connector.
The original spares packs we sold with our panels contain M5 size battery cable connectors.
This could result is that the engineer on site will not be able to connect batteries to the panel using the cables and connectors.
Batteries with M6 sized terminals can be identified by the date code “111209 HAC” which is on the battery carton and printed on the top of the battery itself. “Made In Vietnam” is also printed clearly on the carton and the battery. We do not believe batteries with a “Made In China” label will be affected..

Action:
The spares packs (that come with the panel and ordered separately) have been altered so now contain battery connector for both M5 and M6.

All currently supplied batteries come with the correct M5 connection

Make sure engineers are aware that old spares packs will not have both connectors

Name: Peter Dodge