GENT
by Honeywell

Technical Bulletin

TB:10196 I July 2014

Product parts affected

New VAD S4 devices and Comm tool v1.29



Details

We have released new VAD's (Visual Alarm Device) to comply with EN54 part 23

Part numbers have been altered and where we used to have ST = strobe, we now have VAD = visual alarm device.

Sounder only devices have also had –S added on the end.

To get the full benefit of the changes we have made you need a panel made after January 2014 with MCC software V4.52 or above, the new high powered loop card and a loop with only new S4 devices on. Output devices (sounders or strobes) need to be the new type to get the full power on the loop so have either VAD or –S in the part number.

The S3 wall sounder variants for part 23 will be released later in the year.

For more information on the new part 23 devices or the new loop card pleases download the relevant datasheets from the download section on Gentexpert under Vigilon.

There is also a new commissioning tool to go along with the release of these new devices v1.29.

Action:

Update your commissioning Tool to the latest release.

Review the information on the new devices and loop card before trying to commission a system.

Commissioning engineer online training on the new part 23 devices will be held over the next couple of weeks please look on LMS for date and to book on. These will give an overview of the new part 23 devices. Only existing trained engineers will be able to log on to the course

Technical Support
140 Waterside Road
Hamilton Industrial Park
Leicester
LE5 1TN

t 0116 2462134
e technical.services@honeywell.com
w www.gentexpert.co.uk