Honeywell | Fire Safety
GENT

Gent Technical Bulletin

TB: 10224

Product – Parts Affected:

Commissioning tool v1.33 Services pack 2

Details:

We have released a new Services Pack for commissioning tool v1.33.

This Service Pack has been released to resolve the following issue: If any channels are changed to an input in the S4 mains interface page once this page was saved, that mains interface would no longer appear in the mains interface page.

This would mean that no further changes could be made to the mains interface.

Action:

Before working on any mains interface please ensure you upgrade to Service Pack 2.

We would recommend updating to this new Service Pack at your earliest convenience.

For more information
www.gent.co.uk
www.gentexpert.co.uk

Honeywell Gent
140 Waterside Road
Hamilton Industrial Park
Leicester
LE5 1TN UK

T: +44 (0) 116 246 2134
E: gentenquiry@honeywell.com

For further details on these or any other Gent products please contact your Gent Business Manager or via our contact details found below.

© 2017 Honeywell International Inc.