GENT
by Honeywell

Technical Bulletin

TB:10204 I August 2015

Product parts affected

New Vigilon, Compact panel software. MCC 4.53,LPC 4.49, RPT 1.09.



Details

We are releasing new panel software for both the Vigilon and Compact panels. This is in preparation for future functionality.

MCC / MCB = v4.53


LPC = V4.49

RPT = V1.08

IO = V4.15

These changes also include a change to the membrane changing the text for CB253 & 254 LEDs to Fire Routing Outputs. The User defined keys with command build 253 and 254 is still possible and this will operate the LEDs now labelled as Fire Routing so care should be taken to label these LEDs to avoid confusion for the end User.

See image bellow:



GENT
by Honeywell

Action

Make sure engineers are aware of these changes and look out for future announcements on new functionality.

Technical Support
140 Waterside Road
Hamilton Industrial Park
Leicester
LE5 1TN

t 0116 2462134
e technical.services@honeywell.com
w www.gentexpert.co.uk